

STANDARD BAR SPLICER ASSEMBLY

Minimum Lap Lengths				
Bar size to be spliced	Table 1	Table 2	Table 3	Table 4
3, 4	1'-5"	1'-11''	2'-1"	2'-4"
5	1'-9"	2'-5"	2'-7"	2'-11''
6	2'-1"	2'-11''	3'-1"	3′-6″
7	2'-9"	3'-10''	4'-2"	4'-8"
8	3′-8′′	5'-1"	5′-5′′	6'-2"
9	4'-7"	6'-5"	6'-10''	7′-9″

Table 1: Black bar, 0.8 Class C

Table 2: Black bar, Top bar lap, 0.8 Class C


Table 3: Epoxy bar, 0.8 Class C

Table 4: Epoxy bar, Top bar lap, 0.8 Class C

Threaded splicer bar length = min. lap length + l_2''' + thread length

* Epoxy not required on Bar Splicer Assembly components used in conjunction with black bars.

Location	Bar size	No. assemblies required	Table for minimum lap length
Deck	#5	16	3
Approach	#6	6	3
Deck	#7	32	3




BAR SPLICER ASSEMBLY FOR #5 BAR ON INTEGRAL OR SEMI-INTEGRAL ABUTMENTS

No. required =


DESIGNED		GGE	JANUARY 12, 2010
CHECKED		IJL	EXAMINED & Carl Prayey
DRAWN	Kyle M.	Steffen	PASSED Ralph E. andersa
CHECKED	GGE	IJL	ENGINEER OF BRIDGES AND STRUCTURES
RSD-1			11-1-09


STATE OF ILLINOIS DEPARTMENT OF TRANSPORTATION



INSTALLATION AND SETTING METHODS

"A": Set bar splicer assembly by means of a template bolt.
"B": Set bar splicer assembly by nailing to wood forms or cementing to steel forms.
(E): Indicates epoxy coating.





STANDARD MECHANICAL SPLICER

Location	Bar size	No. assemblies required

<u>NOTES</u>

Splicer bars shall be deformed with threaded ends and have a minimum 60 ksi yield strength.

All reinforcement shall be lapped and tied to the splicer bars.

Bar splicer assemblies shall be epoxy coated according to the requirements for reinforcement bars. See Section 508 of the Standard Specifications.

See special provision for Mechanical Splicers.

See approved list of bar splicer assemblies and mechanical splicers for alternatives.

BAR SPLICER ASSEMBLY AND
MECHANICAL SPLICER DETAILS
IL ROUTE 116 OVER SPOON RIVER
SN 029-0050

	SHEET NO.6	F.A.P. RTE.	SECTION	COUNTY	TOTAL SHEETS	SHEE'
		665	(142-BR)I	FULTON	25	14
	8 SHEETS			CONTRACT	NO. 68	3925
		FED. RC	AD DIST. NO. ILLINOIS FED. A	ID PROJECT		

0290050.dgn 12-Jan-10 08: 21: 00