COUNTY TOTAL SHEET NO.

DOUGLAS 65 36 SECTION COUNTY TO STA. FED. ROAD DIST. NO. ILLINOIS FED. AID PROJECT *(15, 21-25HB-2)BR CONTRACT NO. 90952

BILL OF MATERIALS PAY ITEM PAY ITEM DESCRIPTION UNIT OF MEASURE QTY. X0323710 REMOVE CONDUIT ATTACHED TO STRUCTURE F00T 273 F00T 1416 F00T 1616 BIGODZOG TRENCH & BACKFILL FOR ELECTRICAL WORK 81603005 UNIT DUCT, 600, 2-15-NO.6. () CHO.6 GROWND (XLPTYPE WSE) !" DIA
POLYETHY, ENE
BIOZISSO CONDUIT, AUGERED 2"DIA, PVC F007 200

LEGEND

- EXISTING UNIT DUCT W/(2) *6 XLP & (1) *6 XLP GROUND IN 1" POLYETHYLENE DUCT
- PROPOSED UNIT DUCT W/(2) *6 XLP & (1) *6 XLP GROUND IN 1" POLYETHYLENE DUCT

GENERAL NOTES

- UNLESS OTHERWISE SPECIFIED ALL WORK SHOWN ON SHEET IS THE
 RESPONSIBILITY OF CONTRACTOR.

 2 THE REMOVAL OF CONDUIT ATTACHED TO STRUCTURE

 3 THE CIRCUIT SHALL ONLY BE SPLICED IN THE POLE HANDHOLES.

- 4) UNIT DUCT SHALL BE REMOVED ACCORDING TO ARTICLE 842.03 OF THE STANDARD SPECS.
- 5) THE CONTRACTOR CAN USE EITHER PUSHED OR BORED METHOD TO INSTALL THE CONDUIT, AUGERED 2" DIA. PVC

ILLINOIS DEPARTMENT OF TRANSPORTATION INTERCHANGE LIGHTING SCALE: NTS FILE: 2114LIGHT DATE 4/12/06 DRAWN BY CHECKED BY

--- **Ç** IL 133 **→⑥**→ Z -EXISTING POLE 503 RAMP C RAMP A INSTALL **150** FT CONDUIT, AUGERED 2" DIA., PVC - ¢ FAI 57 _______________________________ INSTALL NEW UNIT DUCT W/(2) *6 XLP & (1) *6 XLP GROUND IN 1" POLYETHYLENE FROM POLE 502 TO POLE 503 REMOVE EXISTING UNIT DUCT AND CONDUIT ATTACHED TO STRUCTURE -RAMP D RAMP B EXISTING POLE 502-┘ INSTALL 50 FT └ CONDUIT, AUGERED 2" DIA., PVC

SCHEMATIC - NOT TO SCALE