

F.A.P. RTE.	SECTION	COUNTY	TOTAL SHEETS	SHEET NO.
326		LIVINGSTON	354	350
STA.		TO STA.		
FED. ROAD DIST. NO.		ILLINOIS FED. AID PROJECT		
*(123,123)RS-3, (124)RS-5, (123)BR-3				

FOR INFORMATION ONLY

So-Deep Test Hole Certification Form

© So-Deep 1988, 1991

Condition of paving prior to work
ASP. RDWY. IN GOOD CONDITION

Contract # **SM8024**
Test Hole # **28**
Plan Scale **1" = 20'**
Sheet # **81**
Proposed **GRADE CHANGE**
Date **AUGUST 14, 2007**

City, County, State **FORREST, LIVINGSTON CO., IL**
Gen. Loc. **SW CORNER BULLARD ST. & CENTER ST.**
Recorded Size/Material/Type **4" C.I. WATER LINE**
Foreman/Truck/Form By **J. HENRY / 221 / J. HENRY**

B.M. 1 Elev. = **688.39'**
IS GIVEN
Description: **(BMM) CHS "1" FOUND, ON E SIDE OF CONC. MH, 41' RT OF CL STA 1247+90, CENTER ST.**

B.M. 2 Elev. = **688.16'**
IS GIVEN
Description: **CHS "X" IN RIM OF SMH, 30.41' RT OF CL STA 1250+06.77, CENTER ST.**

Benchmarks check **BY 8.07'**
Elevations are referenced to **B.M.#1**

Recorded Size/Type of utility **WAS FOUND**
There **WERE NOT** additional utilities in the test hole.
The utility **WAS** in good condition. **SEE REMARKS**

Paving Thickness and type **ASPHALT**

Color of ribbon installed **BLUE**

Soil Type **MOIST BROWN**

Field Condition **ASP. RDWY.**

T.H. tied to **P.K. NAIL**

10 3/4" METALLIC PIPE - SUBMERGED STEEL GAS LINE
Portion of pipe exposed for O.D. measurement:
FULL

Remarks: **"RICK HARDESSY OF FORREST VILLAGE WATER DEPT. HAS INDICATED THAT THE 10 3/4" METALLIC PIPE SERVES AS A CASING FOR THE 4" C.I. WATER LINE. CREW FOUND THE CASING PIPE CORRODED AT THIS LOCATION.**

So-Deep, Corporate Office
8397 Euclid Avenue
Manassas Park, VA 20111
(703)361-6005

SO-DEEP will attempt to use the BMM most applicable to your design. If however, BMM offer by more than .05', resulting differences could cause design conflicts.

So-Deep Test Hole Certification Form

© So-Deep 1988, 1991

Condition of paving prior to work
NO PAVING

Contract # **SM8024**
Test Hole # **27**
Plan Scale **1" = 20'**
Sheet # **81**
Proposed **GRADE CHANGE**
Date **AUGUST 18, 2007**

City, County, State **FORREST, LIVINGSTON CO., IL**
Gen. Loc. **SW CORNER BULLARD ST. & CENTER ST.**
Recorded Size/Material/Type **4" WSTL GAS LINE**
Foreman/Truck/Form By **J. HENRY / 221 / J. HENRY**

B.M. 1 Elev. = **688.39'**
IS GIVEN
Description: **(BMM) CHS "1" FOUND, ON E SIDE OF CONC. MH, 41' RT OF CL STA 1247+90, CENTER ST.**

B.M. 2 Elev. = **688.16'**
IS GIVEN
Description: **CHS "X" IN RIM OF SMH, 30.41' RT OF CL STA 1250+06.77, CENTER ST.**

Benchmarks check **BY 8.07'**
Elevations are referenced to **B.M.#1**

Recorded Size/Type of utility **WAS FOUND**
There **WERE NOT** additional utilities in the test hole.
The utility **WAS** in good condition.

Paving Thickness and type **NO PAVING**

Color of ribbon installed **YELLOW**

Soil Type **MOIST BROWN**

Field Condition **GRASS RW**

T.H. tied to **PEG**

4" WSTL GAS LINE
Portion of pipe exposed for O.D. measurement:
FULL

Remarks: **NONE**

So-Deep, Corporate Office
8397 Euclid Avenue
Manassas Park, VA 20111
(703)361-6005

SO-DEEP will attempt to use the BMM most applicable to your design. If however, BMM offer by more than .05', resulting differences could cause design conflicts.

So-Deep Test Hole Certification Form

© So-Deep 1988, 1991

Condition of paving prior to work
NO PAVING

Contract # **SM8024**
Test Hole # **28**
Plan Scale **1" = 20'**
Sheet # **81**
Proposed **GRADE CHANGE**
Date **AUGUST 18, 2007**

City, County, State **FORREST, LIVINGSTON CO., IL**
Gen. Loc. **SW CORNER BULLARD ST. & CENTER ST.**
Recorded Size/Material/Type **4" C.I. WATER LINE**
Foreman/Truck/Form By **J. HENRY / 221 / J. HENRY**

B.M. 1 Elev. = **688.39'**
IS GIVEN
Description: **(BMM) CHS "1" FOUND, ON E SIDE OF CONC. MH, 41' RT OF CL STA 1247+90, CENTER ST.**

B.M. 2 Elev. = **688.16'**
IS GIVEN
Description: **CHS "X" IN RIM OF SMH, 30.41' RT OF CL STA 1250+06.77, CENTER ST.**

Benchmarks check **BY 8.07'**
Elevations are referenced to **B.M.#1**

Recorded Size/Type of utility **WAS FOUND**
There **WERE NOT** additional utilities in the test hole.
The utility **WAS** in good condition.

Paving Thickness and type **NO PAVING**

Color of ribbon installed **BLUE**

Soil Type **MOIST BROWN**

Field Condition **GRASS RW**

T.H. tied to **PEG**

4" C.I. WATER LINE
Portion of pipe exposed for O.D. measurement:
FULL

Remarks: **NONE**

So-Deep, Corporate Office
8397 Euclid Avenue
Manassas Park, VA 20111
(703)361-6005

SO-DEEP will attempt to use the BMM most applicable to your design. If however, BMM offer by more than .05', resulting differences could cause design conflicts.

REVISIONS	
NAME	DATE

ILLINOIS DEPARTMENT OF TRANSPORTATION

SUBSURFACE UTILITY EXPLORATION

SCALE: VERT. _____
HORIZ. _____

DATE _____

DRAWN BY _____
CHECKED BY _____

PLOT DATE = Dec 16, 2007 11:53:12 AM
FILE NAME = p:\proj\6376\consult\so-deep\sub\sub024.dgn
PLOT SCALE = 20.0000 / IN
USER NAME = schwankeg