



SECTION 'A-A'






DETAIL "A"

DETAIL "B"

CABLE MARKER DETAILS SCALE: NONE



EXISTING ELECTRIC SERVICE PEDESTAL DETAIL

NOTES:


FINISHED GRADE-


- 1. CONTRACTOR WAS RESPONSIBLE FOR LOCATING AND PROTECTING UTILITIES. THE CONTRACTOR HAND-DUG THE TRENCH IN THE VICINITY OF UNDERGROUND UTILITIES. ANY DAMAGE DONE TO UTILITIES WAS REPAIRED BY THE CONTRACTOR AT NO EXPENSE TO THE GOVERNMENT.
- CONTRACTOR INSTALLED CABLE MARKERS FOR BURIED CABLING PER SECT. 18F.3g OF SPEC. FAA-GL-918C AND DWG GL-D-5388G.
- CONTRACTOR INSTALLED WARNING TAPE "CAUTION-UNDERGROUND CABLE". ALLEN SYSTEMS P.N. 0761315 OR EQUAL. INSTALLED 6" BELOW GRADE.
- 4. CONTRACTOR REPAIRED ALL DAMAGED SURFACES IN ACCORDANCE WITH FAA-GL-918C-2A.9d.

NOTES:

GROUND RODS NOT SHOWN IN TRENCH DETAILS.

SEE SITE PLAN FOR TRENCH TYPE LOCATION.





TRENCH BETWEEN PAPI POWER AND CONTROL RACK AND ELEC. HANDHOLE (SEE SITE PLAN DWG GL-D-2795-7-1)

IL. CONTRACT: DU077 IL. LETTING ITEM: 3A IL. PROJECT: DPA-3769 A.L.P. PROJECT: 3-17-0017-822 SURVEY BOOK # BOOK # REVISIONS BY DATE THIS BAR IS EQUAL TO 2" AT FULL SCALE (34X22). PAPI AND RELOCATE REIL LIGHTS DETAIL DUPAGE AIRPORT WEST CHICAGO, ILLINOIS S MISCELLANEOU **RUNWAY 28** INSTALL DESIGN BY DLP DRAWN BY: JRO CHECKED BY JRL APPROVED BY DLP DATE: MARCH 7, 2008

8-1/C #8, 4-# 6 GROUND, TYPE U.S.E. POWER CABLES IN 2" C TRENCH DETAIL SCALE: NONE c COMMON TRENCH AT POWER CONTROL RACK (SEE SITE PLAN DWG GL-D-2795-7-1)

GL-D-2795-7-6

JOB No: 07257-04