STATE OF ILLINOIS DEPARTMENT OF TRANSPORTATION

Embankment (Special) by Bridge Contractor after superstructure is in place.

Excavation for

placing Porous Granular Embankment

(Special) is paid for

as Structure

Backfill with

uncompacted

Porous Granular

Excavation.

Approach Pavement

Geotechnical Fabric

*4'' Ø Perforated

Pipe Drain

*Drainage Aggregate

for French Drains

Bk. of Abut. SECTION THRU INTEGRAL ABUTMENT

(Horiz. dim. @ Rt. L's)

*Included in the cost of Pipe Underdrains for Structures, 4".


63'' Bulb-7

Const. Joint -


All drainage system components shall extend to 2'-0" from the end of each wingwall except an outlet pipe shall extend until intersecting with the side slopes. The pipes shall drain into concrete headwalls. (See Article 601.05 of the Standard Specifications and Highway Standard 601101).

Geocomposite

Wall Drain



DESIGNED Daniel H. Tobias CHECKED W. A. Beisner drawn R. Sommer CHECKED



INDEX OF SHEETS

- 1. General Plan & Elevation
- 2. General Data
- 3.-5. Top of Slab Elevations
- 6. Superstructure
- Superstructure Details
- 8.&9. Diaphragm Details
- 10. Drainage Scupper 11. Anchor Bolt Details
- 12. Framing Plan
- 13.-16. Beam Details
- 17. West Abutment 18. East Abutment

- 19.-21. Piers 22. Bar Splicers 23.-27. Boring Details

TOTAL BILL OF MATERIAL

ITEM	UNIT	SUPER	SUB	TOTAL
Removal of Existing Structures	Each			1
Name Plates	Each	.1		1
Reinforcement Bars, Epoxy Coated	Pound	131660	15480	147140
Concrete Superstructure	Cu. Yd.	550.2		550.2
Bridge Deck Grooving	Sq. Yd.	1353		1353
Protective Coat	Sq. Yd.	1784		1784
Drainage Scuppers DS-33	Each	6		6
Furnishing and Erecting Precast Prestressed Bulb T beams. 63"	Foot	2417		2417
Concrete Structures	Cu. Yd.		178.4	178.4
Porous Granular Embankment (Special)	Cu. Yd.		227.4	227.4
Furnishing Steel Piles HP 10 x 57	Foot		721	721
Furnishing Steel Piles HP 14 x 102	Foot		1339	1339
Test Pile, Steel HP 10x57	Each		1	1
Test Pile, Steel HP 14x102	Each		1	1
Driving Piles	Foot		2060	2060
Underwater Structure Excavation Protection, Location 1	Each	1		1
Underwater Structure Excavation Protection, Location 2	Each	1		1
Underwater Structure Excavation Protection, Location 3	Each	1		1
Stone Riprap, Class A4	Sq. Yd.		686	686
Filter Fabric	Sq. Yd.		686	686
Bar Splicers	Each	62		62
Structure Excavation	Cu. Yd.		145	145
Pipe Underdrain for Structures, 4''	Foot		<i>1</i> 50	150
Geocomposite Wall Drain	Sq. Yd.		80.8	80.8
Concrete Encasement	Cu. Yd.		11.7	11.7
Asbestos Bearing Pad Removal	Each		44	44

-	ROUTE NO.	SECTION	COUNTY		TOTAL SHEET NO.		SHEET	NO.	,
	F.A.P. 857	101BR-6	WHI	TE	100	21 27		EETS	
	FEO. ROAD DIST. NO. 7		B.LINGIS	PED. AID PROJECT-					

SHEET NO. 2

Contract #98960

GENERAL NOTES

Reinforcement bars shall conform to the requirements of ASTM A706 Gr. 60 (IL Modified). See Special Provisions.

The embankment configuration shown shall be the minimum embankment that must be placed and compacted prior to construction of the abutments.

Layout of the slope protection system may be varied to suit ground conditions in the field as directed by the Engineer.

The Steel H-Piles shall be according to AASHTO M270 Gr.50.

The Contractor shall drive test piles to 110% of the nominal bearing specified in permanent loctions at substructures specified or approved by the Engineer before ordering the remainder of piles.

In addition to all other requirements of section 512 of the Standard Specifications, splices for HP10x57 and HP14x102 piles shall develop the full capacity of the steel's cross sectional area of the pile for tension, shear and bending forces. One approved method of achieving this requirement is full penetration butt welding of the entire cross section. Other types of splices meeting the full capacity requirement may be allowed subject to the approval of the Engineer. Any proposal by the Contractor to use an alternate splice method must include adequate documentation demonstrating that the full tension, shear and bending capacities will be met. Appropriate welder qualifications will be required for the positions and processes used in splicing all piles. Nondestructive testing of completed welds will be limited to visual inspection.

The existing structural steel coating contains lead. The Contractor shall take appropriate precautions to deal with the presence of lead on this project. Reinforcement bars designated (E) shall be epoxy coated.

be submitted to the Engineer for approval.

In New of the hammer selection criteria and use of the FHWA Modified Gates formula specified in Section 512 of the Standard Specifications, the Contractor shall conduct a wave equation analysis to establish the driving criteria at all pile foundations which specify a nominal required bearing above 600 kips. The analysis and calculations shall

The piles at the East Abortment shall be driven through 18" diameter precored holes extending to Elev. 350.00 according to Article 512.09(c) of the Standard Specifications, cost included in Driving Piles.

GENERAL DATA F.A.P. RT. 857 SEC. 101BR-6 WHITE COUNTY STATION 171+58.50 STRUCTURE NO. 097-0071

A Rev. 2-22-07