

### STANDARD BAR SPLICER ASSEMBLY

Minimum Lap Lengths						
Bar size to be spliced	I able I		Table 3	Table 4		
3, 4	1'-5"	1'-11''	2'-1"	2'-4''		
5	1'-9''	2'-5"	2'-7"	2'-11''		
6	2'-1"	2'-11''	3'-1''	3'-6"		
7	2'-9''	3'-10''	4'-2"	4'-8''		
8	3′-8′′	5'-1''	5′-5′′	6'-2''		
9	4'-7''	6′-5′′	6'-10''	7′-9′′		

Table 1: Black bar, 0.8 Class C

Table 2: Black bar, Top bar lap, 0.8 Class C


Table 3: Epoxy bar, 0.8 Class C

Table 4: Epoxy bar, Top bar lap, 0.8 Class C

Threaded splicer bar length = min. lap length +  $1_2^{\prime\prime}$  + thread length

\* Epoxy not required on Bar Splicer Assembly components used in conjunction with black bars.

Location	Bar size	No. assemblies required	Table for minimum lap length		
W. Appr. (Top)	#4	8	4		
W. Appr. (Bott.)	#5	14	3		




# BAR SPLICER ASSEMBLY FOR #5 BAR ON INTEGRAL OR SEMI-INTEGRAL ABUTMENTS

No. required =

DESIGNED		IJL	APRIL 30, 2010
CHECKED		GGE	EXAMINED & Carl Prayry
DRAWN	Kyle M.	Steffen	PASSED Ralph E. andersan
CHECKED	IJL	GGE	engineer of Bridges and Structures
BSD-1			11-1-09

0710015.dgn 30-Apr-10 08: 29: 35


# STATE OF ILLINOIS DEPARTMENT OF TRANSPORTATION




#### INSTALLATION AND SETTING METHODS

"A": Set bar splicer assembly by means of a template bolt.
"B": Set bar splicer assembly by nailing to wood forms or cementing to steel forms.

(E): Indicates epoxy coating.





#### STANDARD MECHANICAL SPLICER

Location	Bar size	No. assemblies required		
W. Appr. (Bott.)	#8	49		

# BAR SPLICER ASSEMBLY AND MECHANICAL SPLICER DETAILS STRUCTURE NO.

<u>NOTES</u>

Splicer bars shall be deformed with threaded ends and have a minimum 60 ksi yield strength.

All reinforcement shall be lapped and tied to the splicer bars.

Bar splicer assemblies shall be epoxy coated according to the requirements for reinforcement bars. See Section 508 of the Standard Specifications. See special provision for Mechanical Splicers.

See approved list of bar splicer assemblies and mechanical splicers for alternatives.

## BAR SPLICER ASSEMBLY AND MECHANICAL SPLICER DETAILS SN 071-0015

SHEET NO. 4	F.A.P. RTE.	SEC	ΓΙΟΝ		COUNTY	TOTAL SHEETS	SHEET NO.	
	SHEET NO. 4	17	(102BR)M	& (39BR)N	M	OGLE	19	11
	4 SHEETS					CONTRACT	NO. 64	G13
		FED. RC	AD DIST. NO.	ILLINOIS F	ED. AI	D PROJECT		