
*13R-1:(9)TS:(12B)L.I-1

REPAIR EXISTING CONDUIT ATTACHED TO STRUCTURE - OTY. 1.0 LUMP SUM (INCLUDES ALL ITEMS SHOWN IN DETAIL BELOW)



CONSTRUCTION NOTES

- 1. THE CONTRACTOR SHALL PERFORM ALL WORK IN ACCORDANCE WITH NEC REQUIREMENTS.
- 2. THE CONTRACTOR SHALL VERIFY ALL EXISTING QUANTITIES AND FIELD CONDITIONS PRIOR TO BIDDING. THERE WILL BE NO ADDITIONAL COMPENSATION.
- 3. ALL CONDUITS AND JUNCTION BOXES SHALL BE SECURELY ANCHORED TO THE STRUCTURE UTILIZING DRILLED IN ANCHORS OF SUFFICIENT SIZE AND DEPTH.
- 4. THE CONTRACTOR SHALL DISPOSE OF ALL REMOVAL ITEMS IN ACCORDANCE WITH ARTICLE 202.03 OF THE STANDARD SPECIFICATION.
- THE CONTRACTOR SHALL BE RESPONSIBLE FOR MAINTAINING THE OPERATION OF THE ROADWAY AND NAVIGATIONAL LIGHTS DURING THE CONDUITS AND JUNCTION BOX REPLACEMENT. THIS WORK SHALL BE INCLUDED IN THE COST OF THE CONDUIT REPAIR PAY ITEM.
- 6. ANY MAINTENANCE OF EXISTING LIGHTING SHALL BE CONSIDERED EXTRA WORK IN ACCORDANCE WITH ARTICLE 109.04 OF THE STANDARD SPECIFICATIONS.

SCHEDULE OF QUANTITIES				
REPAIR EXISTING CONDUIT ATTACHED TO STRUCTURE	1.0	LSUM		

OVERHEAD LIGHTING SHEET 1 OF 3

NAME	DATE	ILLINOIS DEPARTMENT OF TRANSPORTATION
		IL 9 (MCNAUGHTON BRIDGE)
		LIGHTING SYSTEM
······································		CONDUIT REPAIR
		SCALE: VERT. DRAWN BY HORIZ. DATE CHECKED BY

NOT TO SCALE

UI UHIE - 3/20/2000 E HAME - SAGENDROPS E HAME - 106/2024 / IN

PLOT DATE = 3/28/206 FILE NAME = SINGENIO PLOT SCALE = 105,8824