

- \* VARIABLE 1'-6" LT OF CENTERLINE, 2'-0" RT OF CENTERLINE.
- \*\* EXTEND THE POROUS GRANULAR EMBANKMENT TO THE TOP OF THE DRAINHOLE FILTER FABRIC ENVELOPES.
- SPECIFICATIONS.
- 2. TRENCH BACKFILL SHALL BE COMPACTED BY EITHER METHOD 2 OR METHOD 3 SPECIFIED IN ARTICLE 550.07, OR IN ACCORDANCE WITH METHOD 1 SPECIFIED IN ARTICLE 550.07, EXCEPT THAT THE COMPACTED LIFTS SHALL NOT EXCEED 8" IN THICKNESS. TRENCH BACKFILL SHALL BE COMPACTED TO A MINIMUM OF 95% OF STANDARD LAB DENSITY.

All dimensions are in inches (millimeters) unless otherwise noted.

Not to Scale

FILE NAME =	USER NAME = hudelsonme	DESIGNED ~	REVISED -	STATE OF ILLINOIS	Detail of Excavation and					F.A.U RTE.	SECTION	COUNTY	TOTAL	HEET	
c:\projecta\il98\dilloncreek\profile.dgn		DRAWN -	REVISED -							6758	7-BR	TAZEWELL	21	11	
	PLOT SCALE = 40.0000 '/ IN.	CHECKED -	REVISED ~	DEPARTMENT OF TRANSPORTATION	Backfill for Box Culverts						CONTRACT		784		
	PLOT DATE = 4/15/2008	DATE -	REVISED -	sc	SCALE:	SHEET NO.	OF	SHEETS	STA.	TO STA.	FED. ROAD DIST	. NO. ILLINOIS FED.			