




TYPICAL MASONRY WALL




BOND BEAM UNIT AT CORNER






CENTERING AND CAGING DEVICES



PLAN SECTION NON-STRUCTURAL BOND BEAM CONTROL JOINT



SLOT FOR ADJUSTABLE UNIT TIE (DOVE FAIL ANCHOR) STEEL COLUMN TIE

DETAIL

MOUTE NO. SECTION COUNTY TOTAL SHEETS SHEET NO. 7 F.A.I. 57 00-00374 Champaign 21 21 SHEETS

Contract # 91382

MASONRY NOTES:

- 1. MASONRY WORK ON THIS PROJECT SHALL CONFORM TO ALL REQUIREMENTS OF ACI 530.1-99, SPECIFICATION FOR MASONRY STRUCTURES, PUBLISHED BY THE AMERICAN CONCRETE INSTITUTE (ACI), DETROIT, MICHIGAN, EXCEPT AS MODIFIED BY THE REQUIREMENTS OF THESE CONTRACT DOCUMENTS.
- 2. CONTRACTOR SHALL SUBMIT SHOP DRAWINGS SHOWING ALL WALL REINFORCING.
- 3. CONCRETE MASONRY UNITS SHALL BE IN ACCORDANCE WITH ASTM C90, GRADE N, TYPE I.
- MORTAR SHALL CONFORM TO ASTM C270, TYPE S MORTAR.
- 5. COMPRESSIVE STRENGTH OF CONCRETE MASONRY (f'm) SHALL BE 1500 PSI MINIMUM.
- BAR REINFORCEMENT SHALL CONFORM TO ASTM A615 GRADE 60.
- 7. LENGTH OF BAR SPLICES SHALL BE EQUAL TO 48 BAR DIAMETERS. 8. JOINT REINFORCEMENT SHALL BE MADE OF COLD DRAWN WIRE AND SHALL CONFORM TO ASTM A82, JOINT REINFORCEMENT SHALL BE:
 - 3-9 GA, WIRE, LADDER TYPE FOR WALLS WITH BRICK VENEER
- 9. JOINT REINFORCEMENT, TIES AND ANCHORS SHALL BE GALVANIZED IN ACCORDANCE WITH ACT 530.1.
- JOINT REINFORCEMENT SHALL BE PLACED IN ALL MASONRY WALLS AND SPACED 16" O.C., UNLESS OTHERWISE NOTED.
- 11. ALL CELLS WITH REINFORCEMENT, BOND BEAMS, MASONRY LINTELS AND SILLS SHALL BE FULLY GROUTED. GROUT SHALL CONFORM TO ASTM C476 AND SHALL HAVE 28-DAY COMPRESSIVE STRENGTH OF 2000 PSI MINIMUM.
- 12. VERTICAL REINFORCEMENT SHALL TERMINATE WITH A 90 DEGREE HOOK AT THE TOP OF ALL WALLS.
 13. LAY CONCRETE MASONRY UNITS WITH FULL MORTAR COVERAGE ON
- HORIZONTAL AND VERTICAL FACE SHELLS AND WEBS.
- 14. MASONRY APPURTENANCES INCLUDING MASONRY DOWEL RODS. DOVE TAIL ANCHORS, WIRE REINFORCEMENT, BOND BEAMS AND MASONRY REINFORCEMENT ARE INCLUDED IN THE UNIT PRICE FOR MASONRY COLUMN OF THE SIZE SPECIFIED AND NO ADDITIONAL COMPENSATION WILL BE ALLOWED.

MASONRY DETAILS CURTIS ROAD BRIDGE ENHANCEMENTS CHAMPAIGN COUNTY STATION 297+20.45



DESIGN FIRM REGISTRATION No. 184-000450

1817 SOUTH NEIL STREET SUITE 100 CHAMPAIGN, IL 61820 PHONE : 217.373.8900 FAX: 217.373.8923

DESIGNED SLD CHECKED SMM DRAWN SLD CHECKED SMM