

| FÆ- | SECTION | COUNTY | TOTAL SHEETS | SHEET NO. |
|-----|----------------------------------|--------|-----------------|--------------|
| | 03-00026-00-PK 06-00026-01-MS | | 53 | 45 |
| | FEDERAL AID P | ROJECT | | |

KEYED NOTES

E.C. SHALL FURNISH AND INSTALL AIPHONE LE—DA OUTDOOR WEATHERPROOF INTERCOM STATION WITHIN EXISTING ROUGH—IN INSTALLED DURING PHASE 1 CONSTRUCTION. PROVIDE A 4 CONDUCTOR 18 AWG STP CABLE WIRING HOMERUN FROM EACH STATION TO THE MASTER STATION IN THE GIFT SHOP. SEE SHEET E4—01 FOR LOCATION OF MASTER STATION.








211 N. Broadway Suite 1900 St. Louis, MO 63102 (314) 241-8188 FAX (314) 241-0125

LEWIS AND CLARK MEMORIAL TOWER VILLAGE OF HARTFORD, ILLINOIS 62049


SHEET TILE.
LANDING ELECTRICAL
PLANS



KENNEDY PROJECT NO KAI= 10-02048

ISSUE DATE APRIL 11, 2008

E4-02



INSTALL HEAT DETECTOR FOR ELEVATOR RECALL ON EXISTING JUNCTION BOX.

CONDUITS INSTALLED IN PHASE 1
CONSTRUCTION