


SERVICE ENTRANCE ELEVATION

NOTES FOR ELECTRIC SERVICE

- CONTRACTOR SHALL COORDINATE SERVICE ENTRANCE WORK WITH THE SERVING ELECTRIC UTILITY; (JO-CARROLL ENERGY, 793 U.S. ROUTE 20 WEST, P.O. BOX 390, ELIZABETH, IL 61028, ATTN. MR. BOB PELELO, PHONE: 815-858-2207 EXT 249, CELL PHONE: 815-858-4142). SERVICE ENTRANCE WORK SHALL BE PAID FOR UNDER AR109200 INSTALL ELECTRICAL EQUIPMENT PER L.S. SERVICE ENTRANCE WORK SHALL ALSO BE COORDINATED
- 2. CONTRACTOR SHALL COORDINATE ANY POWER OUTAGES WITH THE AIRPORT MANAGER.
- EXISTING VAULT SERVICE METER BASE, DISCONNECT, SERVICE CONDUIT & WIRE, & FEEDER CONDUCTORS SHALL BE REMOVED & DISPOSED OF BY THE CONTRACTOR UPON TRANSFER OF POWER & AIRFIELD LIGHTING CIRCUITS TO THE NEW VAULT. EXISTING METER SHALL BE TURNED OVER TO SERVING ELECTRIC UTILITY. REMOVAL WORK SHALL BE PAID FOR UNDER AR109901 REMOVE ELECTRICAL VAULT PER L.S.



NOTES

- REPLACE EXISTING POWER & CONTROL WIRING WITH NEW WIRING FROM THE PROPOSED VAULT TO THE EXISTING FUEL FACILITY. REPLACE EXISTING CONDUIT SEAL OFF FITTINGS AT THE FUEL FACILITY.
- CONDUIT SEAL OFF FITTINGS SHALL BE UL LISTED OR FM APPROVED SUITABLE FOR CLASS I, DIV. 1, GROUP D LOCATION. PER UL STANDARD 886 & NEC 501.15(C)(6), THE CROSS-SECTIONAL AREA OF THE CONDUCTORS PERMITTED IN A SEAL SHALL NOT EXCEED 25 PERCENT OF THE CROSS-SECTIONAL AREA OF A RIGID METAL CONDUIT OF THE SAME TRADE SIZE UNLESS IT IS SPECIFICALLY IDENTIFIED FOR
- COORDINATE RELOCATION OF TELEPHONE SERVICE WITH THE SERVING TELEPHONE COMPANY & THE AIRPORT MANAGER. THE SERVING TELEPHONE COMPANY IS GALLATIN RIVER COMMUNICATIONS, PHONE 1-800-371-6712.

FUEL SYSTEM J-BOX ELEVATION AT VAULT BLDG NOT TO SCALE

TRI-TOWNSHIP AIRPORT SAVANNA, CARROLL COUNTY ILLINOIS HANSON

CONSTRUCT
NEW VAULT
LECTRICAL DETAILS
SHEET 1

19 19 of 24 sheets