


LIGHT POLE WIRING



PAVED AREAS

NON-PAVED AREAS

HEAT-SHRINKABLE CAP WITH FACTORY APPLIED

NUMBER OF CABLES).

WATERPROOF SEALANT (SIZED TO ACCOMMODATE

ELECTRIC FEEDER CABLES

SUCH AS UNIT DUCT (SIZE. AS NOTED ON CONTRACT

> ELECTRIC CABLE TO LUMÎNAIRE (SIZE AS NOTED ELSEWHERE IN THESE PLANS).

DRAWINGS).

-TRIMMED CABLES

COMPRESSION TYPE

COPPER SLEEVE (SIZED FOR CABLES AND MFR. SUGGESTED CRIMP TOOL USED)

SEALANT TAPE OR \_INSERT (AROUND AND THROUGH

CROTCH OF SPLICE).

EXPOSED SEALANT NOTE THAT NUMBER OF CABLES IN

SPLICE MAY VARY

TOTAL SHEET NO.

SPLICING ELECTRIC CABLES BASIC MATERIALS & METHODS

CONDUIT TRENCH BACKFILL DETAIL

USER NAME = \$USER\$ DESIGNED - HEV REVISED SECTION COUNTY CONSTRUCTION DETAILS WEST BARTLETT ROAD DRAWN - DRP REVISED 10-00068-00-LT COOK 30 26 MISCELLANEOUS ELECTRICAL PLOT SCALE = \$SCALE\$ CHECKED - MJR REVISED STREETSCAPE CONTRACT NO. 63512 DATE 12-22-10 REVISED SCALE: NONE SHEET NO. 2 OF 4 SHEETS