DRAINAGE & UTILITIES NOTES:

ON THE PLANS.

- 1. THE LOCATIONS OF EXISTING UTILITIES, AS SHOWN ON THE DRAWINGS, REPRESENT DATA RECEIVED FROM VARIOUS SOURCES. IT IS NOT GUARANTEED TO BE CORRECT OR ALL INCLUSIVE. THE CONTRACTOR MUST CONDUCT HIS OWN INVESTIGATIONS INTO THE LOCATION, SIZE, DEPTH, AND NATURE OF ANY AND ALL EXISTING UTILITIES WHICH MAY IMPACT THE WORK UNDER THIS CONTRACT. ANY EXISTING UTILITIES WHICH ARE TO REMAIN IN SERVICE MUST BE FULLY PROTECTED BY THE CONTRACTOR AND ANY DAMAGE CAUSED BY THE CONSTRUCTION MUST BE IMMEDIATELY REPAIRED AT THE CONTRACTOR'S EXPENSE TO THE SATISFACTION OF THE ENGINEER. THE CONTRACTOR WILL BE RESPONSIBLE FOR THE PROTECTION OF ANY AND ALL SURFACE AND UNDERGROUND UTILITIES, EVEN THOUGH THEY MAY NOT BE IDENTIFIED
- 2. THE CONTRACTOR MUST COORDINATE CONSTRUCTION ACTIVITIES WITH THE RESPECTIVE UTILITIES OF THE CITY OF CHICAGO. BEFORE STARTING ANY EXCAVATION, THE CONTRACTOR MUST CALL THE CHICAGO UTILITY ALERT NETWORK (C.U.A.N.) AT (312) 744-7000 FOR FIELD LOCATIONS OF BURIED ELECTRICAL, TELEPHONE, CABLE, AND GAS FACILITIES (48 HOURS NOTIFICATION IS REQUIRED). THE CONTRACTOR MUST CONTACT THE CITY OF CHICAGO DEPARTMENT OF WATER MANAGEMENT, PERMIT SECTION AT (312) 747-7893 FOR WATER AND CITY SEWER LOCATIONS.
- 3. THE CONTRACTOR MUST MAINTAIN THE SURFACE DRAINAGE OF ALL ROADWAYS DURING CONSTRUCTION OF THIS PROJECT. WHEN EXISTING DRAINAGE FACILITIES ARE DISTURBED, THE CONTRACTOR MUST PROVIDE AND MAINTAIN TEMPORARY OUTLETS AND CONNECTIONS FOR ALL PRIVATE OR PUBLIC DRAINS, SEWERS, INLETS, AND CATCH BASINS. THE CONTRACTOR MUST PROVIDE FACILITIES TO TAKE IN ALL STORM WATER WHICH WILL BE RECIEVED BY THESE DRAINS AND SEWERS AND DISCHARGE THE SAME. THE CONTRACTOR MUST PROVIDE AND MAINTAIN A TEMPORARY OUTLET, AND BE PREPARED AT ALL TIMES TO DISPOSE OF THE WATER RECEIVED FROM THESE TEMPORARY CONNECTIONS UNTIL INSTALLATION IS COMPLETE, INCLUDING PAVEMENT. THIS WORK WILL NOT BE PAID FOR SEPARATELY BUT MUST BE CONSIDERED INCLUDED IN THE COST OF THE CONTRACT.
- 4. WHEN, DURING CONSTRUCTION OPERATIONS, ANY LOOSE MATERIAL IS DEPOSITED IN DRAINAGE STRUCTURES AND THE FLOW OF WATER IS OBSTRUCTED, IT MUST BE REMOVED AT THE CLOSE OF EACH WORKING DAY. AT THE CONCLUSION OF CONSTRUCTION OPERATIONS, ALL DRAINAGE STRUCTURES (NEW AND EXISTING) MUST BE FREE OF ALL DIRT AND DEBRIS. THIS WORK WILL NOT BE PAID FOR SEPARATELY BUT MUST BE CONSIDERED INCLUDED IN THE COST OF THE CONTRACT.
- 5. THE CONTRACTOR MUST PROTECT THE EXISTING MAIN DRAIN DROP MANHOLES FROM THE ENTRY OF ANY LOOSE MATERIAL AS DIRECTED BY THE ENGINEER. THIS WORK WILL NOT BE PAID FOR SEPARATELY BUT MUST BE CONSIDERED INCLUDED IN THE COST OF THE CONTRACT.
- 6. THE CONTRACTOR MUST PROTECT NEW DRAINAGE STRUCTURES FROM THE ENTRY OF ERODED SOILS AS DIRECTED BY THE ENGINEER. THIS WORK WILL NOT BE PAID FOR SEPARATELY BUT MUST BE CONSIDERED INCLUDED IN THE COST OF THE CONTRACT.
- 7. THE LOCATION OF DRAINAGE STRUCTURES AND PIPES CONSTRUCTED UNDER PREVIOUS CONTRACTS IS BASED ON CONTRACT PLAN DRAWINGS. THE CONTRACTOR MUST FIELD VERIFY LIMITS OF PREVIOUS CONSTRUCTION.
- 8. STORM SEWER PLUGS MUST BE INCLUDED IN THE COST OF THE ASSOCIATED PIPE REMOVAL ITEMS AND WILL NOT BE PAID SEPARATELY.
- 9. 'PIPE UNDERDRAINS 6" (SPECIAL)' WILL BE USED TO CONNECT TO DRAINAGE STRUCTURES.
- 10. THE CONTRACTOR MUST ENSURE POSITIVE DRAINAGE TO ALL INLETS, CATCHBASINS, AND OPEN MANHOLES.
- 11. GRATES MUST BE INSTALLED WITH THE VANES ORIENTED AS DIRECTED BY THE RESIDENT ENGINEER.
- 12. ALL TEMPORARY OR PERMANENT CONNECTIONS OF SEWERS AND UNDERDRAINS TO PROPOSED AND EXISTING DRAINAGE STRUCTURES, INCLUDING ANY NEW HOLES REQUIRED IN THE DRAINAGE STRUCTURE, MUST BE CONSIDERED INCLUDED IN THE COST OF THE ASSOCIATED STORM SEWER OR PIPE UNDERDRAIN ITEM. NO ADDITIONAL COMPENSATION WILL BE ALLOWED.
- 13. STATION AND OFFSET VALUES GIVEN FOR EXISTING STRUCTURES REPRESENT THE APPROXIMATE CENTER OF THE EXISTING CASTING.
- 14. DRAINAGE REMOVALS IN THE VICINITY OF THE CTA ARE SHOWN BASED ON RECORD DRAWINGS AND SURVEY WHERE AVAILABLE. ALL EXISTING ACTIVE DRAINGE CONNECTIONS FROM THE CTA MUST BE MAINTAINED. ALL ACTIVE DRAINAGE CONNECTIONS FROM THE CTA DISCOVERED DURING CONSTRUCTION MUST BE MAINTAINED AS DIRECTED BY THE ENGINEER. MAINTENANCE OF ANY ACTIVE DRAINAGE CONNECTIONS FROM THE CTA THAT ARE DISCOVERED DURING CONSTRUCTION WILL NOT BE PAID SEPARATELY, BUT MUST BE INCLUDED IN THE COST OF THE ASSOCIATED DRAINAGE REMOVAL ITEMS.
- 15. STATION AND OFFSET VALUES GIVEN FOR PROPOSED DRAINAGE STRUCTURES REPRESENT THE CENTER OF THE CASTING.
- 16. ALL 'DRAINAGE STRUCTURES, TYPE 1 SPECIAL' AND 'DRAINAGE STRUCTURES, TYPE 2 SPECIAL' MUST HAVE MINIMUM 2'-O" SUMP BELOW LOWEST INVERT ELEVATION.
- 17. PROPOSED STORM SEWER PLUGS ARE INCLUDED IN THE COST OF STORM SEWER PIPE. STORM SEWERS SHALL BE PLUGGED WITH BRICK AND SUITABLE MORTAR, OR BY AN ALTERNATE MEANS THAT IS ACCEPTABLE TO THE ENGINEER.

BOWMAN, BARRETT & ASSOCIATES INC.
CONSULTING ENGINEERS
Chicago, Illinois
312.228.0100
www.bbandainc.com

DRAINAGE & UTILITIES LEGEND:

 F.A.I. SECTION		COUNTY	TOTAL	SHEET NO.		
94/90 •		COOK	598	120		
STA. TO STA.						
FED. ROAD DIST. NO.	ILLIN	OIS FED. AID	PROJECT	-		
62302	*	(1818, ETC,	2324.6-1	P)R-9		

	EXISTING	PROPOSED		EXISTING	PROPOSED
STORM SEWER			INLET		
PIPE UNDERDRAIN	Dan Dan Dan		CATCH BASIN	\circ	
WATER MAIN	W		MANHOLE	0	\odot
GAS MAIN	⊢—— G ⊢——		SURFACE DRAINAGE STRUCTURE (SEE SCHEDULE FOR TYPE)		•
SANITARY SEWER		->>>>>	PGL CREST POINT		← +→
CABLE TELEVISION	CTV	сту	PGL SAG POINT		- ><-
FIBER OPTIC	F0	F0	PROPOSED DRAINAGE STRUCTURE NUMBER	4	(SS -XX)
TELEPHONE	т		MAIN DRAIN DROP MANHOLE	(jo	
ELECTRIC	·	E	JUNCTION CHAMBER TYPE 2		
UTILITY REMOVAL	/>/>/>/		STRUCTURE TO BE CLEANED	C	
ABANDONNED UTILITY			STRUCTURE TO BE FILLED	F	
			STRUCTURE TO BE REMOVED	R	
MAIN DRAIN SEWER	FLOW		STRUCTURE TO BE RECONSTRUCTED	REC	
			STRUCTURE TO BE ADJUSTED	ADJ	
			FRAMES AND GRATES TO BE ADJUSTED	A	

SUMMARY OF SPECIAL DRAINAGE STRUCTURES

	ITEM	STRUCTURE NUMBER	TYPE	STATION	OFFSET
	JUNCTION CHAMBER, NO. 1	JC 19-01	JUNCTION CHAMBER TYPE 2	2473+21	6' LT
	JUNCTION CHAMBER, NO. 2	JC 20-01	JUNCTION CHAMBER TYPE 2	2478+13	5' LT
	JUNCTION CHAMBER, NO. 3	JC 23-01	JUNCTION CHAMBER TYPE 2	2499+01	6' LT
	JUNCTION CHAMBER, NO. 4	JC 24-01	JUNCTION CHAMBER TYPE 2	2504+44	7' LT
	JUNCTION CHAMBER, NO. 5	JC 28-01	JUNCTION CHAMBER TYPE 2	2527+73	7′ LT
			······	************	
	}				
/			<u> </u>		
	JUNCTION CHAMBER, NO. 6	JC 32-01	JUNCTION CHAMBER TYPE 2	2554+02	3' LT
	<u> </u>				
				<u></u>	<u> </u>
	JUNCTION CHAMBER, NO. 7	JC 35-01	JUNCTION CHAMBER TYPE 2	2568+60	4' LT
	JUNCTION CHAMBER, NO. 8	JC 37-01	JUNCTION CHAMBER TYPE 2	2580+01	4' LT
	JUNCTION CHAMBER, NO. 9	JC 38-01	JUNCTION CHAMBER TYPE 2	2584+39	7' LT
				******	******
	Luumman	<u> </u>		<u> </u>	<u>.</u>
A	JUNCTION CHAMBER, NO. 10	JC 41-01	JUNCTION CHAMBER TYPE 2	2607+76	8' LT
CT7	JUNCTION CHAMBER, NO. 11	JC 44-01	JUNCTION CHAMBER TYPE 2	2620+91	4' LT

SEE STRUCTURAL DRAWINGS FOR DETAILS OF EXISTING MAIN DRAIN DROP MANHOLES AND PROPOSED JUNCTION CHAMBERS

SEE CONTRACT 62300 PLANS FOR EXISTING DROP MANHOLES

REVISIONS
NAME DATE
ADDENDUM 1 8/12/05 F.A.

ILLINOIS DEPARTMENT OF TRANSPORTATION

F.A.I. 94/90 (DAN RYAN EXPRESSWAY)

31ST STREET TO 71ST STREET

SB EXPRESS LANE RECONSTRUCTION

DRAINAGE NOTES AND LEGEND

SCALE: 1"=N.T.S DATE: 07/07/05 DRAWN BY: OC CHECKED BY: EED

DN-01