

LEGEND

REL X──

PROPOSED COMBINATION LIGHTING AND TRAFFIC SIGNAL UNIT POLE: ALUMINUM, 45' M.H., 15' TRUSS MAST ARM (IDOT HWY STD 877011, 877012) LUMINAIRE: 400W HPS, CUTOFF, FLAT GLASS, AE 325 SERIES OR APPROVED EQUAL

RELOCATED EXISTING ROADWAY LIGHTING UNIT WITH NEW CONCRETE FOUNDATION

PROPOSED ROADWAY LIGHTING UNIT POLE: ALUMINUM, 45' M.H., 15' TRUSS MAST ARM (IDOT DI DETAIL BE-401) LUMINAIRE: 400W HPS, CUTOFF, FLAT GLASS, AE 325 SERIES OR APPROVED EQUAL

EXISTING ROADWAY LIGHTING UNIT (ORIGINAL LOCATION) **X** EXISTING LUMINAIRE ON COMED POLE TO REMAIN

--EXISTING SERVICE INSTALLATION, 240/480V, 10, 3 WIRE

-PROPOSED SERVICE INSTALLATION, 240/480V, 10, 3 WIRE \boxtimes EXISTING LIGHTING CONTROLLER CABINET

lacksquarePROPOSED LIGHTING CONTROLLER CABINET, 240/480V, 10, 3 WIRE PROPOSED HANDHOLE

 \supset EXISTING HANDHOLE

GROUND ROD, % INCH × 10 FEET

----- UNIT DUCT

"T" TRENCHED


CONDUIT PUSHED (P), 2.5" DIA. GALVANIZED STEEL (UNLESS OTHERWISE NOTED)

XX LIGHT POLE CIRCUIT
XXX, XXX' LT/RT STATION OFFSET FROM BACK-OF-CURB

REMOVAL OF EXISTING LIGHTING UNIT

GENERAL NOTES

- IT SHALL BE THE CONTRACTOR'S RESPONSIBILITY TO MARK THE PROPOSED LOCATIONS OF ALL LIGHT POLES FOR EXAMINATION AND CONFIRMATION WITH THE RESIDENT ENGINEER. THE CONTRACTOR SHALL VERIFY ALL UTILITY LOCATIONS PRIOR TO AUGURING FOR LIGHT POLE FOUNDATIONS. THE EXACT LOCATIONS OF ALL ITEMS SHALL BE CONFIRMED WITH THE RESIDENT ENGINEER PRIOR TO STARTING WORK.
- PROPOSED ROADWAY LIGHT POLES SHALL HAVE A SET-BACK OF 2.0 FEET (MIN) FROM THE BACK OF CURB TO THE CENTER OF POLE, UNLESS OTHERWISE INDICATED ON THE PLANS OR AS DIRECTED BY THE ENGINEER.
- A GROUND ROD SHALL BE PROVIDED FOR EACH CONCRETE FOUNDATION. GROUNDING CONNECTIONS MADE TO THE FOUNDATION SHALL BE EXOTHERMICALLY WELDED, AS SPECIFIED IN THE PLAN DETAILS.
- THE CONTRACTOR SHALL NOTE THE REQUIREMENTS FOR THE ELECTRICAL SERVICE FOR THE PROPOSED ROADWAY LIGHTING. IT IS THE CONTRACTOR'S RESPONSIBILITY FOR TIMELY NOTIFICATION AND COORDINATION WITH THE ELECTRIC UTILITY COMPANY.
- PARALLEL UNIT DUCT RUNS SHOWN ON THE PLANS SHALL BE PLACED IN A COMMON TRENCH.
- THE CONTRACTOR SHALL MAKE SPECIAL NOTE OF THE SPECIFIED REQUIREMENTS FOR BURIED WARNING TAPE, SPECIFIED AS PART OF "TRENCH AND BACKFILL FOR ELECTRICAL WORK". THE INSTALLATION OF THE TAPE SHALL BE INSPECTED BY THE ENGINEER PRIOR TO BACKFILLING OR DURING PLOWING OPERATIONS, AS APPLICABLE.
- ALL CONDUIT IS PUSHED UNLESS OTHERWISE NOTED. CONDUIT LENGTHS SHOWN ON THE PLANS ARE APPROXIMATE. THE CONTRACTOR SHALL VERIFY THE ACTUAL DISTANCE REQUIREMENTS IN THE FIELD.
- THE EXISTING LIGHT POLES SHALL BE DISPOSED OR SALVAGED AS DIRECTED BY THE ENGINEER. THE POLE SHALL BE DISPOSED BY THE CONTRACTOR AT NO COST TO THE VILLAGE. THE SALVAGED POLES AND LUMINAIRES SHALL BE DELIVERED TO THE VILLAGE OF SKOKIE PUBLIC WORKS DEPARTMENT AT 9050 GROSS POINT ROAD.



CONTRACT NO. 63049 COUNTY TOTAL SHEET NO.

129 92

F.A.P. SECTION

350 00-00242-00-CH COOK

PLOT FILE PLOT

DATE NAME SCALE NAME