SHEET NO.14 24 SHEETS

Contract No. 7075 \*(57-4) R, HBY, HBR, (57-4VB) DN

## GENERAL NOTES

DESIGN: AASHTO Standard Specifications for Structural Supports for Highway Signs, Luminaires and Traffic Signals. ("AASHTO Specifications")

MEASUREMENTS: All dimensions are in millimeters (mm) except as noted.

CONSTRUCTION: Current (at time of letting) Illinois Department of Transportation Standard Specifications for Road and Bridge Construction, Supplemental Specifications and Special Provisions. ("Standard Specifications")

LOADING: 145 km/h WIND VELOCITY

WIND LOADING: 1.44 kPa normal to Sign Panel Area and truss elements not behind sign Loadina Diagram.

WALKWAY LOADING: Dead load plus 2.2 kN concentrated live load.

DESIGN STRESSES:

fy = 400 MPa (reinforcement)

WELDING: All welds to be continuous unless otherwise shown. All welding to be done in accordance with current AWS D1.1 and D1.2 Structural Welding Codes (Steel and Aluminum) and the Standard Specificiations.

MATERIALS: Aluminum Alloys as shown throughout plans. All Structural Steel Pipe shall be ASTM A53 Grade B with a minimum yield of 241 MPa, or A500 Grade B or C with a minimum yield of 319 MPa. If A500 pipe is substituted for A53, then the outside diameter shall be as detailed and wall thickness greater than or equal to A53. All Structural Steel Plates and Shapes shall conform to AASHTO M270M Gr. 250, Gr. 345 or Gr. 345W\*. Stainless steel for shims, sleeves and handhole covers shall be ASTM A240, Type 302 or 304, or another alloy suitable for exterior exposure and acceptable to the Engineer. The steel pipe and stiffening ribs at the base plate for the column shall have a minumum longitudinal Charpy V-Notch (CVN) energy of 20 J. at 4° C. (Zone 2) before galvanizing.

FASTENERS FOR ALUMINUM TRUSSES: All bolts noted as "high strenght" (HS) must satisfy the requirements of AASHTO M164 (ASTM A325), or approved alternate, and must have matching lock nuts. Threaded studs for splices (if Members interfere) must satisfy the requirements of ASTM A449, ASTM A193, Grade B7, or approved alternate, and must have matching lock nuts. Bolts and lock nuts not required to be high strength must satisfy the requirements of ASTM A307. All bolts and lock nuts must be hot dip galvanized per AASHTO M232. The lock nuts must have nylon or steel inserts. A stainless steel flat washer conforming to ASTM A240 Type 302 or 304, is required under both head and nut or under both nuts where threaded studs are used. High strength bolt installation shall conform to Article 505.04 (f) (2)d of the IDOT Standard Specifications for Road and Bridge Construction. Rotational capacity ("ROCAP") testing will not be required.

U-BOLTS AND EYEBOLTS: U-Bolts and Eyebolts must be produced from ASTM A276 Type304, 304L, 316 or 316L, condition A, cold finished stainless steel, or an equivalent material acceptable to the Engineer. All nuts for U-Bolts and Eyebolts must be lock nuts equivalent to ASTM A307 with nylon or steel inserts, and hot dip galvanized per AASHTO M232. A stainless steel flat washer conforming to ASTM A240, Type 302 or 304, is required under each U-Bolt and Eyebolt lock nut.

STEEL PIPE: DN indicates nominal diameter.

GALVANIZING: All Steel Grating, Plates, Shapes and Pipe shall be Hot Dip Galvanized after fabrication in accordance with AASHTO M111. Painting is not permitted.

ANCHOR RODS: Shall conform to AASHTO M314 Gr. 725 (105) with a minimum Charpy V-Notch (CVN) energy of 20 J at 5° C.

CONCRETE SURFACES: All concrete surfaces above an elevation 150 mm below the lowest final ground line at each foundation shall be cleaned and coated with Bridge Seat Sealer in accordance with the Standard Specifications.

REINFORCEMENT BARS: Reinforcement Bars designated (E) shall be epoxy coated in accordance with the Standard Specifications.

\*If M270M Gr. 345W steel is proposed, chemistry for plate to be used shall first be approved by the Engineer as suitable for galvanizing and welding.

FOUNDATIONS: The contract unit price for Concrete Foundations and Drilled Shaft Concrete Foundations shall include reinforcement bars complete in place.

## TOTAL RILL OF MATERIAL

| ITEM                                           | UNIT | TOTAL |
|------------------------------------------------|------|-------|
| OVERHEAD SIGN STRUCTURE CANTILEVER TYPE II-C-A | m    | 26.1  |
| OVERHEAD SIGN WALKWAY-CANTILEVER TYPE A        | m    | 16.3  |
| DRILLED SHAFT CONCRETE FOUNDATIONS             | m3   | 17.8  |
|                                                |      |       |
|                                                |      |       |
|                                                |      |       |

Structure Total Truss Lenath Elev. Ds Number Sian Area Type (1) C057I055L164.7 II-C-A 4.581 3.81 12.19 C057I055L164.8 37+297 | II-C-A | 8.58 3 974 15 10 II-C-A 9.20 266,400 5,100 18.43

| <u>I</u>        | russ Type<br>-C-A<br>I-C-A<br>II-C-A | Maximum Sign Area<br>15.8 m <sup>2</sup><br>31.6 m <sup>2</sup><br>37.2 m <sup>2</sup> | Maximum Length<br>7.6 m<br>9.2 m<br>12.2 m |         | _€ Upper Chord          |
|-----------------|--------------------------------------|----------------------------------------------------------------------------------------|--------------------------------------------|---------|-------------------------|
| 4.6 m<br>(Max.) | Мах                                  | 1.44 kPa on<br>iimum Sign Area<br>(See Table)                                          | 0.5 kPa                                    | Max.    | E appoi and             |
|                 | Mo                                   | nximum Length (See 1                                                                   | Fable)                                     | 9.2 m A | <b>-</b>                |
|                 | DESI                                 |                                                                                        | INC. DIACRAM                               |         | Bottom of<br>Base Plate |

DESIGN WIND LOADING DIAGRAM Parameters shown are basis for I.D.O.T. Standards Installations not within dimensional limits shown require special analysis for all components.

(1) After adjustments to level truss and insure adequate vertical clearance, all top and leveling nuts shall be tightened against the base plate with a minimum torque of 270 N·m. Stainless steel mesh shall then be placed around the perimeter of the base plate. Secure to base plate with stainless steel banding.

Note: Trusses shall be shipped individually with adequate provision to prevent detrimental motion during transport. This may require ropes between horizontals and diagonals or energy dissipating (elastic) ties to the vehicle. The contractor is responsible for maintaining the configuration and protection of the trusses.

| NUMBER | REVISION | DATE |
|--------|----------|------|
|        |          |      |
|        |          |      |
|        |          |      |
|        |          |      |
|        |          |      |

\_bJ

Upper Chord

Lower Chord

TYPICAL PLAN

Alternate Vertical Diagonal Bracing for <u>Eac</u>h

Cantilever Length (L) and Basis of Payment

Edge of

Pavement

TYPICAL ELEVATION

Looking in Direction of Traffic

Sign support structures may be subject to damaging vibrations and

maintenance of the structure. To avoid these vibrations and oscillations,

consideration should be given to attaching temporary blank sign panels to

oscillations when sign panels are not in place during erection or

(along © of truss)

Bay in Planes of Front and Back Chords

Walkway, railing and

lights (if required)

omitted for clarity

Bracing (Typ.)

Bracing (Typ.)

Truss

Alternate Direction of Horizontal

Sign Panel-

Elev. A

(Location varies)

the structure.

OSC - A - 1(M)

Elev. A = Elevation at point of minimum

clearance to sign, walkway support or truss.

11/1/2002

Diagonal Bracing for Each Bay in

Planes of Upper and Lower Chords

F.A.I. 55 SECTION (57-4)R, HBY, HBR, 10/08/04 (57-4VB)DM McLEAN COUNTY CHECKED BY MCE AWING NO. COOMBE-BLOXDORF P.C. Engineers /Land Surveyors 14 Springfield, Illinois Design Firm License No. 184-002703 OF 24 SHTS

CANTILEVER SIGN STRUCTURES GENERAL PLAN & ELEVATION ALUMINUM TRUSS & STEEL POST

9450