GENERAL

CLASS SI CONCRETE SHALL BE USED THROUGHOUT.

THIS SPECIFICATION COVERS SLOTTED DRAIN USED FOR THE REMOVAL OF WATER AS SHOWN ON THE PLANS.

THE SLOTTED DRAIN SHALL BE CORRUGATED PIPE CULVERT WITH INTEGRAL SLOTTED DRAINS.

BEFORE PLACING THE CONCRETE ADJACENT TO THE PIPE, THE SLOT SHALL BE COVERED BY EITHER THIN, FLAT METAL SHEETING OR BY A BOARD NOTCHED TO FIT OVER THE GRATE BARS. THIS COVERING MUST FIT CLOSELY IN THE SLOT TO PREVENT ENTRY OF CONCRETE INTO THE PIPE. PAVING OVER THE SLOTTED DRAIN WILL THEN BE ONE CONTINUOUS OPERATION OVER THE PROTECTED DRAIN. THE PROTECTION FOR THE DRAIN SLOT SHALL THEN BE REMOVED. THE PIPE SHALL DRAIN INTO THE SIDE OF THE INLET. THE OPENING WHERE THE SLOT IS REMOVED SHALL BE COVERED TO PREVENT CONCRETE FROM ENTERING THE PIPE.

THE CORRUGATED STEEL PIPE USED IN THE SLOTTED DRAIN SHALL MEET THE REQUIREMENTS OF AASHTO M36/ ASTM A7860.

THE CMP SHALL BE ALUMINIZED STEEL TYPE 2.

THE DIAMETER AND GAGE SHALL BE AS SHOWN ON THE PLAN.

STEEL GRATING SHALL MEET THE GALVANIZING REQUIREMENTS OF AASHTO M111.

THIS WORK WILL BE PAID FOR AT THE CONTRACT UNIT PRICE PER FOOT FOR SLOTTED DRAIN 15" WITH $1\frac{3}{4}$ " SLOT, AND SHALL INCLUDE ELBOWS, DRILLING HOLES IN GRATING, SUPPLYING AND PLACING A1 BARS, AND CONCRETE AND GRATING FOR DEPTH SPECIFIED ON PLANS.

USE APPROVED END CAP TO PREVENT CONCRETE ENTRY INTO THE PIPE DURING GUTTER CONSTRUCTION ON THE UPSTREAM END OF THE PIPE.

CONNECTIONS

THE CORRUGATED STEEL PIPE SHALL HAVE A MINIMUM OF TWO REROLLED ANNULAR ENDS.

THE SLOTTED DRAIN BANDS SHALL BE MODIFIED HUGGER BANDS TO SECURE THE PIPE AND PREVENT INFILTRATION OF THE BACKFILL.

WHEN THE SLOTTED DRAIN IS BANDED TOGETHER, THE ADJACENT

GRATES

THE GRATES SHALL BE MANUFACTURED FROM ASTM A670, GRADE 36 STEEL. THE SPACERS AND BEARING BARS (SIDES) SHALL BE $\frac{3}{6}$ "MATERIAL ±0.008".

THE SPACERS SHALL BE ON 6" CENTERS AND WELDED ON BOTH SIDES TO EACH BEARING BAR (SIDES) WITH FOUR (4) $1\frac{1}{4}$ " LONG $\frac{3}{6}$ " FILLET WELDS ON EACH SIDE OF THE BEARING BAR.

THE PLATE EXTENDER SHALL BE 7 GAGE STEEL MEETING ASTM A761.

THE ENGINEER MAY CALL FOR TENSILE STRENGTH TESTS ON THE GRATE IF THE GRATE IS NOT IN COMPLIANCE WITH THE ABOVE SPACER SPECIFICATIONS. IF TENSILE STRENGTH TESTS ARE CALLED FOR, MINIMUM RESULTS FOR AN IN-PLACE SPACER PULLED PERPENDICULAR TO THE BEARING BAR SHALL BE: T = 12,000 POUNDS FOR $2\frac{1}{2}$ " GRATE

GALVANIZING

THE GRATE AND PLATE EXTENDERS SHALL BE GALVANIZED IN ACCORDANCE WITH ASTM A123 EXCEPT WITH A 2 OZ. GALVANIZED COATING.


GRATE ATTACHED TO CSP

T = 15,000 POUNDS FOR 6" GRATE

THE GRATE SHALL BE FILLET WELDED WITH A MINIMUM WELD 1" LONG TO THE CSP ON EACH SIDE OF THE GRATE AT EVERY OTHER CORRUGATION.

TOLERANCES - FINISHED SLOTTED DRAIN - 20' LENGTH


VERTICAL BOW = $\pm \frac{3}{8}$ " HORIZONTAL BOW = $\pm \frac{5}{8}$ " TWIST = $\pm \frac{1}{2}$



SIDE VIEW DETAIL WITH VARIABLE HEIGHT GRATE

| LOADING CONDITION | MAX. EXTENDER HEIGHT - "H" |
|----------------------------------|-------------------------------|
| H2O/H25 * 750 PSI CONCRETE | 19′′ |

* 125 PSI TIRE PRESSURE



SECTION A-A


| STANDARD SIZES | | | | | | |
|----------------|------------------|------|------|------|------|------|
| GAGE | DIAMETER OF PIPE | | | | | |
| PIPE | 12'' | 15′′ | 18′′ | 24′′ | 30′′ | 36′′ |
| 16 | Χ | Χ | Χ | Χ | Χ | Χ |
| 14 | Χ | Χ | Χ | Χ | Χ | Χ |
| 12 | N.A. | N.A. | N.A. | N.A. | Χ | Χ |

| | RATE YPE | ''A'' | | | |
|-----------------|-------------|--------|--|--|--|
| VERT | 21/2′′ | 13/4′′ | | | |
| VERT | 6′′ | 13/4′′ | | | |
| TRAP | 21/2′′ | 21/4′′ | | | |
| TRAP | 6′′ | 3′′ | | | |
| VERT = VERTICAL | | | | | |

TRAP = TRAPIZOIDAL

SLOTTED DRAIN NOTES

- 1. GRATING IS AVAILABLE IN DEPTHS OF 2 1/2 " AND 6".
- 2. VERTICAL GRATING (STRAIGHT SIDES) WITH VERTICAL SPACERS IS ALSO AVAILABLE.
- 3. FOR 6" VERTICAL & TRAPEZOIDAL REQUIREMENTS, THE SLOTTED DRAIN BAND MAY BE FURNISHED WITH THE 4: TECHCO BAND ANGLE.
- 4. DIMENSIONS ARE SUBJECT TO MANUFACTURING TOLERANCES.
- 5. REFERENCE CONTECH BAND MANUAL DWG. NO. 1002697 FOR BAND DETAILS.
- 6. REFERENCE CONTECH SLOTTED DRAIN DWG. NO. 1002697.
- 7. DIMENSIONS FOR H1 AND H2 AS REQUIRED.
- 8. H1 AND H2 MEASURED FROM TOP OF GRATE TO BOTTOM OF GRATE.



TYPICAL PIPE SECTION

3/6" BEARING BAR-

WEB SPACER

FILLET WELD

STEEL MESH (HEEL GUARD)—

3/6" BEARING BAR-

HEL-COR


PIPE

3/6 " SOLID

HEL-COR

 $2^{1/2}$ " GALV.

GRATE SHOWN




OR 6''

3/6" SOLID


WEB SPACER

-FILLET WELD



 $2^{1/4}$ " WIDE CLIP ANGLE


1/2" DIA. BOLT




1/2" DIA. BOLT- $2\frac{1}{2}$ " GALV. GRATE SHOWN **END VIEW**

GAP PLATE (OPTIONAL)

MAY BE PLACED DIRECTLY OVER BAND BOLT TO PROVIDE CONTINUOUS FORM FOR GROUTING



GRATE WELDING DETAIL




DETAIL WITH MESH

(TRAPEZOIDAL GALVANDIZED GRATE SHOWN)


SECTION B-B

SECTION A-A

STANDARD DETAIL



601-2



STATE OF ILLINOIS DEPARTMENT OF TRANSPORTATION

TOTAL SHEET NO. SECTION COUNTY **SLOTTED DRAIN PIPE** CONTRACT NO. SCALE: SHEET NO. OF SHEETS STA. TO STA. FED. ROAD DIST. NO. | ILLINOIS | FED. AID PROJECT