



NOTES:

- 1. ALL DIMENSIONS ARE IN INCHES (MILLIMETERS)
 UNLESS OTHERWISE SHOWN
- 2. ALL CONDUIT ATTACHED TO STRUCTURE SHALL BE GALVANIZED RIGID METALIC CONDUIT, PVC COATED (GRMC, PVC)
- 3. THE USE OF LIQUID TIGHT METAL CONDUIT (TYPE LFMC)
 SHALL BE LIMITED TO LOCATIONS WHERE MOVEMENT IS
 ANTICIPATED AND SHALL NOT EXCEED 5' (1.5 m) IN LENGTH
- 4. ALL WORK INDICATED SHALL BE INCLUDED IN THE PAY ITEM FOR ELECTRIC CONNECTION TO SIGN STRUCTURE
- 5. THE SAFETY SWITCH SHALL BE LOCATED ON THE SIDE OF THE SIGN STRUCTURE WHICH IS CLOSEST TO THE SHOULDER, OR EDGE OF PAVEMENT.

BE-600

COUNTY TOTAL SHEE NC. COOK 300 293

CONTRACT NO. 60G53

FILE NAME =	DESIGNED	-	AJP .	REVISED	=
\prpln_ABC_C3_D1_BE-600A.dgn	DRAWN	~	TMB	REVISED	Mar.
USER NAME = jmajewski	CHECKED	-	JMM	REVISED	-
PLOT DATE = 12/16/2009	DATE	-	10/16/09	REVISED	-
PLOT DATE = 12/16/2009	DATE.	-	10/16/09	REVISED	-

benesch

STATE OF ILLINOIS
DEPARTMENT OF TRANSPORTATION

SCALE:

ELECTRIC	CONNEC	TION	TO	SIGN	STRUCTURE	SPAN	TYPE	F.A.I. RTE.		SECT	IC
								290	(2828B,D,	ETC.	,
N.T.S.	SHEET NO.	1 OF	8 9	SHEETS	STA.	TO	STA.	 cen pr	AD DICT N	0 1	71 1