STATE OF ILLINOIS DEPARTMENT OF TRANSPORTATION





PLAN TOP AND BOTTOM PLATE



STEEL EXTENSION DETAIL





(+) 51/2" SIDE RETAINER

Equivalent rolled angle with stiffeners will be allowed in lieu of welded plates.

typ. SECTION B-B



EXISTING BEARING REMOVAL DETAIL

Notes:

The structural steel plates of the Bearing Assembly shall conform to the requirements of AASHTO M 270 Grade 50.

Anchor bolts shall be ASTM F1554 all-thread (or an Engineer-approved alternate material) of the grade(s) and diameter(s) specified, ASTM A307 Grade C anchor bolts may be used in lieu of ASTM F1554 Grade 36 (Fy=36ksi). The corresponding specified grade of AASHTO M314 anchor bolts may be used in lieu of ASTM F1554.

Drilled and set anchor bolts shall be installed according to Article 521.06 of the Standard Specifications. Side retainers and other steel members required for

the bearing assembly shall be included in the cost of

The bearing assembly shall be included in the cost of Elastomeric Bearing Assembly, Type I. Steel extensions, shim plates and connection bolts are included with Furnishing and Erecting Structural Steel. Prior to ordering any material, the Contractor shall verify in the field all bearing height and shim thickness dimensions. Existing bearings shall be removed and replaced under traffic. traffic.

Diaphragm removal and reinstallation may be required to facilitate drilling holes. Cost included with Furnishing and Erecting Structural Steel.

Minimum jack capacity = 130 Tons. For beam reactions, see sheet 8 of 14.

BILL OF MATERIAL TWO STRUCTURES

<i>Item</i>	Unit	Total	
Furnishing and Erecting Structural Steel	Pound	10,130	
Jack and Remove Existing Bearing	Each	32	
Elastomeric Bearing Assembly Type I	Each	32	
Anchor Bolts, 1'2"	Each	64	

PIERS 1 AND 3 BEARING DETAILS STRUCTURE NO. 060-0012 (E.B.) STRUCTURE NO. 060-0013 (W.B.)

9	F.A.I. RTE.	I. SECTION				COUNTY	/	TOTAL SHEETS	SHEET NO.
	70	60-(5,6,7)RS, 60-(6,7)BR				MADISO	N	185	123
S	CC						СТ	NO. 76	C56
	FED. RC	AD DIST. NO.	ILLINOIS	FED.	AID	PROJECT			