


ED - BWD
ELECTRIC CONNECTION TO UNDERPASS LIGHTING


NOTES
 1. CONDUIT SHALL BE 4-INCH DIAMETER UNLESS OTHERWISE INDICATED IN THE PLANS.
 2. JUNCTION BOX SIZE
 SINGLE FACE WALL: 21" X 11" X 8"
 DOUBLE FACE WALL: 20" X 13" X 12"

NOTE: FOR DETAILS ABOVE BARRIER WALL SEE UNDERPASS DETAILS.




ED - SGN
JUNCTION BOX EMBEDDED IN BARRIER WALL FOR SIGN LIGHTING

NOTES
 1. CONDUIT SHALL BE 4-INCH DIAMETER UNLESS OTHERWISE INDICATED IN THE PLANS.
 2. JUNCTION BOX SIZE
 SINGLE FACE WALL: 21" X 11" X 8"
 DOUBLE FACE WALL: 20" X 13" X 12"



INSTALLATION OF CONDUIT
IN BRIDGE PARAPET EXPANSION JOINT
(N.T.S.)



ED - BW
JUNCTION BOX EMBEDDED IN BARRIER WALL

NOTES
 1. CONDUIT SHALL BE 4-INCH DIAMETER UNLESS OTHERWISE INDICATED IN THE PLANS.
 2. JUNCTION BOX SIZE
 SINGLE FACE WALL: 21" X 11" X 8"
 DOUBLE FACE WALL: 20" X 13" X 12"