


- NOTES:**
- FOR SYMBOL LIST AND GENERAL ELECTRICAL NOTES, SEE SHEET LT-06.
  - LIGHTING UNIT SHALL BE REINSTALLED ON EXISTING LIGHT POLE FOUNDATION.

**TOLLWAY CABLEDUCT SCHEDULE**

- (A) UNIT DUCT, WITH 4-1/C NO. 2 AND 1/C NO. 4 GROUND, 600V (XLP-TYPE USE), 2" DIA. CNC IN UNDERGROUND CONDUIT, PVC, 4" DIA.
- (B) UNIT DUCT, WITH 4-1/C NO. 2 AND 1/C NO. 4 GROUND, 600V (XLP-TYPE USE), 2" DIA. CNC
- (H) UNIT DUCT, WITH 2-1/C NO. 2 AND 1/C NO. 4 GROUND, 600V (XLP-TYPE USE), 2" DIA. CNC



FILE NAME = *FILEL*	USER NAME = *USER*	DESIGNED MCP	REVISED -	<b>STATE OF ILLINOIS DEPARTMENT OF TRANSPORTATION</b>	<b>TOLLWAY LIGHTING PLAN - ILLINOIS ROUTE 59 AT INTERSTATE 88 - RAMPS C &amp; D</b>	F.A.P. RTE.	SECTION	COUNTY	TOTAL SHEETS	SHEET NO.	
		DRAWN MLB	REVISED -			338	(112 & 113) WRS-5	DUPAGE	963	568	
		CHECKED MCP	REVISED -			<b>LT-13</b>		CONTRACT NO. 60I31			
		DATE 10/15/2012	REVISED -			ILLINOIS FED. AID PROJECT					
		PLOT SCALE = *SCALE*		SCALE: AS SHOWN		SHEET NO. 2 OF 6 SHEETS		STA. TO STA.			