


- NOTES:**
1. FOR SYMBOL LIST AND GENERAL ELECTRICAL NOTES, SEE SHEET LT-06.
  2. JUNCTION BOX, STAINLESS STEEL, EMBEDDED IN STRUCTURE, 20" X 12" X 7".

**TOLLWAY CABLEDUCT SCHEDULE**

- (A) UNIT DUCT, WITH 4-1/C NO. 2 AND 1/C NO. 4 GROUND, 600V (XLP-TYPE USE), 2" DIA. CNC IN UNDERGROUND CONDUIT, PVC, 4" DIA
- (B) UNIT DUCT, WITH 4-1/C NO. 2 AND 1/C NO. 4 GROUND, 600V (XLP-TYPE USE), 2" DIA. CNC



FILE NAME = *FILEL*	USER NAME = *USER*	DESIGNED <i>MCP</i>	REVISED -	<b>STATE OF ILLINOIS DEPARTMENT OF TRANSPORTATION</b>	<b>TOLLWAY LIGHTING PLAN - ILLINOIS ROUTE 59 AT INTERSTATE 88 - RAMPS A &amp; B</b>	F.A.P. RTE.	SECTION	COUNTY	TOTAL SHEETS	SHEET NO.
		DRAWN <i>MLB</i>	REVISED -			338	(112 & 113) WRS-5	DUPAGE	963	569
		CHECKED <i>MCP</i>	REVISED -			<b>LT-14</b>		CONTRACT NO. 60I31		
		DATE <i>10/15/2012</i>	REVISED -			ILLINOIS FED. AID PROJECT				
				SCALE: AS SHOWN		SHEET NO. 3 OF 6 SHEETS		STA.		TO STA.