


CAST IRON BEAM CLAMP HOOK BENT TO SIZE BOLT OR TREADED ROD GALVANIZED CONDUIT HANGER ELECTRIC CABLE ASSEMBLY 1/2" (12.7) GALVANIZED "THIMBLEYE" GALVANIZED GUY CLIPS GALVANIZED STEEL MESSENGER WIRE AERIAL CABLE

AERIAL CABLE ATTACHED TO STRUCTURE NOT TO SCALE



NOTES:

- ALL DIMENSIONS IN INCHES (MILLIMETERS) UNLESS OTHERWISE INDICATED.
- 2. SEE PROPOSED LIGHTING PLAN FOR CONDUIT, CABLE AND ROUTING.
- 3. THE CONTRACTOR SHALL PROVIDE INTERMEDIATE SUPPORTS TO MAINTAIN MINIMUM CLEARANCES. REFER TO AERIAL AERIAL CABLE ATTACHED TO STRUCTURE DETAIL.
- 4. COST OF SPLICES AND MOUNTING HARDWARE SHALL BE INCLUDED IN THE UNIT PRICE FOR AERIAL CABLE.

WOOD POLE TO LIGHTING CONTROLLER WIRING CONNECTION DETAIL

N.T.S.

| FILE NAME = | USER NAME = geglienobt | DESIGNED - | REVISED - 08-08-03 |
|----------------------------|----------------------------|------------|--------------------|
| W:\diststd\22x34\be801.dgn | | DRAWN - | REVISED - |
| | PLOT SCALE = 50.000 '/ IN. | CHECKED - | REVISED - |
| | PLOT DATE = 1/4/2008 | DATE - | REVISED - |

| STATE OF ILLINOIS |
|------------------------------|
| DEPARTMENT OF TRANSPORTATION |

| TEMPORARY AERIAL CABLE INSTALLATION | | | | F.A.P. RTE. | SECTION | COUNTY | SHEETS | NO. | |
|-------------------------------------|-------------|-------------------------|------|----------------|---|--------|--------|-----|-----|
| | | | | 305 | (1920,.01,1518,2022&1922.4B)R | COOK | 919 | 538 | |
| | | | | | BE-801 CONTRACT NO. 60T35 | | | | T35 |
| | SCALE: NONE | SHEET NO. 1 OF 1 SHEETS | STA. | TO STA. | FED. ROAD DIST. NO. 1 ILLINOIS FED. AID PROJECT | | | | |