

F.A.P. RTE.	SECTION	COUNTY	TOTAL SHEETS	SHEET NO.
	06-0096-00-SW	DU PAGE	16	14
FEDERAL RD. DIST. NO.	ILLINOIS	FEDERAL AID PROJECT		
CONTRACT: 83951				

**CONSTRUCTION NOTES**

- For Concrete Driveways, Min. 5" P.C.C. Over a Min. 2" Compacted Aggregate Base. For Asphalt Driveways, Min. 2" Bituminous Concrete Over a Min. 8" Compacted Aggregate Base.
- Min. Width 9' Max. 20'
- Curb & Gutter
- Top of Curb
- Flow Line of Gutter
- Depressed Type Curb & Gutter
- 3/4" Expansion Joint Required For Concrete Driveways Only.
- 5' Radius
- P.C.C. Sidewalk, See Notes 2 & 3.
- Min. 2" Aggregate Base

**GENERAL NOTES**

- For Concrete Driveways Wider Than 14', a Contraction Joint Shall be Located Along The Centerline of The Driveway.
- Sidewalk Shall be a Minimum of 5" Thick.
- A Minimum 6-Bag Mix Concrete Shall be Used For Concrete Driveways, Sidewalks, And Curb and Gutter.

**VILLAGE OF WESTMONT**  
**RESIDENTIAL DRIVEWAY**  
**DETAIL**

ISSUED: March 1988  
 REVISED: August 2002  
 August 2003  
 DWG. R-7-2

**CONSTRUCTION NOTES**

- Slope 3/4" / FT.
- 2- #4 Bars Continuous, Optional.
- 2 Dowel Bars of Expansion Joints.
- Min. 2" Aggr. Base
- Min. 6-Bag Mix Concrete
- Depressed Curb Configuration.

**GENERAL NOTES**

- Standard Curb and Gutter Shall be Used For All New Construction. Roll-Type Curb and Gutter is Not Acceptable.
- Preformed Expansion Joints of 3/4" Thickness Shall be Spaced a Maximum of 40' Apart, and at All Radius Points and 4' Either Side of Inlets.
- Formed or Saw-Cut Contraction Joints Shall be Spaced a Maximum of 10' Apart and Filled with a Silicone Sealant.
- Concrete Barrier-Type Curb and Gutter Shall be Provided for All Parking Lots Accommodating Five (5) or More Parking Spaces.

**VILLAGE OF WESTMONT**  
**CURB AND GUTTER**  
**DETAIL**

ISSUED: March 1988  
 REVISED: August 2003  
 DWG. R-8-1

**CONSTRUCTION NOTES**

- Approved Subgrade
- Geotextile Fabric for Soil Stabilization See Note 4.
- Aggr. Base Course, Type B, CA-6
- 0.3 Gal./5Y Bit Materials (Prime Coat)
- Bit Aggregate Mixture (BAM), MS = 1500
- Bit Conc. Binder Course
- Bit Conc. Surface Course, Class I
- P.C.C., Min. 6-Bag Mix
- Bit Conc. Surface Course

**GENERAL NOTES**

- These Are Minimum Standards Only. Structural Design of Streets Shall be Determined Using State Highway Standards, (With These Minimums) Except Where Approved by Village Engineer.
- 2% Crown to be Installed on All Streets.
- 2% Inverted Crown to be Installed in Alleys.
- Geotechnic Fabric Over Subgrade shall be Minimum 4 oz. per Square Yard. Woven or Non-Woven Engineering Fabric, Meeting State Standards.

**VILLAGE OF WESTMONT**  
**MINIMUM PAVEMENT**  
**CROSS - SECTIONS**

ISSUED: March 1988  
 REVISED:  
 DWG. R-1-0

**Burns & McDonnell**  
 SINCE 1938

date 02-22-06 detailed J. HOLZINGER  
 designed M. KUNTZ checked A. BRYANT

**WESTMONT**  
 ILLINOIS

VILLAGE OF WESTMONT  
 2006 CMAQ SIDEWALK  
 MISCELLANEOUS DETAILS (2 OF 2)  
 project 39606 contract  
 drawing rev.  
 sheet 14 of 16 sheets  
 file I:\WESTMONT\39606-2006 SW DESIGN\CAD\BIDDDETAILS\_2

Scale For Marking  
 Millimeters  
 Inches  
 COPYRIGHT © 2005 BURNS AND McDONNELL ENGINEERING COMPANY, INC.