







305 (12) PIPE REINFORCING SCHEDULE					
Mark Req'd	Size	Length	No.		
a	15 (5)	2750 (110)	2		
b	15 (5)	800 (32)	2		
с	25 (8)	850 (34)	10		

381 (15) PIPE REINFORCING SCHEDULE					
Mark Req'd			No.		
a	15 (5)	3400 (136)	2		
b	15 (5)	875 (35)	2		
c	25 (8)	925 (37)	14		

457 (18) PIPE REINFORCING SCHEDULE				
Mark Req'd	Size	Length	No.	
a	15 (5)	4050 (162)	2	
b	15 (5)	950 (38)	2	
С	25 (8)	1000 (40)	18	

GENERAL NOTES:

Details shown hereon are for the construction of beveled pipe and guard. Alternate designs, methods of construction or materials may be submitted to the Engineer for approval. All methods of construction and materials involved shall conform to current Standard Specifications.

Reinforcing steel used in construction of "Beveled Pipe and Guard" shall be deformed bars meeting the requirements of Article 1006.10 of the Standard Specifications. All steel bars shall be hot-dip galvanized in accordance with ASTM A 123 specifications.

Concrete used in construction of the beveled pipe and guard shall be Class "SI" Concrete.

collar is poured.

Engineer.

SPECIAL NOTE:

A silt basin will be required immediately upstream from the inlet of culvert. Refer to State Standard 280001 for construction details.

C + _ 50 (2) Clear	TABLE OF DIMENSIONS				
20°± 20°± 20°± 20°± 20°± 20°± 20°± 20°±	PIPE SIZE	A	В	с	D
	305 (12)	2.9m (9'-6'')	900 (36)	1.83m (6')	3m (10')
—————————————————————————————————————	381 (15)	3.6m (11'-8'')	975 (39)	2.5m (8'-2'')	3.6m (12')
SECTION B-B	457 (18)	4. 2m (13'-10'')	1050 (42)	3.15m(10'-4'')	4.5m (14'-10'')

-TIME ATEF AREF S-OGN-S AREF

F. A. RTEL	SECTION		COUNTY	TOTAL. Sheets	SHEET ND
301			STEPHENSON	290	127
STA.		TO :	STA.		
FED. ROAD DIST. NO. 2 ILLINGES FED. AND PROJECT					

The corrugated metal pipe shall be cut to fit the 1:8 foreslope. Slots shall be cut into the C.M.P. for placement of the No. 25 (8) bars. After the foreslope has been placed, the No. 25(8) bars shall be fitted into the slots cut in the C.M.P. so they will be in proper position when the concrete

This work shall be paid for at the contract unit price per Each for "Beveled Pipe and Guard", as shown hereon and as directed by the

ALL DIMENSIONS ARE IN MILLIMETERS (INCHES) UNLESS OTHERWISE NOTED.

(VARIES 51.5'-54') MEDIAN CROSSOVER

BEVELED PIPE & GUARD DETAIL SHEET 2 of 2