



TALLMADGE LIGHTING STANDARD AND LUMINARE DETAIL (INSTALL ONLY)





TALLMADGE POLE
CONCRETE FOUNDATION DETAIL




-2-1/C NO. 10 AWG, 600V TYPE XHHW, COLOR CODED CABLES IN POLE SHAFT

-SPLICED CABLES

NO. 8 AWG BARE COPPER GROUND WIRE


-2-1/C NO. 6 AWG, 600V
TYPE XHHW, COLOR CODED
CABLES IN POLE SHAFT
(UNLESS OTHERWISE NOTED)



2-POLE FUSE HOLDER QUICK DISCONNECT WITH TIME LAG-FUSE, 10 AMP


SPLICE GROUND WIRE AND PIGTALE TO POLE GROUND LUG

POLE SHAFT



POLE BASE WIRING DETAIL

## SPLICING ELECTRIC CABLE BASIC MATERIALS AND METHODS



TRENCH CROSS SECTION

l.	REVISIONS		ILLINOIS DEPARTMENT OF TRANSPORTATION	
L	NAME	DATE		
			ROADWAY LIGHTING DETAILS	
- 1			I TO AD WAT	LIGHTING BETAILS
			McCORMICK BOULEVARD	
į.				
				DATE 9/03/04
L				DRAWN BY GEW
			SCALE: NONE	CHECKED BY SRF