
| F.A. | SECTION | COUNTY | TOTAL SHEET | NO. | OFF | O1-00236-00-BR | COOK | 18 | 16 | TO STA.____ FED. ROAD DIST. NO. _ ILLINOIS FED. AID PROJECT

CONTRACT 83817



CABINET/LOCATION	VOLTAGE.	BRANCH BREAKER		CONTROLED BY
C1	120/240V, 1PH, 3W	(2) 30A/2P (1) 20A/1P (1) 20A/1P	LIGHTING (E&W) 240V OUTLETS 120V FLASHING BEACON	TORK 1100 SERIES ON ALWAYS ON ALWAYS
		(1) 30A/2P	LIGHTING BRIDGE 240V	TORK 1100 SERIES

2 CONTROLLER WIRING DIAGRAM

ELECTROMECHANICAL 24 HOUR DIAL TIME SWITCH, TORK 1100 SERIES

CIRCUIT BREAKERS, 600 VOLT, NON-INTERCHANCABLE TRIP, SEE EXACT SIZES AND QUANTITIS ON SCHEDULE

100 AMP REMOTE CONTROL SWITCH, ELECTRICALLY OPERATED, MECHANICALLY HELD, 2-POLE, SINGLE THROW, 600V CONTROL CIRCUIT, 800V ASCO 920 OR EQUAL

REVISIONS		THINDIS DEPARTMEN	NT OF TRANSPORTATION	
NAME	DATE	TEETHOTS DEPARTMEN	TOP TRANSPORTATION	
		HOME AVE PEDESTRA	AIN BRIDGE IMPROVEMENT	
		HOME AVE AND	HARRISON STREET	
		PROPOSED LIGHTING PLAN		
		SCALE: VERT. HORIZ.	DRAWN BY FG	

= *DATE* = *FILEL* = *SCALE* = *REF*

DATE NAME SCALE RENCE PLOT FILE 1 PLOT