









Notes:

1. TB - #8 Terminal Blocks

2. NO - Normally Open

3 NC - Normally Closed

- NO/NC contacts shall all toggle simultaneously with one single manually ceprated switch.
- Manual Bypass Switch shall only switch line. Neutral and Equipment Ground are not switched and shall be connected to NEMA Cabinet Buses.

## MANUAL BYPASS SWITCH (TYPICAL)



an 1997 - 1867 - 1

191035-1084

UPS BLOCK DIAGRAM

AC+ (Line)

On Batt			Low Batt			Timer			BBS Fail		
0	0	0	0	0	0	0	0	0	0	0	0
NO	С	NC	NO	С	NC	NO	С	NC	NO	С	NC

Notes: 1. NO/NC contacts may either share or use seperate commons.

## Relay contacts (NO/NC) available on panel-mounted terminal block (typical)

## BLANK, WESSELINK, COOK & ASSOCIATES ENGINEERS - CONSULTANTS DECATUR, ILLINOIS

F.A.P. 774 (IL 32/33) SEC 107WRS-1, 107BY, 107BY-1 & 107B-2

w <sup>1</sup>.

