ROADWAY LIGHTING SCHEDULE OF QUANTITIES		
ITEM	UNIT	TOTAL QUANTITY
ELECTRIC SERVICE INSTALLATION	EACH	1
ELECTRIC UTILITY SERVICE CONNECTION	LUMP SUM	1
CONDUIT IN TRENCH, 4" DIA., GALVANIZED STEEL	FOOT	42
CONDUIT PUSHED, 4" DIA., GALVANIZED STEEL	FOOT	906
UNIT DUCT, 600V, 3-1C NO. 4, 1/C NO. 6 GROUND, (XLP-TYPE USE), 1 1/4" DIA. POLYETHYLENE	FOOT	4800
ELECTRIC CABLE IN CONDUIT, 600V (EPR-TYPE USE) 3-1/C 300 MCM	FOOT	66
AERIAL CABLE, 3-1/C NO. 4 WITH MESSENGER WIRE	FOOT	6260
TRENCH AND BACKFILL FOR ELECTRICAL WORK	FOOT	3900
LUMINAIRE, SODIUM VAPOR, HORIZONTAL MOUNT, 400 WATT	EACH	52
LIGHTING CONTROLLER, DUPLEX CONSOLE TYPE	EACH	1
LIGHT POLE, ALUMINUM, 47.5 M.H., 15 FT. DAVIT ARM	EACH	20
LIGHT POLE, WOOD, 60 FOOT, CLASS 4, WITH 15FT MAST ARM	EACH	16
LIGHT POLE, WOOD, 60 FOOT, CLASS 4, WITH TWO 15FT MAST ARMS	EACH	3
LIGHT POLE FOUNDATION, 24" DIAMETER	FOOT	190
BREAKAWAY DEVICE, TRANSFORMER BASE, 15 INCH BOLT CIRCLE	EACH	20
REMOVAL OF TEMPORARY LIGHTING UNIT	EACH	19
REMOVAL OF POLE FOUNDATION, CONCRETE	EACH	12
REMOVAL OF EXISTING LIGHTING UNIT, SALVAGE	EACH	12
REMOVAL OF LIGHTING CONTROLLER	EACH	1
REMOVAL OF LIGHTING CONTROLLER FOUNDATION	EACH	1
REMOVE ELECTRIC CABLE FROM CONDUIT	FOOT	17000
MAINTENANCE OF LIGHTING SYSTEM	CAL MO	16
LUMINAIRE SAFETY CABLE ASSEMBLY	EACH	28
GROUND ROD, 5/8" DIA X 10 FT.	EACH	39

^{*:}THE EXISTING LIGHTING CONTROLLER SHALL REMAIN THE PROPERTY OF THE DEPARTMENT AND SHALL BE DELIVERED BY THE CONTRACTOR TO THE DEPARTMENT'S ELECTRICAL MAINTENANCE CONTRACTOR'S MAIN FACILITY.