




## DEMOLITION LEGEND

- R EXISTING TO BE REMOVED AND SALVAGED TO IDOT
- T WOOD POLE WITH LUMINAIRE FOR TEMPORARY LIGHTING

## TEMPORARY LIGHTING NOTES:

- 1. ALL AERIAL CABLES ARE (3) 1/C #4 ALUMINUM WITH MESSENGER WIRE.
- CONTRACTOR SHALL COORDINATE AND STAGE TEMPORARY, DEMOLITION AND PROPOSED LIGHTING INSTALLATION AND ENERGIZATION SO THAT NO SECTIONS OF ROADWAY THAT ARE CURRENTLY ILLUMINATED WILL BE WITHOUT LIGHT FOR ANY NIGHTTIME PERIOD.
- MAINTAIN CLEARANCE FROM GROUND PER NEC SECTION 225.18 FOR ALL AERIAL CABLES.
  MAINTAIN CLEARANCE FROM COMED OVERHEAD ELECTRIC LINES AS REQUIRED BY COMED.
- 4. ALL TEMPORARY LIGHT UNITS SHALL HAVE 60' CLASS 4 WOOD POLES AND 15' MAST ARMS WITH A LUMINAIRE MOUNTING HEIGHT OF 47'-6". LUMINAIRES SHALL BE 400W, 240V, MCIII.
- 5. WORK ON THIS SHEET SHALL BE COORDINATED WITH THE MAINTENANCE OF TRAFFIC PLANS.
- 6. TEMPORARY LIGHTING CIRCUITS TO BE CONNECTED TO EXISTING CONTROLLER.
- REMOVE CONDUCTORS FROM ALL EXISTING UNIT DUCTS. EMPTY UNIT DUCTS ARE TO BE ABANDONED IN PLACE.



			GRAPH	HIC SCAL	.E		
			M	ETERS			
20	0	20		40	60	80	100
						33.555	
			0328				
50	Ó	50	100	150	200	250	
			FEET				

LT-0

FILE NAME = LT-04.dgn PLOT DATE = 0/13/2010 PLOT DA