











LIGHTING FIXTURE SCHEDULE

TYPE	SYMBOL	DESCRIPTION	MANUFACTURER & CATALOG NUMBER	NUMBER OF LAMPS	LAMP TYPE & WATTAGE	VOLTAGE	MOUNTING	MOUNTING HEIGHT	NOTES
A		18 GAUGE # 304 STAINLESS STEEL, ONE PIECE CONSTRUCTION WITH CORNER SEAM WELDED AND GROUND SMOOTH, NO.4 FINISH, 1' BY 4' HOUSING	KENALL: CTA-99-308-FUSE LED (50L50K) TYPE B-LED OR APPROVED EQUAL	(4) 12-LED BOARDS, 5000K 80-CRI	F72T8TL 841HO 65W	120 V	SURFACE	SEE ARCH. DWGS	1
B		18 GAUGE # 304 STAINLESS STEEL, ONE PIECE CONSTRUCTION WITH CORNER SEAM WELDED AND GROUND SMOOTH, NO.4 FINISH, 1' BY 6' HOUSING	EXISTING	2	F72T8TL 841HO 65W	120 V	SURFACE	SEE ARCH. DWGS	3
C		18 GAUGE TYPE 304, NO.4 FINISH DIE FORMED, SEAM WELDED AND GROUND SMOOTH, 1' BY 6' HOUSING	EXISTING	2	F72T8TL 841HO 65W	120 V	SURFACE CORNER MT.	SEE ARCH. DWGS	3
D		18 GAUGE # 304 STAINLESS STEEL, 1' BY 4' HOUSING	KENALL: CTA-99-308-FUSE LED (50L50K) TYPE B-LED OR APPROVED EQUAL	(4) 12-LED BOARDS, 5000K 80-CRI	LED 70W	120 V	RECESSED	SEE ARCH. DWGS	1
H		GREY FINISH, VAPOR TIGHT.	LITHONIA: OLVTWM OR APPROVED EQUAL	LED ARRAY	LED 70W	120 V	WALL	SEE ARCH. DWGS	1
N		INDUSTRIAL STRIP LIGHT FIXTURE WITH WIRE GUARD	LITHONIA: EJSA-2-32-120-GEB10IS-WGL OR APPROVED EQUAL	(4) 12-LED BOARDS, 5000K 80-CRI	LED 70W	120 V	SURFACE/PENDANT	SEE ARCH. DWGS	1,2

NOTES:


1. SEE SPECIFICATIONS FOR ADDITIONAL REQUIREMENTS.
2. INPUT WATTAGE OF FIXTURE IS 59W, FURNISH -20°F BALLAST WITH FIXTURE.
3. REPLACE WITH COLD WEATHER -20°F BALLAST AND RELAMP FIXTURE. REPLACE ALL BROKEN AND CRACKED LENSE. REGASKET FIXTURE WHERE GASKET IS DAMAGED

EMERGENCY/EXIT SYMBOL LIST

TYPE	SYMBOL	DESCRIPTION	MANUFACTURER & CATALOG NUMBER	NUMBER OF LAMPS	LAMP TYPE & WATTAGE	VOLTAGE	MOUNTING	MOUNTING HEIGHT	NOTES
A		EXIT SIGN, ELECTRIC, 120 VOLT, LED LIGHT SOURCE, GLASS PANEL, CHICAGO CODE APPROVED, EMERGENCY BACK-UP POWER	BIG BEAM: ECXLN1RWW-SS-TP-HTR120-TM OR APPROVED EQUAL	LED ARRAY	LED 3.7W	120	CEILING/WALL/PENDANT	SEE ARCH. DWGS	1
B		EXIT SIGN, ELECTRIC, 120 VOLT, LED LIGHT SOURCE, RIGHT ARROW, GLASS PANEL, CHICAGO CODE APPROVED, EMERGENCY BACK-UP POWER	BIG BEAM: ECXLN1RWW-SS-TP-HTR120-TM-AR OR APPROVED EQUAL	LED ARRAY	LED 3.7W	120	CEILING/WALL/PENDANT	SEE ARCH. DWGS	1
C		EXIT SIGN, ELECTRIC, 120 VOLT, LED LIGHT SOURCE, LEFT ARROW, GLASS PANEL, CHICAGO CODE APPROVED, EMERGENCY BACK-UP POWER	BIG BEAM: ECXLN1RWW-SS-TP-HTR120-TM-AL OR APPROVED EQUAL	LED ARRAY	LED 3.7W	120	CEILING/WALL/PENDANT	SEE ARCH. DWGS	1
D		EXIT SIGN, ELECTRIC, 120 VOLT, LED LIGHT SOURCE, DOUBLE-FACE ARROW, GLASS PANEL. CHICAGO CODE APPROVED, EMERGENCY BACK-UP POWER	BIG BEAM: ECXLN2RWW-SS-TP-HTR12?-TM-ARAL/ARAR OR APPROVED EQUAL	LED ARRAY	LED 3.7W	120	CEILING/WALL/PENDANT	SEE ARCH. DWGS	1

A



USER NAME = hab1b	DESIGNED -	REVISED  12/18/2013
	CHECKED -	REVISED
PLOT SCALE = 2:0 " = 1"	DRAWN -	REVISED
PLOT DATE = 12/17/2013	CHECKED -	REVISED

**STATE OF ILLINOIS
DEPARTMENT OF TRANSPORTATION**

**PEORIA STREET STATION
ELECTRICAL LIGHTING FIXTURE SCHEDULES**

MUN	SECTION	COUNTY	TOTAL SHEETS	SHEET NO.
2090	2013-011R	COOK	356	278
CONTRACT NO.			60W29	

SHEET NO. E-202 OF 117 SHEETS

ILLINOIS FED. AID PROJECT

3:43:48 PM
278-60W29.dgn