




**LEGEND**

	EXISTING LIGHT POLE, WEATHERING STEEL, 45 FT. M.H., TENON MOUNT WITH LUMINAIRE, SODIUM VAPOR, MULTI-MOUNT, 250 WATT
	RELOCATE LIGHT POLE, WEATHERING STEEL, 45 FT. M.H., TENON MOUNT WITH LUMINAIRE, SODIUM VAPOR, MULTI-MOUNT, 250 WATT
	PROPOSED LIGHT POLE, WEATHERING STEEL, 45 FT. M.H., TENON MOUNT WITH LUMINAIRE, SODIUM VAPOR, MULTI-MOUNT, 250 WATT
	ELECTRIC SERVICE INSTALLATION 120/240 V, 1 PHASE 3 WIRE
	PROPOSED LIGHTING CONTROLLER, POLE MOUNTED, 240V, 30 AMP
	EXISTING UNIT DUCT, 600V, 2-1C NO. 6, 1/C NO. 6 GROUND, (XLP-TYPE USE), 3/4" DIA. POLYETHYLENE
	PROPOSED UNIT DUCT, 600V, 2-1C NO. 6, 1/C NO. 6 GROUND, (XLP-TYPE USE), 3/4" DIA. POLYETHYLENE
	UNDERGROUND CONDUIT, COILABLE NONMETALLIC CONDUIT, 2" DIA., SCHEDULE 80



FILE NAME *	USER NAME * aparkage	DESIGNED -	REVISED -	<b>STATE OF ILLINOIS DEPARTMENT OF TRANSPORTATION</b>	<b>BUSINESS LOOP 55 PROPOSED LIGHTING PLAN</b>	F.A.P. RTE.	SECTION	COUNTY	TOTAL SHEETS	SHEET NO.	
en\ppl\work\aparkage\aparkage\0306010\0677	F58-Sh-Lgt-Pln.dgn	DRAWN -	REVISED -			666	(26)R5.1	SANGAMON	116	51	
Default	PLOT SCALE = 48,0000 / in.	CHECKED -	REVISED -			SCALE: SHEET OF SHEETS STA. TO STA.					
	PLOT DATE = Dec-09-2013 09:57:20AM	DATE -	REVISED -			ILLINOIS FED. AID PROJECT CONTRACT NO. 72F50					