

10. TOP RAIL COUPLINGS SHALL BE WROUGHT STEEL GALVANIZED OUTSIDE SLEEVE TYPE. 7"

11. ALL FITTINGS TO BE EQUIPPED WITH NUTS AND BOLTS AS REQUIRED FOR ERECTION, (ALL GALV.) CLAMPS AND CAPS TO BE MALLEABLE IRON, GALVANIZED. BANDS TO BE WROUGHT

AND NUTS TO BE %" GALV. STEEL OF PROPER LENGTH.

LONG SPACED $\ @$ 20'-0" ON CENTER, ONE COUPLING IN EVERY FIVE TO BE OF A TYPE TO TAKE UP EXPANSION AND CONTRACTION OF TOP RAIL.

STEEL GALVANIZED. LOCKING DEVICE TO BE ADAPTABLE FOR PADLOCKING. CARRIAGE BOLTS

ENTIRE FENCE POST FOOTING INCLUDING-

ELEVATION AND DETAILS OF 12'-0" FENCE NOT TO SCALE

SLOPED TOP PORTION SHALL BE POURED

CHICAGO PARK DISTRICT 541 North Fairbanks Court

Chicago, Illinois 60611

REVISIONS DATE

APPROVED

ROJ. MGR.: ESIGNER: RAWN: JК CHECKED: CW NONE SCALE: 08/2008 DATE:

> SPEC. NO.: JOB NO.:

SHEET INFORMATION

LINK FENCING DETAILS

PARK NO./PROJECT NO. ST-686

LEAST SIX INCHES BELOW THE GROUND ROD. ALL CONNECTIONS BETWEEN GATE AND FENCE AND GROUND ROD SHALL BE NO. 8 BARE STRANDED SOFT DRAWN CABLE.

20. GROUND RODS SHALL BE INSTALLED WHERE SHOWN OR REQUIRED AND SHALL BE MADE OF COPPER OR COPPER-CLAD STEEL, NOT LESS THAN 34" DIAMETER AND LENGTH OR

GROUND RODS TO BE INSTALLED VERTICALLY.

NUMBER OF RODS SHALL HAVE A RESISTANCE TO GROUND NOT TO EXCEED 25 OHMS.

EN1-R

DRAWING NO.