







STD. 701D

CURB AND GUTTER GENERAL NOTES

- 1. Thickness: "T" = thickness of the curb or gutter
- Depressed curbs: The top of a curb shall be depressed where it is constructed across a sidewalk, driveway, or where directed by the Director of Community Development. The transition from full height curb to depressed curb shall be at the rate of 3" per foot.
- Sub-grade: Improved sub-grade shall extend 1' outside of the back of curb.
- Sub-base: The sub-base shall consist of 4" of compacted crushed limestone.
- 5. Concrete: Shall be a 6 bag mix, attaining a strength of not less than 3500 P.S.I. in 28 days.
- Contraction joints: Maximum of 25' intervals, grooved or sawcut a minimum of 1/8" wide, and a minimum of 2" deep. Sawing shall be completed within 24 hours of the pour.
- 7. Expansion joints: 1" thick preformed joint filler with a single 5/4"x 18" epoxy coated smooth dowel bar, fitted with a pinch cap, installed 5' on either side of any structure within the curb line, at the PT and PC of a radius, and at the end of each concrete pour. Maximum spacing of 75'.
- Construction joints: Use whenever the placing of concrete is held up for 30 minutes or more. Construction joints shall be installed in the same manner as an expansion joint.

REVISIONS		VILLAGE OF ADDISON	
		APPROVED: 2/2/94	
		- What is a second of the seco	
		R. ESPEDIDO, P.E., VILLAGE ENGINEER	

*3884 ARMY TRAIL BLVD. *2625 MILL ROAD



ESIGNED - JJS	REVISED - VILLAGE REVIEW 9-08-09
RAWN - UKB	REVISED - VILLAGE REVIEW 11-05-09
HECKED - SMV	REVISED - IDOT REVIEW 11-17-09
ATE - 8-19-09	REVISED -