

DUCT BANK NOTES:

- 1. DIMENSIONS FOR CONCRETE COVERAGE AND SEPARATION BETWEEN DUCTS ARE MINIMUM.
- INCLUDE DUCT SPACERS AS MANUFACTURED BY UNDERGROUND DEVICES INC., TO MAINTAIN PROPER SEPARATION OF CONDUITS.
- 3. REBAR IS REQUIRED TO ACCOMMODATE FUTURE DUCT EXTENSIONS & INTERFACE AT DUCT BANK TERMINATIONS. CONCRETE ENCASED DUCT BANKS TERMINATING IN HANDHOLES REQUIRE REBAR AT TERMINATIONS.
- 4. CONDUITS FOR CONCRETE ENCASED DUCT SHALL BE SCHEDULE 40 PVC CONFORMING TO ITEM 110.
- 5. MINIMUM DEPTH OF TOP OF DUCT ENCASEMENT SHALL BE 18" BELOW FINISHED GRADE.
- 6. HIGH VOLTAGE AND LOW VOLTAGE CIRCUITS SHALL NOT BE INSTALLED IN THE SAME RACEWAY, CONDUIT, DUCT, HANDHOLE, OR MANHOLE,
- 7. HOMERUN CABLES FOR A RESPECTIVE CIRCUIT SHALL BE INSTALLED IN THE SAME RACEWAY OR DUCT.

TOP VIEW

DUCT

0.75"

 $+-0.2^*$

0.15"-

SECURED WITH FPOXY GLUE

PHONE: (618)-282-4114.

TURF

DUCT MARKER DETAIL

"NOT TO SCALE"

BITUMINOUS PAVEMENT DUCT MARKERS "NOT TO SCALE"

> TOP OF MARKER SHALL BE FLUSH WITH FINISHED PAVEMENT SURFACE. MARKER MAY BE INSTALLED IN A DRILLED HOLE AND

BRASS DUCT MARKERS ARE AVAILABLE FROM

G&S FOUNDRY & MANUFACTURING CO. INC.,

210 KASKASKIA DRIVE, RED BUD, IL. 62278

PROPOSED PAVEMENT

-2-WAY OR

4-WAY DUCT

CONCRETE PAVEMENT MARKER SEE NOTE 2

PRESTAMPED OR-

NOTES:

IMPRESSED LETTERS

INDICATING NUMBER AND SIZE OF DUCTS

CONCRETE DUCT

MARKER-

18" R.

3/16" R.

CHISELED ON THE JOB


(%" HIGH LETTERING MIN.)

8. DUCT INTERFACE TO HANDHOLES OR MANHOLES WILL BE CONSIDERED INCIDENTAL TO THE RESPECTIVE DUCT PAY

MA025 CABLE & DUCT MARKER NOTES:


- THE COST OF ALL TURF AND PAVEMENT DUCT MARKERS SHALL BE INCIDENTAL TO THE DUCT. THE COST OF ALL CABLE MARKERS SHALL BE INCIDENTAL TO THE CABLE.
- 2. BITUMINOUS PAVEMENT DUCT MARKER AND CONCRETE DUCT MARKER TO BE PROVIDED AT EACH END OF EACH DUCT AS SHOWN ON THE LOCATION PLAN. FOR CONCRETE PAVEMENT, THE LETTER "D" SHALL BE IMPRESSED IN THE PAVEMENT INSTEAD OF THE MARKER.

 THE LETTER SHALL BE FORMED AS DESCRIBED IN NOTE 4.
- 3. CABLE MARKERS SHALL BE PLACED AT CHANGES OF DIRECTION AND APPROXIMATELY EVERY 200' ALONG CABLE
- 4. CONCRETE CABLE MARKERS AND DUCT MARKERS SHALL HAVE LETTERS 4" HIGH, 3" WIDE WITH WIDTH OF STROKE ½" AND ¼" DEEP. ALL LETTERS, NUMBERS AND ARROWS




UNDERGROUND ELECTRICAL DUCT

(NOT TO SCALE)



TURF CABLE MARKERS "NOT TO SCALE"



TURF DUCT MARKERS "NOT TO SCALE"

'E, LIGHT AND MARK 805' EXTENSION

TRICAL DETAILS SHEET 4

ELECT

HANSON

COUNTY AIRPORT ON, ILLINOIS