

01A

Letting March 8, 2024

Notice to Bidders, Specifications and Proposal



**Illinois Department
of Transportation**

Springfield, Illinois 62764

**Contract No. ED021
Edgar County Airport
Paris, Illinois
Edgar County
Illinois Project No. PRG-4981
SBG Project No. N/A**



NOTICE TO BIDDERS

- 1. TIME AND PLACE OF OPENING BIDS.** Electronic bids are to be submitted to the electronic bidding system (iCX-Integrated Contractors Exchange). All bids must be submitted to the iCX system prior to 12:00 p.m. on March 8, 2024, at which time the bids will be publicly opened from the iCX SecureVault.
- 2. DESCRIPTION OF WORK.** The proposed improvement is identified and advertised for bids in the Invitation for Bids as:

**Contract No. ED021
Edgar County Airport
Paris, Illinois
Edgar County
Illinois Project No. PRG-4981
SBG Project No. N/A**

Replace Runway 9/27 Pulse Light Approach Slope Indicator (PLASI) with a Precision Approach Path Indicator (PAPI)

For engineering information, please contact Barry S. Stolz, P.E. of Hanson Professional Services, Inc. at 314.942.5288.

3. INSTRUCTIONS TO BIDDERS.

- (a) This Notice, the invitation for bids, proposal and letter of award shall, together with all other documents in accordance with Article 10-18 of the Illinois Standard Specifications for Construction of Airports (Adopted April 1, 2012), become part of the contract. Bidders are cautioned to read and examine carefully all documents, to make all required inspections, and to inquire or seek explanation of the same prior to submission of a bid.
- (b) State law, and, if the work is to be paid wholly or in part with Federal-aid funds, Federal law requires the bidder to make various certifications as a part of the proposal and contract. By execution and submission of the proposal, the bidder makes the certification contained therein. A false or fraudulent certification shall, in addition to all other remedies provided by law, be a breach of contract and may result in termination of the contract.

- 4. AWARD CRITERIA AND REJECTION OF BIDS.** This contract will be awarded within 90 calendar days to the lowest responsive and responsible bidder considering conformity with the terms and conditions established by the Department in the rules, Invitation for Bids and contract documents. The issuance of plans and proposal forms for bidding based upon a prequalification rating shall not be the sole determinant of responsibility. The Department reserves the right to determine responsibility at the time of award, to reject any or all proposals, to readvertise the proposed improvement, and to waive technicalities.

- 5. PRE-BID CONFERENCE.** N/A

- 6. DISADVANTAGED BUSINESS POLICY.** The DBE goal for this contract is 0.0%.

- 7. SPECIFICATIONS AND DRAWINGS.** The work shall be done in accordance with the Illinois Standard Specifications for Construction of Airports (Adopted April 1, 2012), the Special Provisions dated January 12, 2024, and the Construction Plans dated January 12, 2024 as approved by the Illinois Department of Transportation, Division of Aeronautics.

- 8. BIDDING REQUIREMENTS AND BASIS OF AWARD.** When alternates are included in the proposal, the following shall apply:
- a. Additive Alternates
 - (1) Bidders must submit a bid for the Base Bid and for all Additive Alternates.
 - (2) Award of this contract will be made to the lowest responsible qualified bidder computed as follows:

The lowest aggregate amount of (i) the Base Bid plus (ii) any Additive Alternate(s) which the Department elects to award.

The Department may elect not to award any Additive Alternates. In that case, award will be to the lowest responsible qualified bidder of the Base Bid.
 - b. Optional Alternates
 - (1) Bidders must submit a bid for the Base Bid and for either Alternate A or Alternate B or for both Alternate A and Alternate B.
 - (2) Award of this contract will be made to the lowest responsible qualified bidder computed as follows:

The lower of the aggregate of either (i) the Base Bid plus Alternate A or (ii) the Base Bid plus Alternate B.
- 9. CONTRACT TIME.** The Contractor shall complete all work within the specified contract time. Any calendar day extension beyond the specified contract time must be fully justified, requested by the Contractor in writing, and approved by the Engineer, or be subject to liquidated damages.
- The contract time for this contract is Base Bid: 29 calendar days; Additive Alternate #1: 0 additional calendar days; Additive Alternate #2: 0 additional calendar days; Additive Alternate #3: 0 additional calendar days.
- 10. INDEPENDENT WEIGHT CHECKS.** The Department reserves the right to conduct random unannounced independent weight checks on any delivery for bituminous, aggregate or other pay item for which the method of measurement for payment is based on weight. The weight checks will be accomplished by selecting, at random, a loaded truck and obtaining a loaded and empty weight on an independent scale. In addition, the department may perform random weight checks by obtaining loaded and empty truck weights on portable scales operated by department personnel.
- 11. MATERIAL COST ADJUSTMENTS.** The Illinois Department of Transportation, Division of Aeronautics does not offer any material cost adjustment provisions.
- 12. GOOD FAITH COMPLIANCE.** The Illinois Department of Transportation has made a good faith effort to include all statements, requirements, and other language required by federal and state law and by various offices within federal and state governments whether that language is required by law or not. If anything of this nature has been left out or if additional language etc. is later required, the bidder/contractor shall cooperate fully with the Department to modify the contract or bid documents to correct the deficiency. If the change results in increased operational costs, the Department shall reimburse the contractor for such costs as it may find to be reasonable.

By Order of the
Illinois Department of Transportation

Omer Osman,
Secretary

State of Illinois
Department of Transportation

SPECIAL PROVISION
FOR
EEO

Effective: July 21, 1978
Revised: November 18, 1980

The requirements of the following provisions written for federally-assisted construction contracts, including all goals and timetables and affirmative action steps, shall also apply to all State-funded construction contracts awarded by the Illinois Department of Transportation.

Notice of Requirement for Affirmative Action to Ensure
Equal Employment Opportunity (Executive Order 11246)

1. The offeror's or bidder's attention is called to the "Equal Opportunity Clause" and the "Standard Federal Equal Employment Opportunity Construction Contract Specifications" set forth herein.
2. The goals and timetables for minority and female participation, expressed in percentage terms for the Contractor's aggregate workforce in each trade on all construction work in the covered area, are as follows:

APPENDIX A

The following goal for female utilization in each construction craft and trade shall apply to all Contractors holding Federal and federally assisted construction contracts and subcontracts in excess of \$10,000. The goal is applicable to the Contractor's total on-site construction workforce, regardless of whether or not part of that workforce is performing work on a federal, federally assisted or nonfederally related construction contract or subcontract.

Area Covered (Statewide)

Goals for Women apply nationwide.

GOAL	Goal (percent)
Female Utilization	6.9

APPENDIX B

Until further notice, the following goals for minority utilization in each construction craft and trade shall apply to all Contractors holding federal and federally-assisted construction contracts and subcontracts in excess of \$10,000 to be performed in the respective geographical areas. The goals are applicable to the Contractor's total on-site construction workforce, regardless of whether or not part of that workforce is performing work on a federal, federally-assisted or nonfederally related construction contract or subcontract.

<u>Economic Area</u>	Goal (percent)
056 Paducah, KY: Non-SMSA Counties - IL - Hardin, Massac, Pope KY - Ballard, Caldwell, Calloway, Carlisle, Crittenden, Fulton, Graves, Hickman, Livingston, Lyon, McCracken, Marshall	5.2
080 Evansville, IN: Non-SMSA Counties - IL - Edwards, Gallatin, Hamilton, Lawrence, Saline, Wabash, White IN - Dubois, Knox, Perry, Pike, Spencer KY - Hancock, Hopkins, McLean, Mublenberg, Ohio, Union, Webster	3.5
081 Terre Haute, IN: Non-SMSA Counties - IL - Clark, Crawford IN - Parke	2.5

083	Chicago, IL: SMSA Counties: 1600 Chicago, IL -	19.6
	IL - Cook, DuPage, Kane, Lake, McHenry, Will 3740 Kankakee, IL -	9.1
	IL - Kankakee Non-SMSA Counties	18.4
	IL - Bureau, DeKalb, Grundy, Iroquois, Kendall, LaSalle, Livingston, Putnam	
	IN - Jasper, Laporte, Newton, Pulaski, Starke	
084	Champaign - Urbana, IL: SMSA Counties: 1400 Champaign - Urbana - Rantoul, IL -	7.8
	IL - Champaign Non-SMSA Counties -	4.8
	IL - Coles, Cumberland, Douglas, Edgar, Ford, Piatt, Vermilion	
085	Springfield - Decatur, IL: SMSA Counties: 2040 Decatur, IL -	7.6
	IL - Macon 7880 Springfield, IL -	4.5
	IL - Menard, Sangamon Non-SMSA Counties	4.0
	IL - Cass, Christian, Dewitt, Logan, Morgan, Moultrie, Scott, Shelby	
086	Quincy, IL: Non-SMSA Counties	3.1
	IL - Adams, Brown, Pike	
	MO - Lewis, Marion, Pike, Ralls	
087	Peoria, IL: SMSA Counties: 1040 Bloomington - Normal, IL -	2.5
	IL - McLean 6120 Peoria, IL -	4.4
	IL - Peoria, Tazewell, Woodford Non-SMSA Counties -	3.3
	IL - Fulton, Knox, McDonough, Marshall, Mason, Schuyler, Stark, Warren	
088	Rockford, IL: SMSA Counties: 6880 Rockford, IL -	6.3
	IL - Boone, Winnebago Non-SMSA Counties -	4.6
	IL - Lee, Ogle, Stephenson	
098	Dubuque, IA: Non-SMSA Counties -	0.5
	IL - JoDaviess	
	IA - Atlamakee, Clayton, Delaware, Jackson, Winnesheik	
	WI - Crawford, Grant, Lafayette	
099	Davenport, Rock Island, Moline, IA - IL: SMSA Counties: 1960 Davenport, Rock Island, Moline, IA - IL -	4.6
	IL - Henry, Rock Island IA - Scott Non-SMSA Counties -	3.4
	IL - Carroll, Hancock, Henderson, Mercer, Whiteside IA - Clinton, DesMoines, Henry, Lee, Louisa, Muscatine MO - Clark	

107	St. Louis, MO:	
	SMSA Counties:	
	7040 St. Louis, MO - IL -	14.7
	IL - Clinton, Madison, Monroe, St. Clair	
	MO - Franklin, Jefferson, St. Charles,	
	St. Louis, St. Louis City	
	Non-SMSA Counties -	11.4
	IL - Alexander, Bond, Calhoun, Clay,	
	Effingham, Fayette, Franklin, Greene,	
	Jackson, Jasper, Jefferson, Jersey,	
	Johnson, Macoupin, Marion, Montgomery,	
	Perry, Pulaski, Randolph, Richland,	
	Union, Washington, Wayne, Williamson	
	MO - Bollinger, Butler, Cape Girardeau,	
	Carter, Crawford, Dent, Gasconade,	
	Iron, Lincoln, Madison, Maries,	
	Mississippi, Montgomery, Perry,	
	Phelps, Reynolds, Ripley, St. Francois,	
	St. Genevieve, Scott, Stoddard, Warren,	
	Washington, Wayne	

These goals are applicable to all the Contractor's construction work (whether or not it is federal or federally assisted) performed in the covered area. If the Contractor performs construction work in a geographical area located outside of the covered area, it shall apply the goals established for such geographical area where the work is actually performed. With regard to this second area, the Contractor also is subject to the goals for both its federally involved and nonfederally involved construction.

The Contractor's compliance with Executive Order 11246 and the regulations in 41 CFR Part 60-4 shall be based on its implementation of the Equal Opportunity Clause, specific affirmative action obligations required by the provisions and specifications set forth in its federally assisted contracts, and its efforts to meet the goals established for the geographical area where the contract resulting from this solicitation is to be performed. The hours of minority and female employment and training must be substantially uniform throughout the length of the contract, and in each trade, and the Contractor shall make a good faith effort to employ minorities and women evenly on each of its projects. The transfer of minority or female employees or trainees from Contractor to Contractor or from project to project for the sole purpose of meeting the Contractor's goals shall be a violation of the contract, the Executive Order 11246 and the regulations in 41 CFR Part 60-4. Compliance with the goals will be measured against the total work hours performed.

3. The Illinois Department of Transportation will provide written notification to the Director of the Office of Federal Contract Compliance Programs within ten working days of award of any construction contract and/or subcontract in excess of \$10,000 at any tier for construction work under the contract resulting from this solicitation. This notification will list the name, address and telephone number of the subcontractor; employer identification number; estimated dollar amount of the subcontract; estimated starting and completion dates of the subcontract; and the geographical area in which the contract is to be performed.
4. As used in this Notice, and in the contract resulting from this solicitation, the "covered area" is the entire State of Illinois for the goal set forth in APPENDIX A and the county or counties in which the work is located for the goals set forth in APPENDIX B.

STANDARD FEDERAL EQUAL EMPLOYMENT
OPPORTUNITY CONSTRUCTION CONTRACT
SPECIFICATIONS (EXECUTIVE ORDER 11246)

1. As used in these specifications:
 - (a) "Covered area" means the geographical area described in the solicitation from which this contract resulted;
 - (b) "Director" means Director, Office of Federal Contract Compliance Programs, United States Department of Labor, or any person to whom the Director delegates authority;
 - (c) "Employer identification number" means the Federal Social Security number used on the Employer's Quarterly Federal Tax Return, U.S. Treasury Department Form 941;
 - (d) "Minority" includes:
 - (i) Black (all persons having origins in any of the Black African racial groups not of Hispanic origin);
 - (ii) Hispanic (all persons of Mexican, Puerto Rican, Cuban, Central or South American or other Spanish Culture or origin, regardless of race);
 - (iii) Asian and Pacific Islander (all persons having origins in any of the original peoples of the Far East, Southeast Asia, the Indian Subcontinent, or the Pacific Islands); and
 - (iv) American Indian or Alaskan Native (all persons having origins in any of the original peoples of North America and maintaining identifiable tribal affiliations through membership and participation or community identification).
2. Whenever the Contractor, or any Subcontractor at any tier, subcontracts a portion of the work involving any construction trade, it shall physically include in each subcontract in excess of \$10,000. the provisions of these specifications and the Notice which contains the applicable goals for minority and female participation and which is set forth in the solicitations from which this contract resulted.
3. If the Contractor is participating (pursuant to 41 CFR 60-4.5) in a Hometown Plan approved by the U.S. Department of Labor in the covered area either individually or through an association, its affirmative action obligations on all work in the plan area (including goals and timetables) shall be in accordance with that Plan for those trades which have unions participating in the Plan. Contractors must be able to demonstrate their participation in and compliance with the provisions of any such Hometown Plan. Each Contractor or Subcontractor participating in an approved Plan is individually required to comply with its obligations under the EEO clause, and to make a good faith effort to achieve each goal under the Plan in each trade in which it has employees. The overall good faith performance by other Contractors or Subcontractors toward a goal in an approved Plan does not excuse any covered Contractor's or Subcontractor's failure to take good faith efforts to achieve the Plan goals and timetables.

4. The Contractor shall implement the specific affirmative action standards provided in paragraphs 7a through p of these specifications. The goals set forth in the solicitation from which this contract resulted are expressed as percentages of the total hours of employment and training of minority and female utilization the Contractor should reasonably be able to achieve in each construction trade in which it has employees in the covered area. Covered Construction Contractors performing construction work in geographical areas where they do not have a Federal or federally assisted construction contract shall apply the minority and female goals established for the geographical area where the work is being performed. Goals are published periodically in the Federal Register in notice form, and such notices may be obtained from any Office of Federal Contract Compliance Programs office or from Federal procurement contracting officers. The Contractor is expected to make substantially uniform progress toward its goals in each craft during the period specified.
5. Neither the provisions of any collective bargaining agreement, nor the failure by a union with whom the Contractor has a collective bargaining agreement, to refer either minorities or women shall excuse the Contractor's obligations under these specifications, Executive Order 11246, or the regulations promulgated pursuant thereto.
6. In order for the nonworking training hours of apprentices and trainees to be counted in meeting the goals, such apprentices and trainees must be employed by the Contractor during the training period, and the Contractor must have made a commitment to employ the apprentices and trainees at the completion of their training, subject to the availability of employment opportunities. Trainees must be trained pursuant to training programs approved by the U.S. Department of Labor.
7. The Contractor shall take specific affirmative actions to ensure equal employment opportunity. The evaluation of the Contractor's compliance with these specifications shall be based upon its effort to achieve maximum results from its actions. The Contractor shall document these efforts fully, and shall implement affirmative action steps at least as extensive as the following:
 - (a) Ensure and maintain a working environment free of harassment, intimidation, and coercion at all sites, and in all facilities at which the Contractor's employees are assigned to work. The Contractor, where possible, will assign two or more women to each construction project. The Contractor shall specifically ensure that all foremen, superintendents, and other on-site supervisory personnel are aware of and carry out the Contractor's obligation to maintain such a working environment, with specific attention to minority or female individuals working as such sites or in such facilities.
 - (b) Establish and maintain a current list of minority and female recruitment sources, provide written notification to minority and female recruitment sources and to community organizations when the Contractor or its unions have employment opportunities available, and maintain a record of the organizations' responses.
 - (c) Maintain a current file of the names, addresses and telephone numbers of each minority and female off-the-street applicant and minority or female referral from a union, a recruitment source or community organization and of what action was taken with respect to each such individual. If such individual was sent to the union hiring hall for referral and was not referred back to the Contractor by the union or, if referred, not employed by the Contractor, this shall be documented in the file with the reason therefor, along with whatever additional actions the Contractors may have taken.
 - (d) Provide immediate written notification to the Director when the union or unions with which the Contractor has a collective bargaining agreement has not referred to the Contractor a minority person or woman sent by the Contractor, or when the Contractor has other information that the union referral process has impeded the Contractor's efforts to meet its obligations.
 - (e) Develop on-the-job training opportunities and/or participate in training programs for the area which expressly include minorities and women, including upgrading programs and apprenticeship and trainee programs relevant to the Contractor's employment needs, especially those programs funded or approved by the Department of Labor. The Contractor shall provide notice of these programs to the sources compiled under 7b above.
 - (f) Disseminate the Contractor's EEO policy by providing notice of the policy to unions and training programs and requesting their cooperation in assisting the Contractor in meeting its EEO obligations; by including it in any policy manual and collective bargaining agreements; by publicizing it in the company newspaper, annual report, etc.; by specific review of the policy with all management personnel and with all minority and female employees at least once a year; and by posting the company EEO policy on bulletin boards accessible to all employees at each location where construction work is performed.
 - (g) Review, at least annually, the company's EEO policy and affirmative action obligations under these specifications with all employees having any responsibility for hiring, assignment, layoff, termination or other employment decisions including specific review of these items with onsite supervisory personnel such as Superintendents, General Foreman, etc., prior to the initiation of construction work at any job site. A written record shall be made and maintained identifying the time and place of these meetings, persons attending, subject matter discussed, and disposition of the subject matter.
 - (h) Disseminate the Contractor's EEO policy externally by including it in any advertising in the news media, specifically including minority and female news media, and providing written notification to and discussing the Contractor's EEO policy with other Contractors and Subcontractors with whom the Contractor does or anticipates doing business.
 - (i) Direct its recruitment efforts, both oral and written, to minority, female and community organizations, to schools with minority and female students and to minority and female recruitment and training organizations serving the Contractor's recruitment area and employment needs. Not later than one month prior to the date for the acceptance of applications for apprenticeship or other training by any recruitment source, the Contractor shall send written notification to organizations such as the above, describing the openings, screening procedures, and tests to be used in the selection process.
 - (j) Encourage present minority and female employees to recruit other minority persons and women and, where reasonable, provide after school, summer and vacation employment to minority and female youth both on the site and in other areas of a Contractor's workforce.
 - (k) Validate all tests and other selection requirements where there is an obligation to do so under 41 CFR Part 60-3.

- (l) Conduct, at least annually, an inventory and evaluation at least of all minority and female personnel for promotional opportunities and encourage these employees to seek or to prepare for, through appropriate training, etc., such opportunities.
 - (m) Ensure that seniority practices, job classifications, work assignments and other personnel practices, do not have a discriminatory effect by continually monitoring all personnel and employment related activities to ensure that the EEO policy and the Contractor's obligations under these specifications are being carried out.
 - (n) Ensure that all facilities and company activities are nonsegregated except that separate or single-user toilet and necessary changing facilities shall be provided to assure privacy between the sexes.
 - (o) Document and maintain a record of all solicitations of offers for subcontracts from minority and female construction Contractors and suppliers, including circulation of solicitations to minority and female Contractor associations and other business associations.
 - (p) Conduct a review, at least annually, of all supervisors' adherence to and performance under the Contractor's EEO policies and affirmative action obligations.
8. Contractors are encouraged to participate in voluntary associations which assist in fulfilling one or more of their affirmative action obligations (7a through p). The efforts of a Contractor association, joint Contractor-union, Contractor-community, or other similar group of which the Contractor is a member and participant, may be asserted as fulfilling any one or more of its obligations under 7a through p of these Specifications provided that the Contractor actively participates in the group, makes every effort to assure that the group has a positive impact on the employment of minorities and women in the industry, ensures that the concrete benefits of the program are reflected in the Contractor's minority and female workforce participation makes a good faith effort to meet its individual goals and timetables, and can provide access to documentation which demonstrates the effectiveness of actions taken on behalf of the Contractor. The obligation to comply, however, is the Contractor's and failure of such a group to fulfill an obligation shall not be a defense for the Contractor's noncompliance.
 9. A single goal for minorities and a separate single goal for women have been established. The Contractor, however, is required to provide equal employment opportunity and to take affirmative action for all minority groups, both male and female, and all women, both minority and non-minority. Consequently, the Contractor may be in violation of the Executive Order if a particular group is employed in a substantially disparate manner (for example, even though the Contractor has achieved its goals for women generally, the Contractor may be in violation of the Executive Order if a specified minority group of women is underutilized).
 10. The Contractor shall not use the goals and timetables or affirmative action standards to discriminate against any person because of race, color, religion, sex, or national origin.
 11. The Contractor shall not enter into any Subcontract with any person or firm debarred from Government contracts pursuant to Executive Order 11246.
 12. The Contractor shall carry out such sanctions and penalties for violation of these specifications and of the Equal Opportunity Clause, including suspension, termination and cancellation of existing subcontracts as may be imposed or ordered pursuant to Executive Order 11246, as amended, and its implementing regulations, by the Office of Federal Contract Compliance Programs. Any Contractor who fails to carry out such sanctions and penalties shall be in violation of these specifications and Executive Order 11246, as amended.
 13. The Contractor, in fulfilling its obligations under these specifications, shall implement specific affirmative action steps, at least as extensive as those standards prescribed in paragraph 7 of these specifications, so as to achieve maximum results from its efforts to ensure equal opportunity. If the Contractor fails to comply with the requirements of the Executive Order, the implementing regulations, or these specifications, the Director shall proceed in accordance with 41 CFR 60-4.8.
 14. The Contractor shall designate a responsible official to monitor all employment related activity to ensure that the company EEO policy is being carried out, to submit reports relating to the provisions hereof as may be required by the Government and to keep records. Records shall at least include for each employee the name, address, telephone numbers, construction trade, union affiliation if any, employee identification number when assigned, social security number, race, sex, status (e.g., mechanic, apprentice, trainee, helper, or laborer), dates of changes in status, hours worked per week in the indicated trade, rate of pay, and locations at which the work was performed. Records shall be maintained in an easily understandable and retrievable form; however, to the degree that existing records satisfy his requirement, Contractors shall not be required to maintain separate records.
 15. Nothing herein provided shall be construed as a limitation upon the application of other laws which establish different standards of compliance or upon the application of requirements for the hiring of local or other area residents (e.g., those under the Public Works Employment Act of 1977 and the Community Development Block Grant Program).

State of Illinois
Department of Transportation

SPECIAL PROVISION
FOR
SPECIFIC EQUAL EMPLOYMENT OPPORTUNITY RESPONSIBILITIES
NONFEDERAL-AID CONTRACTS

Effective: March 20, 1969
Revised: January 1, 1994

1. General

- a. The requirements set forth herein shall constitute the specific affirmative action requirements under this contract and supplement the non-discrimination requirements contained elsewhere in this proposal.
- b. The Contractor shall work with the Illinois Department of Transportation (IDOT) in carrying out Equal Employment Opportunity (EEO) obligations and in reviews of activities under the contract.
- c. The Contractor, and all subcontractors holding subcontracts (not including material suppliers) of \$10,000 or more, shall comply with the following minimum specific requirement activities of EEO. The Contractor shall include these requirements in every subcontract of \$10,000 or more with such modification of language as is necessary to make them binding on the subcontractor.

2. Equal Employment Opportunity Policy

The Contractor shall accept as operating policy the following statement which is designed to further the provision of EEO to all persons, and to promote the full realization of equal employment opportunity through a positive continuing program: "It is the policy of this Company to ensure that applicants are employed, and that employees are treated during employment, without regard to their race, religion, sex, color, national origin, age, or disability. Such action shall include: employment, upgrading, demotion, or transfer; recruitment or recruitment advertising; layoff or termination; rates of pay or other forms of compensation; and selection for training, including apprenticeship, pre-apprenticeship, and/or on-the-job training."

3. Equal Employment Opportunity Officer

The Contractor shall designate and make known to IDOT contracting officers an EEO Officer who will have the responsibility for and must be capable of effectively administering and promoting an active Contractor program of EEO and who must be assigned adequate authority and responsibility to do so.

4. Dissemination of Policy

- a. All members of the Contractor's staff who are authorized to hire, supervise, promote, and discharge employees, or who recommend such action, or who are substantially involved in such action, will be made fully cognizant of, and will implement, the Contractor's EEO policy and contractual responsibilities to provide EEO in each grade and classification of employment. To ensure that the above agreement will be met, the following actions will be taken as a minimum:
 - (1) Periodic meetings of supervisory and personnel office employees will be conducted before the start of work and then not less often than once every six months, at which time the Contractor's EEO policy and its implementation will be reviewed and explained. The meetings will be conducted by the EEO Officer.
 - (2) All new supervisory or personnel office employees will be given a thorough indoctrination by the EEO Officer, covering all major aspects of the Contractor's EEO obligations within thirty days following their reporting for duty with the Contractor.
 - (3) All personnel who are engaged in direct recruitment for the project will be instructed by the EEO Officer in the Contractor's procedures for locating and hiring minority and female employees.
- b. In order to make the Contractor's EEO policy known to all employees, prospective employees, and potential sources of employees, i.e., schools, employment agencies, labor unions (where appropriate), college placement officers, etc., the Contractor shall take the following actions:
 - (1) Notices and posters setting forth the Contractor's EEO policy will be placed in areas readily accessible to employees, applicants for employment and potential employees.
 - (2) The Contractor's EEO policy and the procedures to implement such policy shall be brought to the attention of employees by means of meetings, employee handbooks, or other appropriate means.

5. Recruitment

- a. When advertising for employees, the Contractor shall include in all advertisements for employees the notation: "An Equal Opportunity Employer". All such advertisements shall be published in newspapers, or other publications, having a large circulation among minority groups in the area from which the project work force would normally be derived.
- b. The Contractor shall, unless precluded by a valid bargaining agreement, conduct systematic and direct recruitment through public and private employee referral sources likely to yield qualified minority and female applicants, including, but not limited to, State employment

agencies, schools, colleges and minority and female organizations. To meet this requirement, the Contractor shall, identify sources of potential minority and female employees, and establish with such identified sources procedures whereby minority and female applicants may be referred to the Contractor for employment consideration. In the event the Contractor has a valid bargaining agreement providing for exclusive hiring hall referrals, he/she is expected to observe the provisions of that agreement to the extent that the system permits the Contractor's compliance with EEO contract provisions.

- c. The Contractor shall encourage present employees to refer minority and female applicants for employment by posting appropriate notices or bulletins in areas accessible to all such employees. In addition, information and procedures with regard to referring minority and female applicants shall be discussed with employees.

6. Personnel Actions

Wages, working conditions, and employee benefits shall be established and administered, and personnel actions of every type, including hiring, upgrading, promotion, transfer, demotion, layoff, and termination, will be taken without regard to race, color, religion, sex, national origin, age, or disability. The following procedures shall be followed:

- a. The Contractor shall conduct periodic inspections of project sites to insure that working conditions and employee facilities do not indicate discriminatory treatment of project site personnel.
- b. The Contractor shall periodically evaluate the spread of wages paid within each classification to determine any evidence of discriminatory wage practices.
- c. The Contractor shall periodically review selected personnel actions in depth to determine whether there is evidence of discrimination. Where evidence is found, the Contractor shall promptly take corrective action. If the review indicates that the discrimination may extend beyond the actions reviewed, such corrective action shall include all affected persons.
- d. The Contractor shall promptly investigate all complaints of alleged discrimination made to the Contractor in connection with the obligations under this contract, shall attempt to resolve such complaints, and shall take appropriate corrective action within a reasonable time. If the investigation indicates that the discrimination may affect persons other than the complainant, such corrective action shall include such other persons. Upon completion of each investigation, the Contractor shall inform every complainant of all of the avenues of appeal.

7. Training and Promotion

- a. The Contractor shall assist in locating, qualifying and increasing the skills of minority and female employees and applicants for employment.
- b. Consistent with the Contractor's work force requirements and as permissible under Federal and State regulations, the Contractor shall make full use of training programs, i.e., apprenticeship, and on-the-job training programs for the geographical area of contract performance.
- c. The Contractor shall advise employees and applicants for employment of available training programs and entrance requirements for each.
- d. The Contractor shall periodically review the training and promotion potential of minority and female employees and shall encourage eligible employees to apply for such training and promotion.

8. Unions

If the Contractor relies in whole or in part upon unions as a source of employees, the Contractor shall use his/her best efforts to obtain the cooperation of such unions to increase opportunities for minorities and females within the unions, and to effect referrals by such unions of minority and female employees. Actions by the Contractor, either directly or through a Contractor's association acting as agent, shall include the procedures set forth below:

- a. The Contractor shall use best efforts to develop, in cooperation with the unions, joint training programs aimed toward qualifying more minority and female employees for membership in the unions and increasing the skills of minority and female employees so that they may qualify for higher paying employment.
- b. The Contractor shall use best efforts to incorporate an EEO clause into each union agreement to the end that such union shall be contractually bound to refer applicants without regard to their race, color, religion, sex, national origin, age, or disability.
- c. The Contractor is to obtain information as to the referral practices and policies of the labor union, except that to the extent such information is within the exclusive possession of the labor union and such labor union refuses to furnish such information to the Contractor, the Contractor shall so certify to IDOT and shall set forth what efforts have been made to obtain such information.
- d. In the event the union is unable to provide the Contractor with a reasonable flow of minority and female referrals within the time limit set forth in the collective bargaining agreement, the Contractor shall, through independent recruitment efforts, fill the employment vacancies without regard to race, color, religion, sex, national origin, age, or disability; making full efforts to obtain qualified and/or qualifiable minorities and females. (The U.S. Department of Labor has held that it shall be no excuse that the union with which the Contractor has a collective bargaining agreement providing for exclusive referral failed to refer minorities or female employees). In the event the union referral practice prevents the Contractor from meeting the obligations pursuant to these Special Provisions, such Contractor shall immediately notify IDOT.

9. Selection of Subcontractors, Procurement of Materials, and Leasing of Equipment

The Contractor shall not discriminate on the grounds of race, color, religion, sex, national origin, age, or disability in the selection and retention of subcontractors, including procurement of materials and leases of equipment.

- a. The Contractor shall notify all potential subcontractors and suppliers of his/her EEO obligations under this contract.
- b. Disadvantaged business enterprises (DBE), as defined in 49 CFR Part 23, shall have equal opportunity to compete for and perform subcontracts which the Contractor enters into pursuant to this contract. The Contractor shall use best efforts to solicit bids from and to utilize DBE subcontractors or subcontractors with meaningful minority and female representation among their employees. Contractors shall obtain lists of DBE construction firms from IDOT personnel.
- c. The Contractor shall use his/her best efforts to ensure subcontractor compliance with their EEO obligations.

10. Records and Reports

The Contractor shall keep such records as necessary to document compliance with the EEO requirements. Such records shall be retained for a period of three years following completion of the contract work and shall be available at reasonable times and places for inspection by authorized representatives of IDOT.

- a. The records kept by the Contractor shall document the following:
 - (1) the number of minorities, non-minorities and females employed in each work classification on the project;
 - (2) the progress and efforts being made in cooperation with unions, when applicable, to increase employment opportunities for minorities and females;
 - (3) the progress and efforts being made in locating, hiring, training, qualifying, and upgrading minority and female employees; and
 - (4) the progress and efforts being made in securing the services of DBE subcontractors, or subcontractors with meaningful minority and female representation among their employees.
- b. The Contractor shall submit to IDOT a monthly report every month for the duration of the project, indicating the number of minority, non-minority and female employees currently engaged in each work classification required by contract work and the number of hours worked. This information is to be reported on Form SBE-956. If on-the-job training is being required by special provision, the Contractor will be required to collect and report training data.

State of Illinois
Department of Transportation

SPECIAL PROVISION
FOR
REQUIRED PROVISIONS – STATE CONTRACTS

Effective: April 1 1965
Revised: January 1, 2017

I. SELECTION OF LABOR

The Contractor shall comply with all Illinois statutes pertaining to the selection of labor.

EMPLOYMENT OF ILLINOIS WORKERS DURING PERIODS OF
EXCESSIVE UNEMPLOYMENT

Whenever there is a period of excessive unemployment in Illinois, which is defined herein as any month immediately following two consecutive calendar months during which the level of unemployment in the State of Illinois has exceeded five percent as measured by the United States Bureau of Labor Statistics in its monthly publication of employment and unemployment figures, the Contractor shall employ at least 90 percent Illinois laborers. "Illinois laborer" means any person who has resided in Illinois for at least 30 days and intends to become or remain an Illinois resident.

Other laborers may be used when Illinois laborers as defined herein are not available, or are incapable of performing the particular type of work involved, if so certified by the Contractor and approved by the Engineer. The Contractor may place no more than three of his/her regularly employed non-resident executive and technical experts, who do not qualify as Illinois laborers, to do work encompassed by this Contract during period of excessive unemployment.

This provision applies to all labor, whether skilled, semi-skilled, or unskilled, whether manual or non-manual.

II. EQUAL EMPLOYMENT OPPORTUNITY

In the event of the Contractor's noncompliance with the provisions of this Equal Employment Opportunity Clause, the Illinois Human Rights Act or the Illinois Department of Human Rights Rules and Regulations, the Contractor may be declared ineligible for future contracts or subcontracts with the State of Illinois or any of its political sub-divisions or municipal corporations, and the contract may be cancelled or voided in whole or in part, and such other sanctions or penalties may be imposed or remedies invoked as provided by statute or regulation.

During the performance of this Contract, the Contractor agrees as follows:

1. That it will not discriminate against any employee or applicant for employment because of race, color, religion, sex, sexual orientation, marital status, order of protection status, national origin or ancestry, citizenship status, age, physical or mental disability unrelated to ability, military status, or an unfavorable discharge from military service; and further that it will examine all job classifications to determine if minority persons or women are underutilized and will take appropriate affirmative action to rectify any such underutilization.
2. That, if it hires additional employees in order to perform this contract or any portion hereof, it will determine the availability (in accordance with the Illinois Department of Human Rights Rules and Regulations) of minorities and women in the area(s) from which it may reasonably recruit and it will hire for each job classification for which employees are hired in such a way that minorities and women are not underutilized.
3. That, in all solicitations or advertisements for employees placed by it or on its behalf, it will state that all applicants will be afforded equal opportunity without discrimination because of race, color, religion, sex, sexual orientation, marital status, order of protection status, national origin or ancestry, citizenship status, age, physical or mental disability unrelated to ability, military status, or an unfavorable discharge from military service.
4. That it will send to each labor organization or representative of workers with which it has or is bound by a collective bargaining or other agreement or understanding, a notice advising such labor organization or representative of the Contractor's obligations under the Illinois Human Rights Act and the Illinois Department of Human Rights Rules and Regulations. If any labor organization or representative fails or refuses to cooperate with the Contractor in its efforts to comply with such Act and Rules and Regulations, the Contractor will promptly so notify the Illinois Department of Human Rights and IDOT and will recruit employees from other sources when necessary to fulfill its obligations thereunder.
5. That it will submit reports as required by the Illinois Department of Human Rights Rules and Regulations, furnish all relevant information as may from time to time be requested by the Illinois Department of Human Rights or IDOT, and in all respects comply with the Illinois Human Rights Act and the Illinois Department of Human Rights Rules and Regulations.
6. That it will permit access to all relevant books, records, accounts and work sites by personnel of IDOT and the Illinois Department of Human Rights for purposes of investigation to ascertain compliance with the Illinois Human Rights Act and the Illinois Department of Human Rights Rules and Regulations.
7. That it will include verbatim or by reference the provisions of this clause in every subcontract it awards under which any portion of the contract obligations are undertaken or assumed, so that the provisions will be binding upon the subcontractor. In the same manner as with other provisions of this contract, the Contractor will be liable for compliance with applicable provisions of this clause by subcontractors; and further it will promptly notify IDOT and the Illinois Department of Human Rights in the event any subcontractor fails or refuses to comply with these provisions. In addition, the Contractor will not utilize any subcontractor declared by the Illinois Human Rights Commission to be ineligible for contracts or subcontracts with the State of Illinois or any of its political subdivisions or municipal corporations.

III. SUBLETTING OR ASSIGNING THE CONTRACT

1. The Contractor shall perform with his/her own organization contract work amounting to not less than 51 percent of the original total contract price, except that any items designated by the State as "Specialty Items" may be performed by subcontract and the amount of any such "Specialty Items" so performed may be deducted from the original total contract price before computing the amount of work required to be performed by the Contractor with his/her own organization.
 - a. "His/her own organization" shall be construed to include only worker employed and paid directly by the Contractor and equipment owned or rented by him/her, with or without operators.
 - b. "Specialty Items" shall be construed to be limited to work that requires specialized knowledge, craftsmanship or equipment not ordinarily available in contracting organizations qualified to bid on the contract as a whole and in general are to be limited to minor components of the overall contract.
2. In addition to the 51 percent requirement set forth in paragraph 1 above, the Contractor shall furnish (a) a competent superintendent or foreman who is employed by him/her, who has full authority to direct performance of the work in accordance with the contract requirements, and who is in charge of all construction operations (regardless of who performs the work), and (b) such other of his/her own organizational capability and responsibility (supervision, management, and engineering services) as the State highway department contracting officer determines is necessary to assure the performance of the contract.
3. The Contractor shall not sublet, sell, transfer, assign or otherwise dispose of the contract or contracts or any portion thereof, or of his/her right, title or interest therein, without written consent of the Engineer. In case such consent is given, the Contractor will be permitted to sublet a portion thereof, but shall perform with the Contractor's own organization, work amounting to not less than 51 percent of the total contract cost, except that any items designated in the contract as "specialty items" may be performed by subcontract and the cost of any such specialty items so performed by subcontract may be deducted from the total cost before computing the amount of work required to be performed by the Contractor with his/her own organization. Materials purchased or produced by the Contractor must be incorporated into the project by the Contractor's own organization if their cost is to be applied to the 50 percent requirement.

No subcontracts, or transfer of contract, shall in any case release the Contractor of his/her liability under the contract and bonds. All transactions of the Engineer shall be with the Contractor. The Contractor shall have representative on the job at all times when either contract or subcontract work is being performed.

All requests to subcontract shall contain a certification that the subcontract agreement exists in writing and physically contains the required Federal and State Equal Employment Opportunity provisions and Labor compliance provisions, including the contract minimum wage requirements. The Contractor shall permit Department or Federal representatives to examine the subcontract agreements upon notice.

4. Any items that have been selected as "Specialty Items" for the contract are listed as such in the Special Provisions, bid schedule, or elsewhere in the contract documents.
5. No portion of the contract shall be sublet, assigned or otherwise disposed of, except with the written consent of the State highway department contracting officer, or his/her authorized representative, and such consent when given shall not be construed to relieve the Contractor of any responsibility for the fulfillment of the contract. Request for permission to sublet, assign or otherwise dispose of any portion of the contract shall be in writing and accompanied by (a) a showing that the organization which will perform the work is particularly experienced and equipped for such work, and (b) an assurance by the Contractor that the labor standards provisions set forth in this contract shall apply to labor performed on all work encompassed by the request.

IV. COMPLIANCE WITH THE PREVAILING WAGE ACT

1. **Prevailing Wages.** All wages paid by the Contractor and each subcontractor shall be in compliance with The Prevailing Wage Act (820 ILCS 130), as amended, except where a prevailing wage violates a federal law, order, or ruling, the rate conforming to the federal law, order, or ruling shall govern. The Contractor shall be responsible to notify each subcontractor of the wage rates set forth in this contract and any revisions thereto. If the Department of Labor revises the wage rates, the Contractor will not be allowed additional compensation on account of said revisions. Current wage rate information shall be obtained by visiting the Department of Labor website at <http://www.illinois.gov/idol/Pages/default.aspx>. It is the responsibility of the Contractor to review the rates applicable to the work of this contract at regular intervals in order to insure the timely payment of current rates. Provision of this information to the Contractor by means of the Department of Labor website satisfies the notification of revisions by the Department to the Contractor pursuant to the Act, and the Contractor agrees that no additional notice is required.
2. **Payroll Records.** The Contractor and each subcontractor shall make and keep, for a period of three years from the later of the date of final payment under the contract or completion of the contract, records of the wages paid to his/her workers. The payroll records shall include each worker's name, address, telephone number, social security number, classification, rate of pay, number of hours worked each day, starting and ending times of work each day, total hours worked each week, itemized deductions made, and actual wages paid. Upon seven business days' notice, these records shall be available at a location within the State, during reasonable hours, for inspection by the Department or the Department of Labor; and Federal, State, or local law enforcement agencies and prosecutors.
3. **SUBMISSION OF PAYROLL RECORDS (BDE)**

Effective: April 1, 2021
Revised: November 2, 2023

Submission of Payroll Records. The Contractor and each subcontractor shall, no later than the 15th day of each calendar month, file a certified payroll for the immediately preceding month to the Illinois Department of Labor (IDOL) through the Illinois Prevailing Wage Portal in compliance with the State Prevailing Wage Act (820 ILCS 130). The portal can be found on the IDOL website at <https://www2.illinois.gov/idol/Laws-Rules/CONMED/Pages/Prevailing-Wage-Portal.aspx>. Payrolls shall be submitted in the format prescribed by the IDOL.

In addition to filing certified payroll(s) with the IDOL, the Contractor and each subcontractor shall certify and submit payroll records to the Department each week from the start to the completion of their respective work, except that full social security numbers shall not be included on weekly submittals. Instead, the payrolls shall include an identification number for each employee (e.g., the last four digits of the employee's social security number). In addition, starting and ending times of work each day may be omitted from the payroll records submitted. The submittals shall be made using LCPTracker Pro software. The software is web-based and can be accessed at <https://lcptracker.com/>. When there has been no activity during a work week, a payroll record shall still be submitted with the appropriate option ("No Work", "Suspended", or "Complete") selected."

4. Employee Interviews. The Contractor and each subcontractor shall permit his/her employees to be interviewed on the job, during working hours, by compliance investigators of the Department or the Department of Labor.

V. NONSEGREGATED FACILITIES

(Applicable to State Financed Construction Contracts and related subcontracts exceeding \$10,000 which are not exempt from the Equal Opportunity clause).

By submission of this bid, the execution of this contract or subcontract, or the consummation of this material supply agreement, as appropriate, the bidder, construction Contractor, subcontractor, or material supplier, as appropriate, certifies that (s)he does not maintain or provide for his/her employees any segregated facilities at any of his/her establishments, and that (s)he does not permit his/her employees to perform their services at any location, under his/her control, where segregated facilities are maintained. (S)He certifies further that (s)he will not maintain or provide for his/her employees any segregated facilities at any of his/her establishments, and that (s)he will not permit his/her employees to perform their services at any location, under his/her control, where segregated facilities are maintained. (S)He agrees that a breach of this certification is a violation of the Equal Opportunity clause in this contract. As used in this certification, the term "segregated facilities" means any waiting rooms, work areas, restrooms and washrooms, restaurants and other eating areas, time clocks, locker rooms and other storage or dressing areas, parking lots, drinking fountains, recreation or entertainment areas, transportation, and housing facilities provided for employees which are segregated by explicit directive or are in fact segregated on the basis of race, creed, color, or national origin, because of habit, local custom, or otherwise. (S)He agrees that (except where he/she has obtained identical certifications from proposed subcontractors and material suppliers for specific time periods), he/she will obtain identical certifications from proposed subcontractors or material suppliers prior to the award of subcontracts or the consummation of material supply agreements, exceeding \$10,000 which are not exempt from the provisions of the Equal Opportunity clause, and that (s)he will retain such certifications in his/her files.

State of Illinois
Department of Transportation

SPECIAL PROVISION
FOR
SECTION 80 PROSECUTION AND PROGRESS

This Special Provision amends the provisions of the Standard Specifications for Construction of Airports, adopted April 1, 2012 and shall be construed to be a part thereof, superseding any conflicting provisions thereof applicable to the work under the contract.

80-09 FAILURE TO COMPLETE ON TIME.

DELETE: "See contract documents for current schedule of deductions."

ADD:

Schedule of Deductions for Each Day of Overrun in Contract Time			
Original Contract Amount		Daily Charges	
From More Than	To and Including	Calendar Day	Work Day
\$ 0	\$ 100,000	\$ 475	\$ 675
100,000	500,000	750	1,050
500,000	1,000,000	1,025	1,425
1,000,000	3,000,000	1,275	1,725
3,000,000	6,000,000	1,425	2,000
6,000,000	12,000,000	2,300	3,450
12,000,000	And over	6,775	9,525

State of Illinois
Department of Transportation

SPECIAL PROVISION
FOR
SECTION 90 MEASUREMENT AND PAYMENT

This Special Provision amends the provisions of the Standard Specifications for Construction of Airports, adopted April 1, 2012 and shall be construed to be a part thereof, superseding any conflicting provisions thereof applicable to the work under the contract.

90-07 PARTIAL PAYMENTS.

DELETE: The entire section.

ADD: Partial payments will be made to the Contractor at least once each month as the work progresses. The payments will be based upon estimates, prepared by the Resident Engineer, of the value of the work performed and materials complete and in place in accordance with the contract, plans, and specifications. Such partial payments may also include the delivered actual cost of those materials stockpiled and stored in accordance with the Section 90-08 PAYMENT FOR MATERIALS ON HAND. From the amount of partial payment so determined on Federal-Aid projects, there shall be deducted an amount up to ten percent of the cost of the completed work which shall be retained until all conditions necessary for financial closeout of the project are satisfied. The amount of the estimate approved as due for payment will be vouchered by the Department and presented to the State Comptroller for payment. No amount less than \$1,000.00 will be approved for payment other than the final payment. A final voucher for under \$5.00 shall not be paid except through electronic funds transfer. (15 ILCS 405/9(b-1))

It is understood and agreed that the Contractor shall not be entitled to demand or receive partial payment based on quantities of work in excess of those provided in the proposal or covered by approved change orders, except when such excess quantities have been determined by the Engineer to be a part of the final quantity for the item of work in question.

No partial payment shall bind the Department to the acceptance of any materials or work in place as to quality or quantity. All partial payments are subject to correction at the time of final payment as provided in Section 90-09 ACCEPTANCE AND FINAL PAYMENT.

Progress payments may be reduced by liens filed pursuant to Section 23(c) of the Mechanics Lien Act, 770 ILCS 60/23(c).

If a Contractor or subcontractor has defaulted on a loan issued under the Department's Disadvantaged Business Revolving Loan Program (20 ILCS 2705/2705-610) progress payments may be reduced pursuant to the terms of that loan agreement. In such cases, the amount of the estimate related to the work performed by the Contractor or subcontractor, in default of the loan agreement, will be offset, in whole or in part, and vouchered by the Department to the Working Capital Revolving Fund or designated escrow account. Payment for the work shall be considered as issued and received by the Contractor or subcontractor on the date of the offset voucher. Further, the amount of the offset voucher shall be a credit against the Department's obligation to pay the Contractor, the Contractor's obligation to pay the subcontractor, and the Contractor's or subcontractor's total loan indebtedness to the Department. The offset shall continue until such time as the entire loan indebtedness is satisfied. The Department will notify the Contractor and Fund Control Agent in a timely manner of such offset. The Contractor or subcontractor shall not be entitled to additional payment in consideration of the offset.

In accordance with 49 USC § 47111, the Department will not make payments totaling more than 90 percent of the contract until all conditions necessary for financial closeout of the project are satisfied.

The failure to perform any requirement, obligation, or term of the contract by the Contractor shall be reason for withholding any progress payments until the Department determines that compliance has been achieved.

90-10 TRUST AGREEMENT OPTION.

DELETE: The entire section.

STATE OF ILLINOIS

SPECIAL PROVISIONS

The following Special Provisions supplement the "Standard Specifications for Construction of Airports," adopted April 1, 2012, and the Special Provisions included herein which apply to and govern the airport improvement of: Replace Runway 9/27 Pulse Light Approach Slope Indicator (PLASI) with a Precision Approach Path Indicator (PAPI) at Edgar County, Contract ED021, and in case of conflict with any part or parts of said Specifications, the said Special Provisions shall take precedence and shall govern.

SPECIAL PROVISION FOR COMPLETION TIME VIA CALENDAR DAYS

It being understood and agreed that the completion within the time limit is an essential part of the contract, the bidder agrees to complete the work within **Base Bid: 29 calendar days; Additive Alternate #1: 0 additional calendar days; Additive Alternate #2: 0 additional calendar days; Additive Alternate #3: 0 additional calendar days**, unless additional time is granted by the Engineer in accordance with the provisions of the specifications. In case of failure to complete the work on or before the time named herein, or within such extra time as may have been allowed by extensions, the bidder agrees that the Department of Transportation shall withhold from such sum as may be due him/her under the terms of this contract, the costs, as set forth in Section 80-09 Failure to Complete on Time of the Standard Specifications, which costs shall be considered and treated not as a penalty but as damages due to the State from the bidder by reason of the failure of the bidder to complete the work within the time specified in the contract.

CONSTRUCTION AIR QUALITY – DIESEL VEHICLE EMISSIONS CONTROL (BDE)

Effective: April 1, 2009

Revised: January 2, 2012

Diesel Vehicle Emissions Control. The reduction of construction air emissions shall be accomplished by using cleaner burning diesel fuel. The term "equipment" refers to any and all diesel fuel powered devices (rated at 50 hp and above, to be used on the project site in excess of seven calendar days over the course of the construction period on the project site (including any "rental" equipment).

All equipment on the jobsite, with engine ratings of 50 hp and above, shall be required to: use Ultra Low Sulfur Diesel fuel (ULSD) exclusively (15 ppm sulfur content or less).

Diesel powered equipment in non-compliance will not be allowed to be used on the project site, and is also subject to a notice of non-compliance as outlined below.

The Contractor shall certify that only ULSD will be used in all jobsite equipment. The certification shall be presented to the Department prior to the commencement of the work.

If any diesel powered equipment is found to be in non-compliance with any portion of this specification, the Engineer will issue the Contractor a notice of non-compliance and identify an appropriate period of time, as outlined below under environmental deficiency deduction, in which to bring the equipment into compliance or remove it from the project site.

Any costs associated with bringing any diesel powered equipment into compliance with these diesel vehicle emissions controls shall be considered as included in the contract unit prices bid for the various items of work involved and no additional compensation will be allowed. The Contractor's compliance with this notice and any associated regulations shall also not be grounds for a claim.

Environmental Deficiency Deduction. When the Engineer is notified, or determines that an environmental control deficiency exists, he/she will notify the Contractor in writing, and direct the Contractor to correct the deficiency within a specified time period. The specified time-period, which begins upon Contractor notification, will be from 1/2 hour to 24 hours long, based on the urgency of the situation and the nature of the deficiency. The Engineer shall be the sole judge regarding the time period.

The deficiency will be based on lack of repair, maintenance and diesel vehicle emissions control.

If the Contractor fails to correct the deficiency within the specified time frame, a daily monetary deduction will be imposed for each calendar day or fraction thereof the deficiency continues to exist. The calendar day(s) will begin when the time period for correction is exceeded and end with the Engineer's written acceptance of the correction. The daily monetary deduction will be \$1,000.00 for each deficiency identified.

If a Contractor or subcontractor accumulates three environmental deficiency deductions in a contract period, the Contractor will be shutdown until the deficiency is corrected. Such a shutdown will not be grounds for any extension of contract time, waiver of penalties, or be grounds for any claim.

CONSTRUCTION AIR QUALITY – IDLING RESTRICTION (BDE)

Effective: April 1, 2009

Idling Restrictions. The Contractor shall establish truck-staging areas for all diesel powered vehicles that are waiting to load or unload material at the jobsite. Staging areas shall be located where the diesel emissions from the equipment will have a minimum impact on adjacent sensitive receptors. The

Department will review the selection of staging areas, whether within or outside the existing highway right-of-way, to avoid locations near sensitive areas or populations to the extent possible. Sensitive receptors include, but are not limited to, hospitals, schools, residences, motels, hotels, daycare facilities, elderly housing and convalescent facilities. Diesel powered engines shall also be located as far away as possible from fresh air intakes, air conditioners, and windows. The Engineer will approve staging areas before implementation.

Diesel powered vehicle operators may not cause or allow the motor vehicle, when it is not in motion, to idle for more than a total of 10 minutes within any 60 minute period, except under any of the following circumstances:

- 1) The motor vehicle has a gross vehicle weight rating of less than 8000 lb (3630 kg).
- 2) The motor vehicle idles while forced to remain motionless because of on-highway traffic, an official traffic control device or signal, or at the direction of a law enforcement official.
- 3) The motor vehicle idles when operating defrosters, heaters, air conditioners, or other equipment solely to prevent a safety or health emergency.
- 4) A police, fire, ambulance, public safety, other emergency or law enforcement motor vehicle, or any motor vehicle used in an emergency capacity, idles while in an emergency or training mode and not for the convenience of the vehicle operator.
- 5) The primary propulsion engine idles for maintenance, servicing, repairing, or diagnostic purposes if idling is necessary for such activity.
- 6) A motor vehicle idles as part of a government inspection to verify that all equipment is in good working order, provided idling is required as part of the inspection.
- 7) When idling of the motor vehicle is required to operate auxiliary equipment to accomplish the intended use of the vehicle (such as loading, unloading, mixing, or processing cargo; controlling cargo temperature; construction operations, lumbering operations; oil or gas well servicing; or farming operations), provided that this exemption does not apply when the vehicle is idling solely for cabin comfort or to operate non-essential equipment such as air conditioning, heating, microwave ovens, or televisions.
- 8) When the motor vehicle idles due to mechanical difficulties over which the operator has no control.
- 9) The outdoor temperature is less than 32 °F (0 °C) or greater than 80 °F (26 °C).

When the outdoor temperature is greater than or equal to 32 °F (0 °C) or less than or equal to 80 °F (26 °C), a person who operates a motor vehicle operating on diesel fuel shall not cause or allow the motor vehicle to idle for a period greater than 30 minutes in any 60 minute period while waiting to weigh, load, or unload cargo or freight, unless the vehicle is in a line of vehicles that regularly and periodically moves forward.

The above requirements do not prohibit the operation of an auxiliary power unit or generator set as an alternative to idling the main engine of a motor vehicle operating on diesel fuel.

Environmental Deficiency Deduction. When the Engineer is notified, or determines that an environmental control deficiency exists based on non-compliance with the idling restrictions, he/she will notify the Contractor, and direct the Contractor to correct the deficiency.

If the Contractor fails to correct the deficiency a monetary deduction will be imposed. The monetary deduction will be \$1,000.00 for each deficiency identified.

SPECIAL PROVISION FOR DISADVANTAGED BUSINESS ENTERPRISE PARTICIPATION

Effective: September 1, 2000

Revised: March 2, 2019

FEDERAL OBLIGATION. The Department of Transportation, as a recipient of federal financial assistance, is required to take all necessary and reasonable steps to ensure nondiscrimination in the award and administration of contracts. Consequently, the federal regulatory provisions of 49 CFR Part 26 apply to this contract concerning the utilization of disadvantaged business enterprises. For the purposes of this Special Provision, a disadvantaged business enterprise (DBE) means a business certified by the Department in accordance with the requirements of 49 CFR Part 26 and listed in the Illinois Unified Certification Program (IL UCP) DBE Directory.

STATE OBLIGATION. This Special Provision will also be used by the Department to satisfy the requirements of the Business Enterprise for Minorities, Females, and Persons with Disabilities Act, 30 ILCS 575. When this Special Provision is used to satisfy state law requirements on 100 percent state-funded contracts, the federal government has no involvement in such contracts (not a federal-aid contract) and no responsibility to oversee the implementation of this Special Provision by the Department on those contracts. DBE participation on 100 percent state-funded contracts will not be credited toward fulfilling the Department's annual overall DBE goal required by the US Department of Transportation to comply with the federal DBE program requirements.

CONTRACTOR ASSURANCE. The Contractor makes the following assurance and agrees to include the assurance in each subcontract the Contractor signs with a subcontractor.

The Contractor, subrecipient, or subcontractor shall not discriminate on the basis of race, color, national origin, or sex in the performance of this contract. The Contractor shall carry out applicable requirements of 49 CFR Part 26 in the award and administration of contracts funded in whole or in part with federal or state funds. Failure by the Contractor to carry out these requirements is a material breach of this contract, which may result in the termination of this contract or such other remedy as the recipient deems appropriate, which may include, but is not limited to:

- (a) Withholding progress payments;
- (b) Assessing sanctions;
- (c) Liquidated damages; and/or
- (d) Disqualifying the Contractor from future bidding as non-responsible.

OVERALL GOAL SET FOR THE DEPARTMENT. As a requirement of compliance with 49 CFR Part 26, the Department has set an overall goal for DBE participation in its federally assisted contracts. That goal applies to all federal-aid funds the Department will expend in its federally assisted contracts for the subject reporting fiscal year. The Department is required to make a good faith effort to achieve the overall goal. The dollar amount paid to all approved DBE companies performing work called for in this contract is eligible to be credited toward fulfillment of the Department's overall goal.

CONTRACT GOAL TO BE ACHIEVED BY THE CONTRACTOR. This contract includes a specific DBE utilization goal established by the Department. The goal has been included because the Department has determined the work of this contract has subcontracting opportunities that may be suitable for performance by DBE companies. The determination is based on an assessment of the type of work, the location of the work, and the availability of DBE companies to do a part of the work. The assessment indicates, in the absence of unlawful discrimination and in an arena of fair and open competition, DBE companies can be expected to perform 0.0% of the work. This percentage is set as the DBE participation goal for this contract. Consequently, in addition to the other award criteria established for this contract, the Department will only award this contract to a bidder who makes a good faith effort to meet this goal of DBE participation in the performance of the work. A bidder makes a good faith effort for award consideration if either of the following is done in accordance with the procedures set for in this Special Provision:

- (a) The bidder documents enough DBE participation has been obtained to meet the goal or,
- (b) The bidder documents a good faith effort has been made to meet the goal, even though the effort did not succeed in obtaining enough DBE participation to meet the goal.

DBE LOCATOR REFERENCES. Bidders shall consult the IL UCP DBE Directory as a reference source for DBE-certified companies. In addition, the Department maintains a letting and item specific DBE locator information system whereby DBE companies can register their interest in providing quotes on particular bid items advertised for letting. Information concerning DBE companies willing to quote work for particular contracts may be obtained by contacting the Department's Bureau of Small Business Enterprises at telephone number (217) 785-4611, or by visiting the Department's website at: <http://www.idot.illinois.gov/doing-business/certifications/disadvantaged-business-enterprise-certification/il-ucp-directory/index>.

BIDDING PROCEDURES. Compliance with this Special Provision is a material bidding requirement and failure of the bidder to comply will render the bid not responsive.

The bidder shall submit a DBE Utilization Plan (form SBE 2026), and a DBE Participation Statement (form SBE 2025) for each DBE company proposed for the performance of work to achieve the contract goal, with the bid. If the Utilization Plan indicates the contract goal will not be met, documentation of good faith efforts shall also be submitted. The documentation of good faith efforts must include copies of each DBE and non-DBE subcontractor quote submitted to the bidder when a non-DBE subcontractor is selected over a DBE for work on the contract. The required forms and documentation must be submitted as a single .pdf file using the "Integrated Contractor Exchange (iCX)" application within the Department's "EBids System".

The Department will not accept a Utilization Plan if it does not meet the bidding procedures set forth herein and the bid will be declared not responsive. In the event the bid is declared not responsive, the Department may elect to cause the forfeiture of the penal sum of the bidder's proposal guaranty and may deny authorization to bid the project if re-advertised for bids.

GOOD FAITH EFFORT PROCEDURES. The contract will not be awarded until the Utilization Plan is approved. All information submitted by the bidder must be complete, accurate and adequately document enough DBE participation has been obtained or document the good faith efforts of the bidder, in the event enough DBE participation has not been obtained, before the Department will commit to the performance of the contract by the bidder. The Utilization Plan will be approved by the Department if the Utilization Plan documents sufficient commercially useful DBE work to meet the contract goal or the bidder submits sufficient documentation of a good faith effort to meet the contract goal pursuant to 49 CFR Part 26, Appendix A. This means the bidder must show that all necessary and reasonable steps were taken to achieve the contract goal. Necessary and reasonable steps are those which, by their scope, intensity and appropriateness to the objective, could reasonably be expected to obtain sufficient DBE participation, even if they were not successful. The Department will consider the quality, quantity, and intensity of the kinds of efforts the bidder has made. Mere *pro forma* efforts, in other words efforts done as a matter of form, are not good faith efforts; rather, the bidder is expected to have taken genuine efforts that would be reasonably expected of a bidder actively and aggressively trying to obtain DBE participation sufficient to meet the contract goal.

(a) The following is a list of types of action that the Department will consider as part of the evaluation of the bidder's good faith efforts to obtain participation. These listed factors are not intended to be a mandatory checklist and are not intended to be exhaustive. Other factors or efforts brought to the attention of the Department may be relevant in appropriate cases and will be considered by the Department.

(1) Soliciting through all reasonable and available means (e.g. attendance at pre-bid meetings, advertising and/or written notices) the interest of all certified DBE companies that have the capability to perform the work of the contract. The bidder must solicit this interest within sufficient time to allow the DBE companies to respond to the solicitation. The bidder must determine with certainty if the DBE companies are interested by taking appropriate steps to follow up initial solicitations.

(2) Selecting portions of the work to be performed by DBE companies in order to increase the likelihood that the DBE goals will be achieved. This includes, where appropriate, breaking out contract work items into economically feasible units to facilitate DBE participation, even when the Contractor might otherwise prefer to perform these work items with its own forces.

(3) Providing interested DBE companies with adequate information about the plans, specifications, and requirements of the contract in a timely manner to assist them in responding to a solicitation.

(4) a. Negotiating in good faith with interested DBE companies. It is the bidder's responsibility to make a portion of the work available to DBE subcontractors and suppliers and to select those portions of the work or material needs consistent with the available DBE subcontractors and suppliers, so as to facilitate DBE participation. Evidence of such negotiation includes the names, addresses, and telephone numbers of DBE companies that were considered; a description of the information provided regarding the plans and specifications for the work selected for subcontracting; and evidence as to why additional agreements could not be reached for DBE companies to perform the work.

b. A bidder using good business judgment would consider a number of factors in negotiating with subcontractors, including DBE subcontractors, and would take a firm's price and capabilities as well as contract goals into consideration. However, the fact that there may be some additional costs involved in finding and using DBE companies is not in itself sufficient reason for a bidder's failure to meet the contract DBE goal, as long as such costs are reasonable. Also the ability or desire of a bidder to perform the work of a contract with its own organization does not relieve the bidder of the responsibility to make good faith efforts. Bidders are not, however, required to accept higher quotes from DBE companies if the price difference is excessive or unreasonable. In accordance with the above Bidding Procedures, the documentation of good faith efforts must include copies of each DBE and non-DBE subcontractor quote submitted to the bidder when a non-DBE subcontractor was selected over a DBE for work on the contract.

(5) Not rejecting DBE companies as being unqualified without sound reasons based on a thorough investigation of their capabilities. The bidder's standing within its industry, membership in specific groups, organizations, or associations and political or social affiliations (for example union vs. non-union employee status) are not legitimate causes for the rejection or non-solicitation of bids in the bidder's efforts to meet the project goal.

- (6) Making efforts to assist interested DBE companies in obtaining bonding, lines of credit, or insurance as required by the recipient or Contractor.
- (7) Making efforts to assist interested DBE companies in obtaining necessary equipment, supplies, materials, or related assistance or services.
- (8) Effectively using the services of available minority/women community organizations; minority/women contractors' groups; local, state, and federal minority/women business assistance offices; and other organizations as allowed on a case-by-case basis to provide assistance in the recruitment and placement of DBE companies.

(b) If the Department determines the bidder has made a good faith effort to secure the work commitment of DBE companies to meet the contract goal, the Department will award the contract provided it is otherwise eligible for award. If the Department determines the bidder has failed to meet the requirements of this Special Provision or that a good faith effort has not been made, the Department will notify the responsible company official designated in the Utilization Plan that the bid is not responsive. The notification will also include a statement of reasons for the adverse determination. If the Utilization Plan is not approved because it is deficient as a technical matter, unless waived by the Department, the bidder will be notified and will be allowed no more than a five calendar day period to cure the deficiency.

(c) The bidder may request administrative reconsideration of an adverse determination by emailing the Department at "DOT.DBE.UP@illinois.gov" within the five calendar days after the receipt of the notification of the determination. The determination shall become final if a request is not made on or before the fifth calendar day. A request may provide additional written documentation or argument concerning the issues raised in the determination statement of reasons, provided the documentation and arguments address efforts made prior to submitting the bid. The request will be reviewed by the Department's Reconsideration Officer. The Reconsideration Officer will extend an opportunity to the bidder to meet in person to consider all issues of documentation and whether the bidder made a good faith effort to meet the goal. After the review by the Reconsideration Officer, the bidder will be sent a written decision within ten working days after receipt of the request for reconsideration, explaining the basis for finding that the bidder did or did not meet the goal or make adequate good faith efforts to do so. A final decision by the Reconsideration Officer that a good faith effort was made shall approve the Utilization Plan submitted by the bidder and shall clear the contract for award. A final decision that a good faith effort was not made shall render the bid not responsive.

CALCULATING DBE PARTICIPATION. The Utilization Plan values represent work anticipated to be performed and paid for upon satisfactory completion. The Department is only able to count toward the achievement of the overall goal and the contract goal the value of payments made for the work actually performed by DBE companies. In addition, a DBE must perform a commercially useful function on the contract to be counted. A commercially useful function is generally performed when the DBE is responsible for the work and is carrying out its responsibilities by actually performing, managing, and supervising the work involved. The Department and Contractor are governed by the provisions of 49 CFR Part 26.55(c) on questions of commercially useful functions as it affects the work. Specific counting guidelines are provided in 49 CFR Part 26.55, the provisions of which govern over the summary contained herein.

(a) DBE as the Contractor: 100 percent goal credit for that portion of the work performed by the DBE's own forces, including the cost of materials and supplies. Work that a DBE subcontracts to a non-DBE does not count toward the DBE goals.

(b) DBE as a joint venture Contractor: 100 percent goal credit for that portion of the total dollar value of the contract equal to the distinct, clearly defined portion of the work performed by the DBE's own forces.

(c) DBE as a subcontractor: 100 percent goal credit for the work of the subcontract performed by the DBE's own forces, including the cost of materials and supplies, excluding the purchase of materials and supplies or the lease of equipment by the DBE subcontractor from the Contractor or its affiliates. Work that a DBE subcontractor in turn subcontracts to a non-DBE does not count toward the DBE goal.

(d) DBE as a trucker: 100 percent goal credit for trucking participation provided the DBE is responsible for the management and supervision of the entire trucking operation for which it is responsible. At least one truck owned, operated, licensed, and insured by the DBE must be used on the contract. Credit will be given for the following:

(1) The DBE may lease trucks from another DBE firm, including an owner-operator who is certified as a DBE. The DBE who leases trucks from another DBE receives credit for the total value of the transportation services the lessee DBE provides on the contract.

(2) The DBE may also lease trucks from a non-DBE firm, including from an owner-operator. The DBE who leases trucks from a non-DBE is entitled to credit only for the fee or commission it receives as a result of the lease arrangement.

(e) DBE as a material supplier:

(1) 60 percent goal credit for the cost of the materials or supplies purchased from a DBE regular dealer.

(2) 100 percent goal credit for the cost of materials or supplies obtained from a DBE manufacturer.

(3) 100 percent credit for the value of reasonable fees and commissions for the procurement of materials and supplies if not a DBE regular dealer or DBE manufacturer.

CONTRACT COMPLIANCE. Compliance with this Special Provision is an essential part of the contract. The Department is prohibited by federal regulations from crediting the participation of a DBE included in the Utilization Plan toward either the contract goal or the Department's overall goal until the amount to be applied toward the goals has been paid to the DBE. The following administrative procedures and remedies govern the compliance by the Contractor with the contractual obligations established by the Utilization Plan. After approval of the Utilization Plan and award of the contract, the Utilization Plan and individual DBE Participation Statements become part of the contract. If the Contractor did not succeed in obtaining enough DBE participation to achieve the advertised contract goal, and the Utilization Plan was approved and contract awarded based upon a determination of good faith, the total dollar value of DBE work calculated in the approved Utilization Plan as a percentage of the awarded contract value shall become the amended contract goal. All work indicated for performance by an approved DBE shall be performed, managed, and supervised by the DBE executing the DBE Participation Commitment Statement.

(a) **NO AMENDMENT.** No amendment to the Utilization Plan may be made without prior written approval from the Department's Bureau of Small Business Enterprises. All requests for amendment to the Utilization Plan shall be emailed to the Department at DOT.DBE.UP@illinois.gov.

(b) CHANGES TO WORK. Any deviation from the DBE condition-of-award or contract plans, specifications, or special provisions must be approved, in writing, by the Department as provided elsewhere in the Contract. The Contractor shall notify affected DBEs in writing of any changes in the scope of work which result in a reduction in the dollar amount condition-of-award to the contract. Where the revision includes work committed to a new DBE subcontractor, not previously involved in the project, then a Request for Approval of Subcontractor, Department form BC 260A or AER 260A, must be signed and submitted. If the commitment of work is in the form of additional tasks assigned to an existing subcontract, a new Request for Approval of Subcontractor will not be required. However, the Contractor must document efforts to assure the existing DBE subcontractor is capable of performing the additional work and has agreed in writing to the change.

(c) SUBCONTRACT. The Contractor must provide copies of DBE subcontracts to the Department upon request. Subcontractors shall ensure that all lower tier subcontracts or agreements with DBEs to supply labor or materials be performed in accordance with this Special Provision.

(d) ALTERNATIVE WORK METHODS. In addition to the above requirements for reductions in the condition of award, additional requirements apply to the two cases of Contractor-initiated work substitution proposals. Where the contract allows alternate work methods which serve to delete or create underruns in condition of award DBE work, and the Contractor selects that alternate method or, where the Contractor proposes a substitute work method or material that serves to diminish or delete work committed to a DBE and replace it with other work, then the Contractor must demonstrate one of the following:

(1) The replacement work will be performed by the same DBE (as long as the DBE is certified in the respective item of work) in a modification of the condition of award; or

(2) The DBE is aware its work will be deleted or will experience underruns and has agreed in writing to the change. If this occurs, the Contractor shall substitute other work of equivalent value to a certified DBE or provide documentation of good faith efforts to do so; or

(3) The DBE is not capable of performing the replacement work or has declined to perform the work at a reasonable competitive price. If this occurs, the Contractor shall substitute other work of equivalent value to a certified DBE or provide documentation of good faith efforts to do so.

(e) TERMINATION AND REPLACEMENT PROCEDURES. The Contractor shall not terminate or replace a DBE listed on the approved Utilization Plan, or perform with other forces work designated for a listed DBE except as provided in this Special Provision. The Contractor shall utilize the specific DBEs listed to perform the work and supply the materials for which each is listed unless the Contractor obtains the Department's written consent as provided in subsection (a) of this part. Unless Department consent is provided for termination of a DBE subcontractor, the Contractor shall not be entitled to any payment for work or material unless it is performed or supplied by the DBE in the Utilization Plan.

As stated above, the Contractor shall not terminate or replace a DBE subcontractor listed in the approved Utilization Plan without prior written consent. This includes, but is not limited to, instances in which the Contractor seeks to perform work originally designated for a DBE subcontractor with its own forces or those of an affiliate, a non-DBE firm, or with another DBE firm. Written consent will be granted only if the Bureau of Small Business Enterprises agrees, for reasons stated in its concurrence document, that the Contractor has good cause to terminate or replace the DBE firm. Before transmitting to the Bureau of Small Business Enterprises any request to terminate and/or substitute a DBE subcontractor, the Contractor shall give notice in writing to the DBE subcontractor, with a copy to the Bureau, of its intent to request to terminate and/or substitute, and the reason for the request. The Contractor shall give the DBE five days to respond to the Contractor's notice. The DBE so notified shall advise the Bureau and the Contractor of the reasons, if any, why it objects to the proposed termination of its subcontract and why the Bureau should not approve the Contractor's action. If required in a particular case as a matter of public necessity, the Bureau may provide a response period shorter than five days.

For purposes of this paragraph, good cause includes the following circumstances:

(1) The listed DBE subcontractor fails or refuses to execute a written contract;

(2) The listed DBE subcontractor fails or refuses to perform the work of its subcontract in a way consistent with normal industry standards. Provided, however, that good cause does not exist if the failure or refusal of the DBE subcontractor to perform its work on the subcontract results from the bad faith or discriminatory action of the Contractor;

(3) The listed DBE subcontractor fails or refuses to meet the Contractor's reasonable, nondiscriminatory bond requirements;

(4) The listed DBE subcontractor becomes bankrupt, insolvent, or exhibits credit unworthiness;

(5) The listed DBE subcontractor is ineligible to work on public works projects because of suspension and debarment proceedings pursuant 2 CFR Parts 180, 215 and 1200 or applicable state law.

(6) The Contractor has determined the listed DBE subcontractor is not a responsible contractor;

(7) The listed DBE subcontractor voluntarily withdraws from the projects and provides written notice to the Contractor of its withdrawal;

(8) The listed DBE is ineligible to receive DBE credit for the type of work required;

(9) A DBE owner dies or becomes disabled with the result that the listed DBE subcontractor is unable to complete its work on the contract;

(10) Other documented good cause that compels the termination of the DBE subcontractor. Provided, that good cause does not exist if the Contractor seeks to terminate a DBE it relied upon to obtain the contract so that the Contractor can self-perform the work for which the DBE contractor was engaged or so that the Contractor can substitute another DBE or non-DBE contractor after contract award.

When a DBE is terminated or fails to complete its work on the Contract for any reason, the Contractor shall make a good faith effort to find another DBE to substitute for the original DBE to perform at least the same amount of work under the contract as the terminated DBE to the extent needed to meet the established Contract goal. The good faith efforts shall be documented by the Contractor. If the Department requests documentation under this provision, the Contractor shall submit the documentation within seven days, which may be extended for an additional seven days if necessary at the request of the Contractor. The Department will provide a written determination to the Contractor stating whether or not good faith efforts have been demonstrated.

(f) **FINAL PAYMENT.** After the performance of the final item of work or delivery of material by a DBE and final payment therefore to the DBE by the Contractor, but not later than 30 calendar days after payment has been made by the Department to the Contractor for such work or material, the Contractor shall submit a DBE Payment Agreement on Department form SBE 2115 to the Resident Engineer. If full and final payment has not been made to the DBE, the DBE Payment Agreement shall indicate whether a disagreement as to the payment required exists between the Contractor and the DBE or if the Contractor believes the work has not been satisfactorily completed. If the Contractor does not have the full amount of work indicated in the Utilization Plan performed by the DBE companies indicated in the Utilization Plan and after good faith efforts are reviewed, the Department may deduct from contract payments to the Contractor the amount of the goal not achieved as liquidated and ascertained damages. The Contractor may request an administrative reconsideration of any amount deducted as damages pursuant to subsection (h) of this part.

(g) **ENFORCEMENT.** The Department reserves the right to withhold payment to the Contractor to enforce the provisions of this Special Provision. Final payment shall not be made on the contract until such time as the Contractor submits sufficient documentation demonstrating achievement of the goal in accordance with this Special Provision or after liquidated damages have been determined and collected.

(h) **RECONSIDERATION.** Notwithstanding any other provision of the contract, including but not limited to Article 109.09 of the Standard Specifications, the Contractor may request administrative reconsideration of a decision to deduct the amount of the goal not achieved as liquidated damages. A request to reconsider shall be delivered to the Contract Compliance Section and shall be handled and considered in the same manner as set forth in paragraph (c) of "Good Faith Effort Procedures" of this Special Provision, except a final decision that a good faith effort was not made during contract performance to achieve the goal agreed to in the Utilization Plan shall be the final administrative decision of the Department. The result of the reconsideration process is not administratively appealable to the U.S. Department of Transportation.

SPECIAL PROVISION FOR WEEKLY DBE TRUCKING REPORTS (BDE)

Effective: June 2, 2012
Revised: November 1, 2021

The Contractor shall submit a weekly report of Disadvantaged Business Enterprise (DBE) trucks hired by the Contractor or subcontractors (i.e. not owned by the Contractor or subcontractors) that are used for DBE goal credit.

The report shall be submitted to the Resident Engineer on Division of Aeronautics Form "AER 723" within ten business days following the reporting period. The reporting period shall be Sunday through Saturday for each week reportable trucking activities occur.

Any costs associated with providing weekly DBE trucking reports shall be considered as included in the contract unit prices bid for the various items of work involved and no additional compensation will be allowed.

SPECIAL PROVISION FOR SUBCONTRACTOR MOBILIZATION PAYMENTS

Effective: November 2, 2017
Revised: April 1, 2019

To account for the preparatory work and the operations necessary for the movement of subcontractor personnel, equipment, supplies, and incidentals to the project site and for all other work or operations that must be performed or costs incurred when beginning work approved for subcontracting according to Section 80-01 of the Standard Specifications, the Contractor shall make a mobilization payment to each subcontractor.

This mobilization payment shall be made at least seven days prior to the subcontractor starting work. The amount paid shall be at the following percentage of the amount of the subcontract reported on form AER 260A submitted for the approval of the subcontractor's work.

Value of Subcontract Reported on Form AER 260A	Mobilization Percentage
Less than \$10,000	25%
\$10,000 to less than \$20,000	20%
\$20,000 to less than \$40,000	18%
\$40,000 to less than \$60,000	16%
\$60,000 to less than \$80,000	14%
\$80,000 to less than \$100,000	12%
\$100,000 to less than \$250,000	10%
\$250,000 to less than \$500,000	9%
\$500,000 to \$750,000	8%
Over \$750,000	7%

The mobilization payment to the subcontractor is an advance payment of the reported amount of the subcontract and is not a payment in addition to the amount of the subcontract; therefore, the amount of the advance payment will be deducted from future progress payments.

This provision shall be incorporated directly or by reference into each subcontract approved by the Department.

SPECIAL PROVISION FOR PAYMENTS TO SUBCONTRACTORS

Effective: November 2, 2017

Federal regulations found at 49 CFR §26.29 mandate the Department to establish a contract clause to require Contractors to pay subcontractors for satisfactory performance of their subcontracts and to set the time for such payments.

State law also addresses the timing of payments to be made to subcontractors and material suppliers. Section 7 of the Prompt Payment Act, 30 ILCS 540/7, requires that when a Contractor receives any payment from the Department, the Contractor shall make corresponding, proportional payments to each subcontractor and material supplier performing work or supplying material within 15 calendar days after receipt of the Department payment. Section 7 of the Act further provides that interest in the amount of two percent per month, in addition to the payment due, shall be paid to any subcontractor or material supplier by the Contractor if the payment required by the Act is withheld or delayed without reasonable cause. The Act also

provides that the time for payment required and the calculation of any interest due applies to transactions between subcontractors and lower-tier subcontractors and material suppliers throughout the contracting chain.

This Special Provision establishes the required federal contract clause, and adopts the 15 calendar day requirement of the State Prompt Payment Act for purposes of compliance with the federal regulation regarding payments to subcontractors. This contract is subject to the following payment obligations.

When progress payments are made to the Contractor according to Article 90-07 of the Standard Specifications, the Contractor shall make a corresponding payment to each subcontractor and material supplier in proportion to the work satisfactorily completed by each subcontractor and for the material supplied to perform any work of the contract. The proportionate amount of partial payment due to each subcontractor and material supplier throughout the contracting chain shall be determined by the quantities measured or otherwise determined as eligible for payment by the Department and included in the progress payment to the Contractor. Subcontractors and material suppliers shall be paid by the Contractor within 15 calendar days after the receipt of payment from the Department. The Contractor shall not hold retainage from the subcontractors. These obligations shall also apply to any payments made by subcontractors and material suppliers to their subcontractors and material suppliers; and to all payments made to lower tier subcontractors and material suppliers throughout the contracting chain. Any payment or portion of a payment subject to this provision may only be withheld from the subcontractor or material supplier to whom it is due for reasonable cause. If reasonable cause is asserted, written notice shall be provided to the applicable subcontractor and/or material supplier and the Engineer within five days of the Contractor receiving payment. The written notice shall identify the contract number, the subcontract or material purchase agreement, a detailed reason for refusal, the value of payment being withheld, and the specific remedial actions required of the subcontractor and/or material supplier so that payment can be made.

This Special Provision does not create any rights in favor of any subcontractor or material supplier against the State or authorize any cause of action against the State on account of any payment, nonpayment, delayed payment, or interest claimed by application of the State Prompt Payment Act. The Department will not approve any delay or postponement of the 15 day requirement except for reasonable cause shown after notice and hearing pursuant to Section 7(b) of the State Prompt Payment Act. State law creates other and additional remedies available to any subcontractor or material supplier, regardless of tier, who has not been paid for work properly performed or material furnished. These remedies are a lien against public funds set forth in Section 23(c) of the Mechanics Lien Act, 770 ILCS 60/23(c), and a recovery on the Contractor's payment bond according to the Public Construction Bond Act, 30 ILCS 550.

SPECIAL PROVISION FOR SUBCONTRACTOR AND DBE PAYMENT REPORTING (BDE)

Effective: April 2, 2018

Subcontractor and Disadvantaged Business Enterprise Payment Reporting

The Contractor shall report all payments made to the following parties:

- (a) first tier subcontractors;
- (b) lower tier subcontractors affecting disadvantaged business enterprise (DBE) goal credit;
- (c) material suppliers or trucking firms that are part of the Contractor's submitted DBE utilization plan.

The report shall be made through the Department's on-line subcontractor payment reporting system within 21 days of making the payment.

SPECIAL PROVISION FOR NPDES CERTIFICATION

In accordance with the provisions of the Illinois Environmental Protection Act, the Illinois Pollution Control Board Rules and Regulations (35 Ill. Adm. Code, Subtitle C, Chapter I), and the Clean Water Act, and the regulations thereunder, this certification is required for all construction contracts that will result in the disturbance of one or more acres total land area.

The bidder certifies under penalty of law that he/she understands the terms and conditions of the general National Pollutant Discharge Elimination System (NPDES) permit (ILR100000) that authorizes the storm water discharges associated with industrial activity from the construction site identified as part of this certification.

The Airport Owner or its Agent will:

- 1) prepare, sign and submit the Notice of Intent (NOI)
- 2) conduct site inspections and complete and file the inspection reports
- 3) submit Incidence of Non-Compliance (ION) forms
- 4) submit Notice of Termination (NOT) form

Prior to the issuance of the Notice-to-Proceed, for each erosion control measure identified in the Storm Water Pollution Prevention Plan, the contractor or subcontractor responsible for the control measure(s) must sign the above certification (forms to be provided by the Department).

ILLINOIS WORKS APPRENTICESHIP INITIATIVE – STATE FUNDED CONTRACTS (BDE)

Effective: June 2, 2021

Revised: September 2, 2021

Illinois Works Jobs Program Act (30 ILCS 559/20-1 et seq.). For contracts having an awarded contract value of \$500,000 or more, the Contractor shall comply with the Illinois Works Apprenticeship Initiative (30 ILCS 559/20-20 to 20-25) and all applicable administrative rules. The goal of the Illinois Apprenticeship Works Initiative is that apprentices will perform either 10% of the total labor hours actually worked in each prevailing wage classification or 10% of the estimated labor hours in each prevailing wage classification, whichever is less. The Contractor may seek from the Department of

Commerce and Economic Opportunity (DCEO) a waiver or reduction of this goal in certain circumstances pursuant to 30 ILCS 559/20-20(b). The Contractor shall ensure compliance during the term of the contract and will be required to report on and certify its compliance. An apprentice use plan, apprentice hours, and a compliance certification shall be submitted to the Engineer on forms provided by the Department and/or DCEO.

REVISIONS TO THE ILLINOIS PREVAILING WAGE RATES

The Prevailing rates of wages are included in this Contract proposal. The rates have been ascertained and certified by the Illinois Department of Labor for the locality in which the work is to be performed and for each craft or type of work or mechanic needed to execute the work of the Contract. As required by Prevailing Wage Act ([820 ILCS](#) 130/0.01, et seq.) and this Proposal, not less than the rates of wages ascertained by the Illinois Department of Labor and as revised during the performance of a Contract shall be paid to all laborers, workers and mechanics performing work under the Contract. Post the scale of wages in a prominent and easily accessible place at the site of work.

If the Illinois Department of Labor revises the prevailing rates of wages to be paid as listed in the specification of rates, the contractor shall post the revised rates of wages and shall pay not less than the revised rates of wages. Current wage rate information shall be obtained by visiting the Illinois Department of Labor web site at <https://www2.illinois.gov/idol/Laws-Rules/CONMED/Pages/Rates.aspx> or by calling 312-793-2814. It is the responsibility of the contractor to review the rates applicable to the work of the contract at regular intervals in order to insure the timely payment of current rates. Provision of this information to the contractor by means of the Illinois Department of Labor web site satisfies the notification of revisions by the Department to the contractor pursuant to the Act, and the contractor agrees that no additional notice is required. The contractor shall notify each of its subcontractors of the revised rates of wages.

SECTION III

Edgar County Airport Paris, Illinois

Replace Runway 9/27 Pulse Light Approach Slope Indicators (PLASI's) with Precision Approach Path Indicators (PAPI's)

Illinois Project No.: PRG-4981

Prepared by



1/12/2024
Expires: 11/30/25



Engineering | Planning | Allied Services

Hanson Professional Services Inc.
1525 S. Sixth St.
Springfield, IL 62703



Kevin N. Lightfoot

1/10/2024
EXPIRES: 11/30/2025
COVERING
ELECTRICAL DESIGN

Issued: January 12, 2024 IDOT Letting: March 8, 2024

INDEX

Item No.	Description	Page No.
	Foreword	2
DIVISION I –GENERAL PROVISIONS		
50	Control of Work	3
70	Legal Regulations and Responsibility to the Public	4
80	Prosecution and Progress.....	7
DIVISION II – PAVING CONSTRUCTION DETAILS		
150520	Mobilization	8
DIVISION VI – LIGHTING INSTALLATION		
108	Installation of Underground Cable for Airports	9
110	Installation of Airport Underground Electrical Duct.....	19
125	Installation of Airport Lighting Systems	26
125620	Abbreviated PAPI (L-881 System)	37
125910	Remove PLASI	49

APPENDIX A – Constant Current Regulator and Cable Testing Forms

APPENDIX B – PAPI Ground Check List

Refer to IDOT Division of Aeronautics Policy Memorandums (as applicable):

96-1, "Item 610, Structural Portland Cement Concrete: Job Mix Formula Approval & Production Testing.

FOREWORD

These Special Provisions, together with applicable Standard Specifications, Rules and Regulations, Contract Requirements for Airport Improvement Projects, Payroll Requirements and Minimum Wage Rates, which are hereto attached or which by reference are herein incorporated, cover the requirements of the State of Illinois, Department of Transportation (IDOT), Division of Aeronautics (IDA) for the following improvement project at the **Edgar County Airport, Paris, Illinois**, including the following:

SCOPE OF WORK

This project will include removal and replacement of the existing Pulse Light Approach Slope Indicators (PLASI's) on Runway 9-27 with Precision Approach Path Indicators (PAPI's) with the associated cabling, duct work and vault work.

GOVERNING SPECIFICATIONS AND RULES AND REGULATIONS

The State of Illinois Department of Transportation, Division of Aeronautics, Standard Specifications for Construction of Airports, **adopted April 1, 2012**, shall govern the project, except as otherwise revised or noted in these Special Provisions. All references to IDOT Specifications refer to Standard Specifications for Road and Bridge Construction, Illinois Department of Transportation, adopted April 1, 2016, as revised. In the event of inconsistencies between the Standard Specifications and the Special Provisions, the Special Provisions shall govern. The Contractor shall maintain a minimum of one printed copy of the relevant sections of the Standard Specifications for Construction of Airports on the project site at all times. The Standard Specifications for Construction of Airports is available on line at the following address link:

<https://idot.illinois.gov/doing-business/procurements/engineering-architectural-professional-services/consultant-resources/standard-specifications.html>

REFERENCES

The following Federal Aviation Administration Advisory Circulars are referenced on the Plans and/or Special Provision Specifications in regard to safety on airports. These Advisory Circulars are available on the FAA web site at http://www.faa.gov/regulations_policies/advisory_circulars

- A. FAA AC No. 70/7460-1L (or most current issue) "Obstruction Marking and Lighting."
- B. FAA AC No. 150/5210-5D (or most current issue) "Painting, Marking, and Lighting of Vehicles Used on an Airport."
- C. FAA AC No. 150/5300-13B "AIRPORT DESIGN."
- D. FAA AC No. 150/5370-2G (or most current issue) "Operational Safety on Airports During Construction."

DIVISION I – GENERAL PROVISIONS

SECTION 50. CONTROL OF WORK

50-06 CONSTRUCTION LAYOUT STAKES

Revise the first paragraph to read:

“The Contractor shall be responsible for all construction layout and any extension of the control network provided in the plans necessary to properly complete the work.”

Under the heading RESPONSIBILITY OF THE RESIDENT ENGINEER, delete paragraphs A, B, and C.

50-16 FINAL INSPECTION

Revise the first sentence of the first paragraph to read:

“Upon due notice to the Resident Engineer/Technician by the Contractor of presumptive completion of the entire project, the charging of Contract Time shall be suspended and the Engineer will make an inspection.”

Add after the first sentence of the second paragraph:

“The charging of Contract Time shall resume upon receipt of the punch list from the Engineer and continue until the remaining work, including work as required in Section 40-08 Final Clean Up, is completed to the satisfaction of the Engineer.”

END OF SECTION 50

SECTION 70. LEGAL REGULATIONS AND RESPONSIBILITY TO PUBLIC

70-10 BARRICADES, WARNING SIGNS, AND HAZARD MARKINGS. Add the following paragraphs to this section:

"The Edgar County Airport has two paved runways, This project will require the temporary closure of Runway 18/36 and Runway 9/27. The project will also require the temporary closure of taxiways. Refer to the Construction Safety Plan Sheets for additional information regarding the temporary closures during construction.

A runway will be closed any time the Contractor is working within the existing runway obstacle free zone (125 feet from the runway centerline) as depicted on the Proposed Safety Plan. Runway closures shall be completed in accordance with the details shown in the Construction Plans. Prior to opening the Runway a Representative of the Airport, the Contractor, and the Resident Engineer/Technician will inspect the runway to be sure the pavement is clean, all holes and trenches have been backfilled, and all equipment and materials are at least 250 feet from the Runway centerline. Any deficiencies noticed will be corrected before the Contractor will be allowed to re-open the runway.

The Contractor shall coordinate with the Airport and the Resident Engineer/Technician to turn off the runway and taxiway lighting circuits as well as the Nav aids. When the runway is re-opened these circuits must be re-activated. All existing lighting and Nav aids associated with the respective runway that is closed, will be inactive during runway closures.

Except where shown otherwise on the plans, work within 58 feet of an active taxi-lane centerline shall require closure of that taxi-lane using barricades in accordance with the Construction Safety and Phasing Plan.

Except where shown otherwise on the plans, work within 66 feet of an active taxiway centerline shall require closure of that taxiway using barricades in accordance with the Construction Safety and Phasing Plan.

All work included in opening and closing the runways, taxiways, and taxi-lanes will be considered incidental to the Project and no additional compensation will be allowed.

The Airport Manager shall be notified a minimum of **72 hours** in advance of any work that would require the closure of the runway, and a minimum of **48 hours** notice before the closure of any taxiway. It will be the responsibility of the Contractor to properly mark the closed runway, and when the runway is re-opened, to remove the marking. The appropriate marking for a closed runway is a cross at both ends of the runway. When a taxiway is to be closed for more than 72 hours, if that taxiway exits from an open runway, a taxiway closure cross shall be placed on the taxiway as shown on the plans.

The legs of the runway cross will be 60 ft in length and 10 ft in width, while the legs of the taxiway cross will be 30 ft in length and 5 ft in width. The crosses will be constructed of any suitable, locally available materials, such as fabric, plywood, or other similar material. They will be held in place in a manner locally determined to be suitable. The Contractor will be responsible for placing and removing the crosses as the runways are closed and opened. The Contractor will provide the Engineer with a proposed schedule of when and length of time for all closures. The Project Engineer must review and approve this schedule before any construction

begins. The placement, maintenance and removal of the crosses will be considered as an incidental item to the contract and no additional compensation will be allowed.

Extreme care will be taken not to impose on the operations of any open runway or taxiway. The proposed Safety and Phasing Plan Sheets, as outlined on the Construction Plans and in the Special Provisions, will maximize safety and attempt to minimize disruption to Airport daily operations.

When the Contractor's vehicles are on Airport property, they shall be properly marked. The markings shall consist of a 3-ft sq. flag consisting of a checkered pattern of international orange and white squares of not less than 1 ft on each side displayed in full view above the vehicle. Contractor vehicles engaged in continuous hauling operations will not be required to display a flag.

The Contractor will be responsible for placing barricades and/or traffic cones at the locations shown on the Construction Plans, or as directed by the Airport Manager. It will be the Contractor's responsibility to furnish and maintain the barricades equipped with red flashing or red, steady-burn lights and 20-in. sq. orange flags throughout the duration of this project.

The barricades and their maintenance will be considered as an incidental item to the contract, and no additional compensation will be allowed. Any cost of labor and equipment, which is necessary to insure safety at the Airport during the duration of the project, will be considered incidental to the contract, and no additional reimbursement for these items of work will be received.

All runway closures will be coordinated with the Airport Manager. The runway will be closed in accordance with the procedures set forth on the Proposed Safety and Phasing Plan Sheets. Prior to re-opening the runway the Contractor will insure the following:

1. All holes/trenches have been backfilled.
2. All equipment has been moved outside the Runway Safety Area.
3. All trucks have their beds lowered and all cranes have their booms lowered.
4. There is no material stockpiled within the Runway Object Free Area.
5. All active pavements have been swept of foreign material.
6. All lighting circuits associated with the pavement being re-opened are active and functioning correctly.
7. Representatives of the Contractor, Airport Manager and Resident Engineer/Technician shall inspect the pavement prior to re-opening. Anything noted will be corrected prior to re-opening."

Add the following:

70-27 AIRPORT SECURITY NOTES. Airport security will be maintained at all times. The Contractor will monitor the site access to the proposed job site to insure no one will enter the access gate that is not authorized to be on the construction site or on the air side of the airport.

70-28 MAINTAINING OPERATION OF AIRFIELD LIGHTING AND NAVAIDS. Shut down of airfield lighting and/or Navaids shall only be permitted during day light hours and must be coordinated with and approved by the Airport Manager. All airfield lighting and Navaid circuits shall be operational at night fall. The Contractor shall not leave the runway lighting, taxiway lighting, or any other airfield lighting circuit inoperable overnight. The Contractor shall provide temporary cable connections (in unit duct) and any manual operations of airfield lighting to keep them in operation overnight. The Contractor shall secure, identify, and place temporary exposed wiring in conduit, duct, or unit duct to prevent electrocution and fire ignition sources in conformance with the requirements of FAA AC 150/5370-2 (current issue in effect) "OPERATIONAL SAFETY ON AIRPORTS DURING CONSTRUCTION".

70-29 SITE INSPECTION. The Contractor shall be responsible for an on-site inspection prior to submitting a bid on this project. Upon receipt of a bid, it shall be assumed that the Contractor is fully familiar with the construction site.

70-30 SAFETY PLAN COMPLIANCE DOCUMENT. Prior to the issuance of a construction Notice-to-Proceed (NTP), the Contractor shall be responsible for preparing and submitting a Safety Plan Compliance Document in accordance with FAA Advisory Circular 150/5370-2G, paragraph 2.4.2, or equivalent section in subsequent/current issue. The Airport Director shall approve this document and submit to the Division of Aeronautics for approval prior to the NTP issuance.

END OF SECTION 70

SECTION 80. PROSECUTION AND PROGRESS

80-02 PROGRESS SCHEDULE. Add the following to this section:

“In the event that other construction projects are in progress at the Airport at the same time as this project, the Contractor will be required to cooperate with all other Contractors and the Airport Manager in the coordination of the work.”

80-13 CONTRACTOR’S ACCESS TO AIRFIELD. Add the following to this section:

The Contractor's personnel and equipment shall not traverse outside the designated work areas to other locations on the Airport. The designated haul route will be the only vehicular access to the construction site. It will be the responsibility of the Contractor to maintain the proposed haul route and equipment parking area for the duration of the project.

The Contractor shall access the proposed work site using the haul route as detailed on the Plans. The Contractor will be expected to maintain this access throughout this project. At the end of the project the Contractor will return the haul route and equipment parking area to its original condition, unless otherwise noted on the Plans. An equipment parking area will be located in close proximity to the haul route.

The Contractor will be responsible for obtaining any permits necessary to use the State/County/Township/City roads. All work required in complying with the above requirement will be considered incidental to the Contract, and no additional compensation will be allowed.

Failure to use the prescribed haul routes and equipment parking area or adhere to the safety requirements will result in the suspension of work.

The Contractor is required to be in 2-way radio contact with the Airport UNICOM Channel (123.00 MHz) any time his construction activities are on the Airport property. This will keep the Contractor in constant contact with the Edgar County Airport personnel and provide immediate communication in the event of an aeronautical emergency.

Add the following:

80-14 EMPLOYEE PARKING. The Contractor’s employees shall park their personal vehicles in the designated Equipment Parking Area as shown on the Proposed Safety and Phasing Plan Sheets. The Contractor will transport the workers from the parking area to the work area. Only Contractor vehicles needed for construction will be allowed outside of the proposed equipment parking area. No employee vehicle will be allowed onto the proposed construction site.

80-15 EQUIPMENT PARKING AND MATERIAL STORAGE. The Contractor will be allowed to park equipment and store material in the Proposed Equipment Parking Area shown on the Safety and Phasing Plan Sheets. The Contractor will maintain this area throughout the duration of the project and restore it to its original condition upon completion of the project. This work will be considered incidental to the Contract and no additional compensation will be allowed.

END OF SECTION 80

DIVISION II PAVING CONSTRUCTION DETAILS

ITEM 150520 MOBILIZATION

BASIS OF PAYMENT

150-3.1 Revise this section to read as follows:

“Mobilization shall be limited to 10% of the original contract amount. Should the bid for mobilization exceed 10%, the amount over 10% will not be paid until final acceptance of the project by the Engineer.

Based upon the contract lump sum price for “Mobilization” partial payments will be allowed as follows:

- a. With first pay request, 25%.
- b. When 25% or more of the original contract is earned, an additional 25%.
- c. When 50% or more of the original contract is earned, an additional 40%.
- d. The remaining 10% of the pay item will be paid along with any amount bid in excess of 10% of the original contract amount upon final acceptance of the project by the Engineer.

Nothing herein shall be construed to limit or preclude partial payment for other items as provided for by the contract.

Payment will be made under:

Item AR150520 Mobilization - per lump sum.”

END OF ITEM 150520

DIVISION VI – LIGHTING INSTALLATION

ITEM 108 INSTALLATION OF UNDERGROUND CABLE FOR AIRPORTS

DESCRIPTION

108-1.1. Add the following to this section:

“This Item of work shall consist of the installation (plowing, trenching, directional-boring, or installing in ducts or raceways) of cable for airfield lighting circuits and/or Navaid circuits on the runways, taxiways, aprons, and the associated homeruns at the locations shown on the Plans and in accordance with these Specifications. This Item shall include cable in unit duct where noted on the Plans and specified herein.

In areas where there is congestion of buried cable or where the proposed cable crosses an existing cable, the Contractor will be required to trench the proposed cable into place. In all other areas, the Contractor has the option to either trench or plow the proposed cable in unit duct into place.

When crossing existing circuits, the Contractor will be required to hand dig the trenches for the proposed cable.

Furnishing and installing lockout/tagout kits and following lockout/tagout procedures for safety of personnel.”

Add the following:

108-1.2 REFERENCES. Note: where FAA Advisory Circulars are referenced they shall be the current issue or issues in effect.

- A. ASTM Specification B3 – Standard Specification for Soft or Annealed Copper Wire.
- B. ASTM Specification B8 – Standard Specification for Concentric-Lay-Stranded Copper Conductors, Hard, Medium-Hard, or Soft.
- C. FAA Advisory Circular 150/5340-30 (current issue in effect) DESIGN AND INSTALLATION DETAILS FOR AIRPORT VISUAL AIDS
- D. FAA Advisory Circular 150/5345-7 (current issue in effect) "SPECIFICATIONS FOR L-824 UNDERGROUND ELECTRICAL CABLE FOR AIRPORT LIGHTING CIRCUITS.
- E. FAA Advisory Circular 150/5345-26 (current issue in effect) “FAA SPECIFICATIONS FOR L-823 PLUG AND RECEPTACLE CABLE CONNECTORS”.
- F. FAA AC No. 150/5345-53 “AIRPORT LIGHTING EQUIPMENT CERTIFICATION PROGRAM” (current issue in effect) and AC 150/5345-53D, AIRPORT LIGHTING EQUIPMENT CERTIFICATION PROGRAM Appendix 3 Addendum (current issue in effect).
- G. FAA AC No. 150/5370-2 (current issue in effect) “OPERATIONAL SAFETY ON AIRPORTS DURING CONSTRUCTION.

- H. Federal Specification A-A-59544 Cable and Wire, Electrical (Power, Fixed Installation).
- I. NFPA 70 – National Electrical Code (most current issue in force).
- J. NFPA 70E – Standard for Electrical Safety in the Workplace.
- K. NFPA 2638645-1 = National Fire Protection Association IDN.
- L. OSHA 29 CFR Part 1910 Occupational Safety and Health Standards for electrical safety and lockout/tagout procedures.
- M. UL Standard 44 – Thermoset-Insulated Wires and Cables.
- N. UL Standard 83 – Thermoplastic-Insulated Wires and Cables.
- O. UL Standard 854 – Service Entrance Cables.

108-1.3 SHOP DRAWINGS. The Contractor shall furnish shop drawings for approval before ordering equipment and/or materials. Shop drawings are required for each wire, conductor, and/or cable type to be used on the project. **Shop drawings shall be clear and legible. Copies that are illegible will be rejected.** Shop drawings shall include the following information:

- A. In order to expedite the shop drawing review, inspection and/or testing of materials, the Contractor shall furnish complete statements to the Project Engineer of Record as to the origin, composition, and manufacturer of all material to be used in the work. Such statements shall be furnished promptly after execution of the contract but, in all cases, prior to delivery of such materials.
- B. Provide certification that steel products are manufactured in the USA from domestic steel to comply with the Steel Products Procurement Act (30 ILCS 565).
- C. Indicate the pay item number for each respective cable and/or cable in unit duct.
- D. Shop drawings shall include wire/conductor/cable cut sheets with type, size, specifications, Intertek Testing Services verification/ETL listing or UL listing, manufacturer, and catalog or part number.
- E. Shop drawings for cable in unit duct items shall include cut sheets with type, size, specifications, Intertek Testing Services verification/ETL listing or UL listing, manufacturer, and catalog or part number for the respective unit duct.
- F. Where cable is required to have colored coded insulation, provide information on the color coding for the respective conductors.

EQUIPMENT AND MATERIALS

108-2.1 GENERAL. Add the following:

"All cable shall be FAA approved or UL-listed as suitable for installed application. Cable furnished on this project shall comply with the requirements of the "Airport Improvement Program Buy American Preference requirements. All conductors shall be Copper."

Lockout/Tagout Kit. Provide a Lockout Station suitable for wall mounting, with 5 lockout padlocks each with a different key, 5 lockout hasps to accommodate multiple padlocks, and 50 lockout tags. Lockout station and components shall comply with OSHA Standard 1910.147. Include hardware to mount on the vault interior wall.

108-2.2 CABLE. Revise this section to read as follows:

“L-824 Cable – L-824 cable shall be FAA L-824, Type C and shall conform to the requirements of FAA Advisory Circular 150/5345-7 (current edition in effect) "SPECIFICATIONS FOR L-824 UNDERGROUND ELECTRICAL CABLE FOR AIRPORT LIGHTING CIRCUITS". L-824 cable shall be FAA approved and listed in the current AC 150/5345-53D, AIRPORT LIGHTING EQUIPMENT CERTIFICATION PROGRAM Appendix 3 Addendum. Circuits for use with constant current regulator outputs (runway or taxiway lighting circuits) shall use 5000-Volt rated cable. Circuits for use with low voltage applications (600 Volts or below) shall use either 5000-Volt rated cable or 600-Volt rated cable and shall have colored insulation corresponding to the respective voltage system. Cable shall be manufactured in the United States of America to comply with the Airport Improvement Program Buy American Requirement or be on the Federal Aviation Administration list of Nationwide Buy American Waivers.

Cable for use with airfield lighting series circuits (including runway lighting, taxiway lighting and taxi guidance signs) shall be one conductor No. 8, 5,000-Volt, FAA L-824, Type C, stranded.

XLP-USE Wire. Cable shall comply with UL Standard 44, UL Standard 854, and Federal Specification A-A-59544. The conductor shall be concentric-strand, soft Copper, conforming to ASTM B8 and Underwriters' Laboratories Standard UL44 for Rubber Insulated Wires. Insulation shall be rated for 600-Volt. Insulation shall be cross-linked polyethylene conforming to Underwriters Laboratories Requirements for Type USE-2 insulation. Cable shall be UL-listed and marked USE-2. Cable shall be manufactured in the United States of America to comply with the Airport Improvement Program Buy American Requirement.

Item AR108088/AS108088, 1/C #8 XLP-USE shall consist of 1/C #8 AWG, XLP-USE, 600 Volt cable or 1/C #8 AWG, FAA L-824, Type C, 5,000 Volt or 600 Volt cable. Conductor insulation for 240 VAC, 1 phase, 2-wire with ground circuits shall be color-coded: Phase A – Black, Phase B – Red, and Ground – Green.

Item AR108658/AS108658, 3/C #8 600 V UG Cable in UD shall consist of 3-1/C #8 AWG, XLP-USE, 600 Volt cables in unit duct (1-inch or sized larger as required per NEC) or 3-1/C #8 AWG, FAA L-824, Type C, 5,000 Volt or 600 Volt cables in unit duct (1-inch or sized larger as required per NEC). Conductor insulation for 240 VAC, 1 phase, 2-wire with ground circuits shall be color-coded: Phase A – Black, Phase B – Red, and Ground – Green.

Color-coding: Color-code phase and neutral conductor insulation for No. 6 AWG or smaller. Provide colored marking tape or colored insulation for phase and neutral conductors for No. 4 AWG and larger. Insulated ground conductors shall have green

colored insulation for all conductor sizes (AWG and/or KCMIL) to comply with NEC 250.119. Neutral conductors shall have white colored insulation for No. 6 AWG and smaller to meet the requirements of NEC 200.6. Standard colors for power wiring and branch circuits for 120/240 VAC, 1-Phase, 3-Wire system shall be Phase A – Black, Phase B – Red, Neutral – White, and Ground – Green.”

108-2.4 CABLE CONNECTIONS. Add the following to this section:

“The Contractor will use a cable stripper/penciller whenever cable connections are made.

All breaks in the unit duct shall be sealed by shrink kits.

All below grade splices shall be installed in splice cans, handholes, or manholes. Splice cans shall be L-867, Class IA, Size B (12 in. diameter), 24 in. deep, with ½ in. thick, galvanized steel cover and stainless-steel bolts. Larger-sized splice cans shall be provided, as applicable, for specific equipment applications or manufacturer’s recommendations, and/or where detailed on the Plans. Splice cans located in areas subject to heavy aircraft or vehicle loading shall be L-868 type. The Engineer shall approve all splice locations before work commences. The furnishing and installing of splice cans for new homerun cables shall be incidental to the respective cable pay item, and no additional compensation will be allowed.”

108-2.5 RESERVED. Revise 108-2.5 as follows to comply with the requirements of FAA Advisory Circular Number 150/5370-10G Standards for Specifying Construction of Airports, Item L-108 Underground Power Cable for Airports:

“**108-2.5 SPLICER QUALIFICATIONS.** Every airfield lighting cable splicer shall be qualified in making cable splices and terminations on cables rated at and/or above 5000 Volts AC. The Contractor shall submit to the Project Engineer of Record proof of the qualifications of each proposed cable splicer for the cable type and voltage level to be worked on. Cable splicing/terminating personnel shall have a minimum of three (3) years continuous experience in terminating/splicing medium voltage cable.”

108-2.13 UNIT DUCT. Add the following:

“Standard sizes of smooth wall polyethylene duct shall conform to the dimensional requirements specified below:

Nominal Duct Size	Nominal Inside Diameter	Nominal Standard Wall	Nominal Outside Diameter*
¾”	0.910”	0.070”	1.050”
1”	1.145”	0.085”	1.315”
1-1/4”	1.440”	0.110”	1.660”
1-1/2”	1.650”	0.125”	1.900”
2”	2.065”	0.155”	2.375”
2-1/2”	2.449”	0.213”	2.875”
3”	3.048”	0.226”	3.500”
4”	4.000”	0.250”	4.500”

* Dimensions include allowance for duct eccentricity.”

CONSTRUCTION METHODS

108-3.1 GENERAL. Add the following to this section:

“Keep all work, power outages, and/or shut down of existing systems coordinated with the Airport Manager and the Resident Engineer/Resident Technician. Any shutdown of existing systems shall be scheduled with and approved by the Airport Manager prior to shutdown. Once shut down, the circuits shall be labeled as such to prevent accidental energizing of the respective circuits. All personnel shall follow U.S. Department of Labor Occupational Safety & Health Administration (OSHA) 29 CFR Part 1910 Occupational Safety and Health Standards for electrical safety and lockout/tagout procedures including, but not limited to, 29 CFR section 1910.147 The Control of Hazardous Energy (lockout/tagout).

Examine the site to determine the extent of the work. Contractor shall field verify existing site conditions.

Verify respective circuits and power sources prior to removing, disconnecting, relocating, installing, connecting, or working on the respective airfield lighting, taxi sign, NAVAID, or other device. Identify each respective circuit prior to performing work on that circuit.

If the Contractor wishes to lay cable on a line other than that shown on the Plans, he shall obtain approval of the Project Engineer of Record of record before doing so and coordinate with the Resident Engineer/Technician. Any additional cable needed because of such change will be at the Contractor's expense.

New airfield lighting series circuit cables shall be installed a minimum of 18 inches below grade to comply with NEC 300.5 Underground Installations. Deeper depths might be required to avoid obstructions or where detailed herein.

Locate and identify all existing underground utilities located within the area where the proposed cables are being installed, and will take all precautions to protect these utilities from damage. Care shall be taken so as not to damage any existing circuits. Any existing circuits damaged shall be immediately repaired to the satisfaction of the Engineer and/or the respective utility or owner where applicable. Any underground utility damaged will be repaired or replaced at the Contractor's own expense. Any repairs of existing cables will be considered incidental to the contract, and no additional compensation will be allowed.

In areas where there is a congestion of buried cables or where the proposed cable crosses an existing cable, the Contractor will be required to hand dig and/or carefully excavate the trench necessary for the proposed cable. At other locations the proposed cable may be trenched or plowed into place. Hand digging, trenching, and/or plowing will be considered incidental to the proposed cables and no additional compensation will be allowed.

Grounding work and modifications shall not be performed during a thunderstorm or when a thunderstorm is predicted in the area. Grounding for airfield lights and taxi signs shall be as detailed on the Plans and as specified herein.

Homerun cables for a respective circuit that are installed in conduit or duct shall be run together in the same raceway or duct.

The respective personnel performing airfield lighting work, vault work, and/or test shall be familiar with, and qualified to work on 5000-volt airfield lighting series circuits, constant current regulators and associated airport electrical vault equipment.

FAA requires that every airfield lighting cable splicer shall be qualified in making cable splices and terminations on cables rated at and/or above 5000 Volts AC and shall have a minimum of three (3) years continuous experience in terminating/splicing medium voltage cable.

Only cable in unit duct may be plowed or directional-bored.

Obey and comply with the applicable requirements of NFPA 70E – Standard for Electrical Safety in the Workplace.

The Contractor shall comply with the requirements of FAA AC No. 150/5370-2 (current issue in effect) “OPERATIONAL SAFETY ON AIRPORTS DURING CONSTRUCTION”.

In the event a conflict is determined with respect to manufacturer installation instructions, National Electrical Code, and/or the Contract Documents, contact the Project Engineer of Record for further directions.

Secure, identify and place any above ground temporary wiring in conduit to prevent electrocution and fire ignition sources in conformance with the requirements of FAA AC 150/5370-2G, Part 2.18.3 “Lighting and Visual NAVAIDs”. All temporary installations shall comply with National Electrical Code Article 590 – “Temporary Installations.”

Existing ducts and cables associated with removal work shall be abandoned in place unless it conflicts with the installation of the airfield light, sign, duct, cable, handhole, manhole, site work, pavement or other work, then it shall be disconnected, removed, and disposed of off the site at no additional cost to the Contract. Contractor may remove abandoned cables at no additional cost to the Contract and shall have the salvage rights to abandoned cables.

Other construction projects might be in progress on the Airport at the same time as this project. The Contractor will be required to cooperate with all other contractors and the Airport Manager in the coordination of the work.

Relocation of existing cables and/or cable in unit duct will require careful excavation of the cables to prevent damage to them. The cables and/or cable in unit duct shall be excavated and exposed and then relocated to a different depth and/or route to accommodate the respective site work.

The cable quantities as shown on the Construction plans are based on straight-line measurement. All other cable lengths, such as slack or waste, will not be measured for payment.

All cables installed by the Contractor shall be properly labeled and tagged at all points of access (handholes, manholes, terminal panels, control panels, and the respective wireway in the vault).

All changes to the airfield lighting system shall be documented by the Contractor and provided to the Resident Engineer/Technician.”

108-3.2 INSTALLATION IN DUCT OR CONDUIT. Add the following to this section:

“The unit duct will be run continuously through all ducts and conduits.

Where cable in unit duct enters a handhole or manhole with a continuous duct bank system to the termination point (such as from a handhole to the vault or between handholes and/or manholes) the unit duct will not be required for the respective cable.”

108-3.3 TRENCHING. Add the following to this section:

“F. Cable installed in cultivated fields shall be installed at a minimum of 42 in. below grade.

G. Any and all trenches will be backfilled to a smooth grade to the satisfaction of the Engineer. All trench settlements shall be corrected for a period of one year. Restoration, grading, and seeding of areas disturbed during the installation of the proposed cable will be incidental to the respective 108 Pay Item.”

108-3.5 SPLICING. Add the following:

“In-line connections for existing cables cut during construction shall be repaired with a cast splice kit. The Contractor shall have a minimum of two splice kits on the job site at all times for emergency repairs. Cast splice kits shall be specified in paragraph (a) of Item 108-2.4. **Splice cans shall be provided for existing cables cut and repaired for each splice in cables not to be abandoned. Where a splice can is not readily available at the time of the cable damage, splice markers shall be temporarily installed over each splice in cables not to be abandoned, then these splices shall later be replaced with new splices in an L-867 splice can. Costs associated with splice cans for accidental cable cuts caused by the Contractor, repairs and/or shortages of cables will be the responsibility of the Contractor and no additional compensation will be allowed.**

There shall be no splices between series lighting circuit isolation transformers. In the event that a series lighting circuit cable is cut between isolation transformers, the entire length of cable between these isolation transformers shall be replaced, at the Contractor’s own expense.

The Contractor shall use a cable stripper/penciller whenever cable connections are made.

All splices and connections will be considered incidental to the respective cable.”

108-3.8 TESTING. Add the following.

- "K. Prior to beginning airfield lighting modifications, cable installation, and/or any other work that might possibly affect airfield lighting circuits, all existing series circuit cables shall be Megger tested and recorded at the vault. All existing series circuit cable loops shall have the resistance tested and recorded for each circuit at the vault. Each constant current regulator shall be tested with results recorded. Copies of test results shall be provided to the Resident Engineer/Resident Technician and the respective Project Engineer of Record within 5 business days of conducting the respective set of tests. See the testing forms in Appendix A.
- L. After airfield lighting modifications, additions, and/or upgrades have been completed, series circuit cables shall be Megger tested and recorded at the vault. All series circuit cable loops shall have the resistance tested and recorded for each circuit at the vault. Each constant current regulator shall be tested with results recorded. Copies of test results shall be provided to the Resident Engineer/Resident Technician and the respective Project Engineer of Record within 5 business days of conducting the respective set of tests. See the testing forms in Appendix A.
- M. Insulation resistance testing equipment for use with 5,000 Volt series circuit cables shall use an insulation resistance tester capable of testing the cables at 5,000 Volts. Older series circuit cables and/or cables in poor condition may require the test voltage to be performed at a voltage lower than 5,000 Volts (Example 1,000 Volts, 500 Volts, or less than 500 Volts). The respective test voltage shall be recorded for each cable insulation resistance test result.
- N. Insulation resistance testing equipment for use with 600 Volt rated cables shall use a 500 Volt insulation resistance tester. The respective test voltage shall be recorded for each cable insulation resistance test result.
- O. It is recommended to use the same insulation resistance test equipment throughout the project to ensure reliable comparative readings at the beginning of the project and at the completion of the project.
- P. The Contractor is responsible to employ qualified personnel that are capable of properly conducting the required tests to the satisfaction of the Project Engineer of Record. Tests that provide unsatisfactory results shall be reviewed to determine the possible cause of unsatisfactory results, corrections shall be made, and the tests shall be conducted again.
- Q See Appendix A – "Constant Current Regulator and Cable Testing Forms" for additional information on testing requirements for airfield lighting systems. All testing will be considered incidental to the respective work items and no additional compensation will be allowed."

Add the following:

108-3.12 LOCATING OF EXISTING UNDERGROUND UTILITIES AND CABLES. The location, size, and type of material of existing underground and/or aboveground utilities indicated on the Plans are not represented as being accurate, sufficient, or complete. Neither the Owner nor the Engineer assumes any responsibility whatsoever in respect to the accuracy, completeness, or

sufficiency of the information. There is no guarantee, either expressed or implied, that the locations, size, and type of material of existing underground utilities indicated are representative of those to be encountered in the construction. It shall be the Contractor's responsibility to determine the actual location of all such facilities, including service connections to underground utilities. Prior to construction, the Contractor shall notify the utility companies of his operational plans, and shall obtain, from the respective utility companies, detailed information and assistance relative to the location of their facilities and the working schedule of the companies for removal or adjustment, where required. In the event an unexpected utility interference is encountered during construction, the Contractor shall immediately notify the utility company of jurisdiction. The Owner's Representative and/or the Resident Engineer/Technician shall also be immediately notified. Any damage to such mains and services shall be restored to service at once and paid for by the Contractor at no additional cost to the Contract.

All utility cables and lines shall be located by the respective utility. **Contact JULIE (Joint Utility Location Information for Excavators) for utility information, phone: 1-800-892-0123.** Contact the FAA (Federal Aviation Administration) for assistance in locating FAA cables and utilities. Location of FAA power, control, and communication cables shall be coordinated with and/or located by the FAA. Also contact Airport Director/Manager and Airport Personnel for assistance in locating underground Airport cables and/or utilities. Also coordinate work with all aboveground utilities.

Payment for locating and marking underground utilities and cables will not be paid for separately but shall be considered incidental to the plowing/trenching/boring of cable and cable in unit duct.

108-3.13 SEPARATION OF HIGH-VOLTAGE AND LOW-VOLTAGE WIRING. High-voltage circuit wiring (airfield lighting 5000 Volt series circuits and/or other circuits rated above 600 Volts) and low-voltage circuit wiring (rated 600 Volts and below) shall maintain separation from each other. High-voltage wiring and low-voltage wiring shall not be installed in the same wireway, conduit, duct, raceway, handhole, or junction box. Where necessary provide split flexible duct around low voltage cables located in a handhole with high voltage cables, to isolate the cables from possible contact with each other.

108-3.14 IDENTIFICATION OF CABLES. At electrical handholes and manholes, identify and label each cable originating in the vault with respect to the system or device served. Provide identification tags rated suitable for the respective locations with permanent markings.

METHOD OF MEASUREMENT

108-4.1. Add the following:

"The footage of cable and/or cable in unit duct installed in duct, conduit, or raceway to be paid for shall be the number of linear feet of cable installed in duct, conduit, or raceway measured in place by direct measurement, completed, ready for operation and accepted as satisfactory with no allowance being made for overrun due to slack, turns, splices, etc. Slack cable required to perform cable splices outside of the respective splice cans, handholes, or manholes, shall be incidental to the respective cable pay item and no additional measurement for payment will be made. Coring and interface to handholes or manholes shall be incidental to the respective cable pay item and no additional measurement for payment will be made. The relocation, interface, and/or adjustment of existing cable and/or cable in unit duct will be considered incidental to the work for which it is required, and no additional compensation will be allowed. Cable tests and constant

current regulator tests will be considered incidental to the respective cable pay item and no additional compensation will be allowed. Cable will be measured for payment from the respective termination or splice point in the field up to the vault or respective termination point.

Testing the airfield lighting systems and the associated constant current regulator tests and cable tests will be considered incidental to the Contract and no additional compensation will be allowed.

All lockout/tagout procedures to ensure and maintain safety of personnel will be considered incidental to the respective item of work for which it applies, and no additional compensation will be allowed.”

BASIS OF PAYMENT

108-5.1. Add the following:

“Payment will be made at the contract unit price per lin. ft. of cable completed and accepted by the Engineer. This price shall be full compensation for furnishing all materials, and for all preparation, assembly, and installation of these materials; for all plowing, trenching, directional-boring, coring of manholes or handholes, installation in ducts, raceways, conduits, splice cans, handholes, or manholes, and for all excavation and backfilling; for all site restoration (topsoiling, grading, seeding, mulching) and pavement restoration; and for all labor, equipment, tools, testing, and incidentals necessary to complete this Item.

Payment will be made under:

Item AR108088, 1/C #8 XLP-USE – per FOOT
Item AR108658, 3/C #8 600 V UG Cable in UD – per FOOT
Item AS108088, 1/C #8 XLP-USE – per FOOT
Item AS108658, 3/C #8 600 V UG Cable in UD – per FOOT”

END OF ITEM 108

ITEM 110 AIRPORT UNDERGROUND ELECTRICAL DUCT BANKS AND CONDUITS

DESCRIPTION

110-1.1 Add the following:

“This item of work shall consist of the installation of all proposed conduits and ducts as shown on the Construction Plans.”

110-1.2 REFERENCES. The publications listed below form a part of this specification to the extent referenced. The publications are referred to within the text by the basic designation only. Note: where FAA Advisory Circulars are referenced, they shall be the current issue or issues in effect.

- A. ANSI C80.1 – Rigid Steel Conduit, Zinc Coated.
- B. ANSI C80.4 – Fittings Rigid Metal Conduit and EMT.
- C. ASTM A706 – Standard Specification for Deformed and Plain Low-Alloy Steel Bars for Concrete Reinforcement
- D. ASTM D3350 – Specification of Polyethylene Plastics Pipe and Fittings Materials.
- E. ASTM F2160 – Standard Specification for Solid Wall, High-Density Polyethylene Conduit Based on Controlled Outside Diameter.
- F. FAA AC 150/5340-30, “DESIGN AND INSTALLATION DETAILS FOR AIRPORT VISUAL AIDS”.
- G. FAA AC 150/5345-53, “AIRPORT LIGHTING EQUIPMENT CERTIFICATION PROGRAM”.
- H. FAA STD-019f, Lightning and Surge Protection, Grounding Bonding and Shielding Requirements for Facilities and Electronic Equipment.
- I. NEMA TC-2 – Electrical Plastic Tubing and Conduit.
- J. NEMA TC-3 – Fittings Rigid PVC Conduit and Tubing.
- K. NEMA TC-7 – Smooth-Wall Coilable Polyethylene Electrical Plastic Conduit.
- L. NFPA 70 – National Electrical Code (NEC), most current issue in force.
- M. NFPA 2638645-1 = National Fire Protection Association IDN.
- N. OSHA 29 CFR Part 1910, Occupational Safety and Health Standards for electrical safety and lockout/tagout procedures.
- O. UL Standard 6 – Electrical Rigid Metal Conduit – Steel.
- P. UL Standard 514B – Conduit, Tubing and Cable Fittings.

- Q. UL Standard 514C – Nonmetallic Outlet Boxes, Flush-Device Boxes, and Covers.
- R. UL Standard 1242 – Electrical Intermediate Metal Conduit Steel.
- S. UL Standard 651 – Schedule 40 and 80 Rigid PVC Conduit.
- T. UL Standard 651A – Type EB and A Rigid PVC Conduit and HDPE Conduit.
- U. UL Standard 651B – Standard for Continuous Length High-Density Polyethylene (HDPE) Conduit.

110-1.3 SHOP DRAWINGS. The Contractor shall furnish shop drawings for approval before ordering equipment and/or materials. Shop drawings are required for each type of conduit or duct to be used on the project. **Shop drawings shall be clear and legible. Copies that are illegible will be rejected.** Shop drawings shall include the following information:

- A. In order to expedite the shop drawing review, inspection and/or testing of materials and equipment, the Contractor shall furnish complete statements to the Project Engineer of Record as to the origin and manufacturer of all materials and equipment to be used in the work. Such statements shall be furnished promptly after execution of the contract but, in all cases, prior to delivery of such materials and equipment.
- B. Provide certification that steel products are manufactured in the USA from domestic steel to comply with the Steel Products Procurement Act (30 ILCS 565).
- C. Indicate the pay item number for each respective conduit or duct.
- D. Shop drawings shall include conduit and/or duct cut sheets with type, size, specifications, UL listing, manufacturer, and catalog or part number.
- E. Provide manufacturer's literature confirming the respective duct to be bored is suitable for directional boring with the respective Shop Drawing submittal.
- F. Provide certification that the respective steel conduits used on this project are manufactured from 100 percent domestic steel.
- G. Provide certification that the respective plastic conduits used on this project are manufactured from domestic materials.

EQUIPMENT AND MATERIALS

110-2.1 GENERAL. Add the following:

"All materials for these items shall be in accordance with the FAA Standard Specification 110 Equipment and Materials, as detailed on the Plans, and as specified herein.

- A. The duct to be directional-bored shall be Schedule 40 PVC Conduit, Schedule 80 PVC Conduit or High-Density Polyethylene (HDPE) duct, (Schedule 40, Schedule 80, SDR 9, or SDR 11), and suitable for directional boring installation."

110-2.2 STEEL CONDUIT. Replace this section with the following:

“Rigid Steel Conduit and fittings shall be hot-dipped, galvanized, UL-listed, and produced in accordance with UL Standard 6 – Rigid Metal Conduit and ANSI C80.1 – Rigid Steel Conduit, Zinc Coated. Couplings, connectors, and fittings for rigid steel conduit shall be threaded, galvanized steel or galvanized, malleable iron, specifically designed and manufactured for the purpose. Fittings shall conform to ANSI C80.4 – Fittings Rigid Metal Conduit and EMT and UL 514B – Conduit, Tubing, and Cable Fittings. Set screw type fittings are not acceptable. Steel used to manufacture conduits shall be 100 percent domestic steel to comply with the Airport Improvement Program Buy American Preference Requirements and the Steel Products Procurement Act. Contractor shall provide certification that the respective steel conduits used on this project are manufactured from 100 percent domestic steel.

Miscellaneous Fittings. Fittings shall be suitable for use with conduits and ducts supplied. All fittings for use with rigid metal conduit shall be threaded. Set screw-type fittings are not acceptable. All conduit bodies, fittings, and boxes installed in classified hazardous locations (Class I, Division 1 or 2, Group D) shall be suitable for use in Class I, Division 1, and Group D locations. Fittings shall be as manufactured by Appleton, Crouse-Hinds, Hubbell-Killark, O-Z/Gedney, or approved equal.

Provide NEMA 4, 4X hubs for all conduit entries into NEMA 4, 4X equipment enclosures to maintain the NEMA 4, 4X rating of the respective enclosure. Hubs for use with NEMA 4X stainless steel enclosures shall be NEMA 4X stainless steel hubs.”

110-2.3 PLASTIC CONDUIT. Add the following to the end of this section:

“Conduits shall be suitable for underground applications encased in concrete or direct burial, and suitable for exposed applications aboveground.

- C. Conduits for concrete encasement shall be Schedule 40 PVC, UL-listed, rated for 90°C cable, conforming to NEMA Standard TC-2 and UL 651, listed suitable for concrete encasement or Schedule 40 (minimum) HDPE conduit, UL-listed or ETL listed, conforming to NEMA Standard TC-7 and UL 651B and listed suitable for concrete encasement. Conduits shall be suitable for underground applications encased in concrete or direct burial, and suitable for exposed applications aboveground.
- D. Conduits for directional boring shall be Schedule 40 PVC or Schedule 80 PVC conduit, UL-listed or ETL listed, rated for 90°C cable-conforming to NEMA Standard TC-2 and UL 651 and suitable for directional boring installation, Schedule 40 HDPE or Schedule 80 HDPE conduit, UL-listed, conforming to NEMA Standard TC-7 and UL 651B and suitable for directional boring installation, or Wall Type SDR 11 (minimum) HDPE conduit manufactured in accordance with ASTM D-3350 (Specification of Polyethylene Plastics Pipe and Fittings Materials) and ASTM F2160 (Standard Specification for Solid Wall, High-Density Polyethylene Conduit Based on Controlled Outside Diameter), and suitable for directional boring installation. **Per NEC 300.5 (K), raceways installed using directional boring equipment shall be approved for the purpose. Provide manufacturer’s literature confirming the respective duct is suitable for directional boring with the respective Shop Drawing submittal.**
- E. Conduits for direct burial in earth shall be PVC Schedule 40 (minimum wall thickness), UL-listed, rated for 90°C cable-conforming to NEMA Standard TC-2 and UL 651, listed

suitable for direct burial in earth, or HDPE Schedule 40 (minimum wall thickness), conforming to NEMA Standard TC-7 and UL 651B, or HDPE SDR 13.5 (minimum wall thickness) manufactured in accordance with ASTM D-3350 (Specification of Polyethylene Plastics Pipe and Fittings Materials) and ASTM F2160 (Standard Specification for Solid Wall, High-Density Polyethylene Conduit Based on Controlled Outside Diameter). Conduits shall be suitable for direct burial in earth and/or concrete encasement.”

110-2.4 SPLIT CONDUIT. Add the following to this section:

“NON-METALLIC SPLIT DUCT. Non-metallic split duct shall be used to extend existing duct that contains cables and/or for protection of existing cables as detailed on the Plans. Non-metallic split duct shall be Schedule 40 PVC designed for use with power and control cable applications. Non-metallic split duct shall be suitable for direct burial in earth and concrete encasement and exhibit superior impact strength. Joints shall be sealed with corrosion-resistant tape and heavy-duty plastic straps as recommended by the split duct manufacturer for the application. Split duct sleeve couplings, duct sweeps, fittings, and accessories shall be by the same manufacturer to assure system integrity. Non-metallic split duct shall be manufactured by Prime Conduit, Inc., Carlon Electrical Products, Cantex Inc., or approved equal. 4-in. Schedule 40 split ducts shall be Carlon Part Number 49015SD, Cantex Part Number A52EAZS, or approved equal. Install split duct as detailed on the Plans and in conformance with manufacturer’s recommendations for the respective application. Provide adapters, couplings, and fittings to accommodate interface to existing duct or conduit. Where split duct is to be concrete-encased, confirm it is suitable for the respective application with the manufacturer.”

Add the following:

110-2.9 DUCT SPACERS. Provide duct spacers to provide proper separation of conduits installed in concrete encased duct. Duct spacers shall be designed to provide 3” separation of conduits. Duct spacers shall be suitable for the respective size and quantity of ducts; Underground Devices Incorporated Wunpeece Series, Carlon Snap-N-Stack Combo Spacers, Cantex Spacers for Duct, or approved equal. Confirm catalog numbers with the manufacturer for the respective application.

CONSTRUCTION METHODS

110-3.1 GENERAL. Add to this section:

“The proposed conduits and ducts shall be constructed at the locations and in accordance with the details shown on the Construction Plans. Ducts shall be installed 18 in. minimum below grade. Ducts located in area subject to farming shall be 42 in minimum below grade. Where detailed on the Plans or where required to avoid obstructions, ducts shall be buried deeper. Where concrete-encased duct interfaces to directional-bored duct at a pavement crossing, the concrete encasement shall be installed up to the respective pavement edge. Where concrete-encased duct interfaces to an electrical handhole or manhole, the concrete encasement shall be installed up to the respective handhole or manhole. Provide bushings or bells at conduit terminations in electrical handholes or manholes.

Underground ducts installed by directional-boring method shall be installed in a manner that will not damage any existing underground utilities and shall not disturb or damage the respective pavement or roadway surface. Ducts shall be directional bored at the locations shown on the Construction Plans. The ducts will be bored at a minimum depth of 24 inches below the bottom of the pavement it is being bored under. Ducts installed under paved areas and roadways shall extend a minimum of 10 feet beyond the respective pavement or roadway surface, unless detailed otherwise on the Plans. A pull wire will be left in the conduit if it is to be left vacant. The ends of the conduit will be sealed with approved plugs.

The Contractor will determine if there is a conflict between the installation of the proposed electrical ducts and any existing/proposed utilities. He will make all necessary adjustments in depth of installation to avoid any and all existing/proposed underground improvements.

Provide conduit bushings or bells at duct terminations in handholes and manholes.”

110-3.7 RESTORATION. Add to this section:

“Any and all trenches and disturbed areas will be backfilled and restored to a smooth grade and seeded to the satisfaction of the Resident Engineer/Resident Technician. All trench settlements shall be corrected for a period of one year. Restoration, grading, and seeding of areas disturbed during the installation of the proposed ducts will be incidental to the respective pay item for which the duct is installed and shall be in accordance with Item 901 Seeding and Item 908 Mulching.

Any and all disturbed pavement areas will be restored to their original or better condition. Restoration of pavement areas disturbed during the installation of the proposed ducts will be incidental to the respective pay item for which the duct is installed. The restoration of concrete pavement will be completed in accordance with Item 610 for sidewalks and concrete pavement but will be incidental to the respective pay item for which the duct is installed.”

Add the following:

110-3.8 LOCATING OF EXISTING UNDERGROUND UTILITIES AND CABLES. The location, size, and type of material of existing underground and/or aboveground utilities indicated on the Plans are not represented as being accurate, sufficient, or complete. Neither the Owner nor the Engineer assumes any responsibility whatsoever in respect to the accuracy, completeness, or sufficiency of the information. There is no guarantee, either expressed or implied, that the locations, size, and type of material of existing underground utilities indicated are representative of those to be encountered in the construction. It shall be the Contractor’s responsibility to determine the actual location of all such facilities, including service connections to underground utilities. Prior to construction, the Contractor shall notify the utility companies of his operational plans, and shall obtain from the respective utility companies detailed information and assistance relative to the location of their facilities and the working schedule of the companies for removal or adjustment, where required. In the event an unexpected utility interference is encountered during construction, the Contractor shall immediately notify the utility company of jurisdiction. The Owner’s Representative and/or the Resident Engineer shall also be immediately notified. Any damage to such mains and services shall be restored to service at once and paid for by the Contractor at no additional cost to the Contract.

All utility cables and lines shall be located by the respective utility. **Contact JULIE (Joint Utility Location Information for Excavators) for utility information, phone: 1-800-892-0123.** Contact the FAA (Federal Aviation Administration) for assistance in locating FAA cables and utilities. Location of FAA power, control, and communication cables shall be coordinated with and/or located by the FAA. Also contact Airport Director/Manager and Airport Personnel for assistance in locating underground Airport cables and/or utilities. Also coordinate work with all aboveground utilities.

Contractor shall locate and mark all existing cables within ten (10) feet of proposed excavating/trenching area. Any cables found interfering with proposed excavation or cable/trenching shall be hand dug and exposed. Any damaged cables shall be immediately repaired to the satisfaction of the Resident Engineer at the Contractor's expense. The Resident Engineer and Owner shall be notified immediately if any cables are damaged.

Due to the quantities of existing utilities and lines in the proposed areas of work, the Contractor will need to carefully excavate to expose and protect these utilities and lines prior to installing manholes, handholes, and/or junction structures and the associated trenches for the proposed conduits, ducts, and raceway system.

Payment for locating and marking underground utilities and cables will not be paid for separately but shall be considered incidental to the respective duct installation.

110-3.9 SEPARATION OF HIGH-VOLTAGE AND LOW-VOLTAGE WIRING. High-voltage circuit wiring (airfield lighting 5000 Volt series circuits and/or other circuits rated above 600 Volts) and low-voltage circuit wiring (rated 600 Volts and below) shall maintain separation from each other. High-voltage wiring and low-voltage wiring shall not be installed in the same wireway, conduit, duct, raceway, handhole, or junction box.

METHOD OF MEASUREMENT

110-4.1 Add the following:

"All restoration work associated with installation of ducts and conduits will be considered incidental to the respective item for which they are installed, and no additional measurement will be made. Removal and replacement of bituminous pavement or concrete pavement will be considered incidental to the respective pay item for which the duct is installed. All duct and conduit interface to manholes, handholes, junction structures, or pull boxes including coring of manholes, handholes, junction structures, or pull boxes will be considered incidental to the respective item for which they are installed, and no additional measurement will be made. Conduits, conduit nipples, conduit couplings, and other conduit fittings included with splice cans, junction structures, Navaid installations, base mounted airfield light fixtures, airfield signs, and/or taxi signs, will be considered incidental to the respective item for which they are installed, and no additional measurement will be made.

All lockout/tagout procedures to ensure and maintain safety of personnel will be considered incidental to the respective item of work for which it applies, and no additional compensation will be allowed."

110-4.2 Delete this section.

BASIS OF PAYMENT

110-5.1. Add the following:

“Payment will be made at the contract unit price per each type and size of conduit, completed and accepted. This price shall be full compensation for furnishing all materials and for all preparation, assembly, and installation of these materials; for all sawing and pavement removal; for all duct interface work to handholes/manholes including coring of handholes/manholes; for all excavation and backfilling with aggregate backfill, earth backfill, and concrete; and for all labor, coordination, equipment, tools, and incidentals necessary to complete this Item. Removal and replacement of bituminous pavement or concrete pavement will be considered incidental to the respective pay item for which the duct is installed.

Payment will be made under:

Item AR110014	4” Directional Bore - per FOOT
Item AS110014	4” Directional Bore - per FOOT”

END OF ITEM 110

ITEM 125 INSTALLATION OF AIRPORT LIGHTING SYSTEMS

CONSTRUCTION METHODS

Add the following:

125-3.4 SAFETY PRACTICES WITH AIRFIELD LIGHTING SERIES CIRCUITS. Please understand that airfield lighting series circuits are dangerous and only qualified personnel should be permitted to work on them and safety procedures need to be followed. Safety of personnel is the top priority. Follow safety procedures for all work. Only qualified and experienced personnel should be permitted to work on airfield lighting series circuits. The following safety procedures shall be followed for the safety of personnel.

- A. Contractor shall coordinate work and any power outages with the Airport Manager and the Resident Engineer/Resident Technician. Any shutdown of existing systems shall be scheduled with and approved by the Airport Manager prior to shut down. Once shut down, the circuits shall be labeled as such to prevent accidental energizing of the respective circuits. All personnel shall follow U.S. Department of Labor Occupational Safety & Health Administration (OSHA) 29 CFR Part 1910 Occupational Safety and Health Standards for electrical safety and lockout/tagout procedures including, but not limited to, 29 CFR section 1910.147 The Control of Hazardous Energy (lockout/tagout). Where the facility is not equipped with lockout/tagout equipment the Contractor will be responsible to provide the appropriate lockout/tagout equipment for safety of personnel.
- B. The Contractor shall provide a copy of their electrical energy source Lockout/Tagout Procedures document to the Airport Director/Manager, Resident Engineer and the Project Engineer of Record. The Lockout/Tagout Procedures document shall include the contact information with 24-hour phone numbers for the Contractor and the Electrical Contractor Superintendent and/or the respective licensed Journeyman Electricians on the project site.
- C. Where existing electrical equipment does not have features for lockout/tagout the Contractor will be responsible for providing the appropriate lockout/tagout equipment and measures to ensure the safety of personnel.
- D. Compliance with Lockout/Tagout Procedures and all other safety procedures and requirements are the responsibility of the Contractor, the respective maintenance personnel, and any other personnel working on the equipment or electrical system.
- E. All electrical work shall comply with the requirements of NFPA 70 - National Electrical Code (NEC) most current issue in force, and all other applicable local codes, laws, ordinances, and requirements in force. Electrical equipment shall be installed in conformance with the respective manufacturer's directions and recommendations for the respective application. Any installations which void the UL listing, Intertek Testing Services verification/ETL listing, (or other third-party listing) and/or the manufacturer's warranty of a device, will not be permitted.
- F. Provide personnel protective equipment for all personnel working on or testing electrical systems suitable for the respective application. Provide protective equipment for personnel to keep them safe in the event of an arc flash or other electrical accident.

- G. The respective personnel performing airfield lighting work, vault work, and/or tests shall be familiar with, and qualified to work on 5000 Volt airfield lighting series circuits, constant current regulators, and associated airport electrical vault equipment. Every airfield lighting cable splicer shall be qualified in making cable splices and terminations on cables rated at and/or above 5000 Volts AC. The Contractor shall submit to the Project Engineer of Record proof of the qualifications of each proposed cable splicer for the cable type and voltage level to be worked on. Cable splicing/terminating personnel shall have a minimum of three (3) years continuous experience in terminating/splicing medium voltage cable.
- H. Personnel shall comply with the applicable requirements of NFPA 70E – Standard for Electrical Safety in the Workplace.
- I. Per NFPA 70E Standard for Electrical Safety in the Workplace it defines Electrically Safe Work Condition as “A state in which an electrical conductor or circuit part has been disconnected from energized parts, locked/tagged in accordance with established standards, tested to verify the absence of voltage, and, if necessary, temporarily grounded for personnel protection.” Prior to conducting tests or working on equipment, verify equipment enclosures and frames have a good and secure ground connection for the safety of personnel.
- J. Personnel shall comply with the applicable requirements of FAA Advisory Circular Number 150/5340-26C “Maintenance of Airport Visual Aid Facilities”. Obtain and review this document for your safety.
- K. FAA Advisory Circular Number 150/5340-26C notes that there are three basic rules to remember when working on and around airport lighting circuits. These are noted as follows:
1. **ALWAYS** assume that the circuit is energized until you have proven otherwise. ALWAYS check for current before disconnecting the series circuit connector, removing the S1 cutout, or opening the primary series circuit by any other means. Make it a required practice to check the circuit with an ammeter prior to breaking the connection – NO EXCEPTIONS. Never attempt to measure voltage in a series lighting circuit using ordinary volt meters. An inductive voltage measuring device (sometimes referred to as a “ticker”) such as is described in Chapter 4 may be used to detect the presence of induced voltage on a series lighting cable after checking for the presence of current. Always use a true RMS clamp-on type ammeter to verify if the circuit is energized. ALWAYS check the operation of the test equipment on a known live circuit before and after measurements are taken.
 2. **NEVER** under any circumstances open or break a live airfield series circuit. The voltage generated in the circuit can reach levels many times normal before the regulator’s open circuit protection can shut it down. As long as a current flow can be maintained, even if it is through you, the regulator will continue to operate. This is one of the reasons that series circuits can be so hazardous to work around – there is no personnel protection provided such as might be found on parallel interior wiring.

3. ***NEVER enter a manhole with energized conductors and never handle cables or transformers in light bases while there is current present. Cables or connectors can have cracked insulation where it is not visible or may be deteriorated and fall apart, exposing you to live circuit conductors.***

- L. Verify respective circuits and power sources prior to removing, disconnecting, relocating, installing, connecting, re-lamping, or working on the respective airfield lighting, taxi sign, NAVAID, or other device. Identify each respective circuit prior to performing work on that circuit. Disconnect the airfield lighting series circuit cables from the constant current regulator when performing work or tests on the respective circuit. Disconnect the power source for the respective lighting system, sign, Navaid or other device when performing work or tests on the respective circuit. Shut down and lockout the circuit for safety of personnel.

- M. When performing work on an airfield lighting circuit the respective circuit shall be shut down and locked off for the safety of personnel. This includes, but is not limited to, light fixture, sign and/or Navaid removals, repairs, replacements, relocations, lamp replacements, transformer replacements, component replacements, and/or installations; cable work, removals, repairs, replacements, relocations, rerouting, splicing, connecting, testing, and/or installations; grounding work, repairs, replacements, corrections, testing, and/or installations; Airport Electrical Vault work, constant current regulator work, and/or other electrical work.

- N. Make sure each constant current regulator has a good and secured frame ground connection from the regulator housing to the respective vault ground bus and grounding electrode system, prior to operation and testing of each regulator.

- O. Avoid placing materials on top of constant current regulators. Maintain clearance about constant current regulators for air flow and cooling.

- P. Make sure each airfield light fixture, sign, and Navaid has a good and secured frame ground connection from the respective device to the respective grounding electrode system, prior to operation, working on, and/or and testing of the device.

- Q. Never come in contact with water surrounding an active airfield lighting series circuit. Do not put your hand in a junction structure, splice can, handhole, manhole or other raceway system containing live airfield lighting circuits with water. The water may conduct electricity and cause harm, electric shock, injury or death.

- R. Series circuit disconnects are required for each constant current regulator in accordance with FAA AC 150/5340-30J "Design and Installation Details for Airport Visual Aids". The following practices are recommended and/or required for series circuit cutouts/disconnects and the associated airfield lighting series circuit wiring.
 1. The Type S-1 Series Plug Cutout is a series circuit disconnecting device installed at the output side of a constant current regulator (CCR). With the handle plug assembly removed, the cutout isolates the CCR output from airfield lighting series circuit loop for maintenance and personnel safety. The S-1 cutout also shorts the series loop and shorts the regulator secondary for helping with servicing, maintenance, and troubleshooting.

2. Provide series plug cutouts for each constant current regulator as detailed on the Plans. Series plug cutouts shall be Type S-1, rated 5KV, 20-Amps, and shall comply with FAA AC 150/5340-30J. Cutouts shall be certified in writing by the manufacturer as suitable for the respective application. Cutouts shall disconnect the input from the output, short the input terminals, and short the output terminals when the handle/plug is removed. Series plug cutouts shall be Crouse-Hinds, Type S-1, Model 2, Catalog Number 30775, Manairco Catalog Number MRS1, or an approved equal. Series cutouts where the manufacturer has noted their cutouts are not recommended to operate with the handle pulled/removed are not acceptable. Other cutouts, that do not function as detailed on the Plans or that are not suitable for the respective application, are not acceptable.
3. Install the series plug cutouts in a NEMA 1 or NEMA 12 painted steel enclosure adequately sized to house the cutout(s), with a hinged cover and back panel to mount the cutouts. All enclosures shall be pad lockable. Where existing cutout enclosures are used provide pad lock kits for each existing enclosure. The installation of series circuit cutouts shall accommodate lockout/tagout for safety of personnel.
4. Never remove or insert a series circuit plug cutout/disconnect with the circuit energized. Removal of a series circuit plug cutout/disconnect on an energized circuit can result in an arc flash that may cause injury, burns, and harm to personnel. Always shutoff and lockout input power to the respective constant current regulator prior to pulling or inserting a series plug cutout.
5. Series circuit plug cutouts/disconnects shall only be used on airfield lighting series circuits in accordance with the respective manufacturer's instructions. Verify ratings and applications with each respective series plug cutout manufacturer. Note, observe, and verify the differences in applications for the different manufacturer series plug cutouts. Confirm ratings and suitability for the respective application with each respective cutout manufacturer. Some manufacturer's Type S-1 series circuit cutouts might not be suitable for applications that other manufacturer's Type S-1 series circuit cutouts are rated for.
6. Know the difference between Type S-1 series circuit plug cutouts and Type SCO series circuit plug cutouts. Type SCO cutouts do not operate the same as Type S-1 cutouts. Examples of Type S-1 cutouts include Crouse-Hinds, Type S-1, Model 2, Catalog Number 30775, and Manairco Catalog Number MRS1. Example of Type SCO cutout is ADB Safegate Part Number 1475.92.030 and Part Number 1475.92.030-1. Refer to the respective installation instructions for each type of cutout. This is important for the safety of personnel.
7. Series circuit wiring shall be installed in enclosed raceways. No exposed airfield lighting series circuit cables (L-824) will be permitted in the Airport Electrical Vault. In accordance with National Electrical Code Article 300, Part II Requirements for over 1000 Volts, Nominal, Part 300.37 Aboveground Wiring Methods, Exception, it notes: "*Airfield lighting cable used in series circuits that are powered by regulators and installed in restricted airport lighting vault shall be permitted as exposed cable installations.*" An Airport Electrical Vault is a restricted access facility limited to access by qualified persons only. Often airport

electrical vault buildings do not have provisions to limit access to only qualified personnel. Therefore, no exposed airfield lighting series circuit cables will be permitted in the Airport Electrical Vault.

8. Maintain separation of high-voltage airfield lighting 5000 Volt series circuits from low-voltage circuit wiring (120 VAC, 208 VAC, 240 VAC, 480 VAC or other wiring rated 600 Volts and below). High-voltage wiring and low-voltage wiring shall not be installed in the same wireway, conduit, duct, raceway, junction box, handhole, or manhole. High-voltage airfield lighting 5000 Volt series circuits wiring shall enter each respective regulator at the high-voltage/series circuit output section of the regulator. 208 VAC, 240 VAC, or 480 VAC input power wiring shall enter each respective regulator at the low-voltage/input power section of the regulator. Control wiring shall enter each respective regulator at the control section of the regulator.
- S. The following are a list of incidents that have taken place on airfields that resulted in dangerous conditions, injuries, electric shock, and/or death. These are provided for informational purposes to help keep personnel safe.
1. Situation 1; In 2023 a taxiway circuit was tested to be in very poor and dangerous condition. The circuit was energized, and the Airport staff drove around to see if any lights were on. They observed one of the airfield lighting series circuit transformers was above grade and was on fire on a wet day. The Airport Maintenance Person got out of the truck to go look at the transformer that was on fire. The Hanson employee on site told the Airport Maintenance Personnel to get back in the truck immediately and explained that a 5,000 Volt series circuit on fire in wet conditions can cause electrocution to someone getting into the nearby wet grass and/or standing water. Injury was avoided on this day.
 2. Situation 2; The taxiway circuit identified in Situation 1 was troubleshooted by qualified personnel. The circuit was energized, and the Electrical Contractor drove around to see if any lights were on. They observed one of the taxiway lights having steam coming out of the light base due to boiling water caused by a bad transformer and/or ground fault condition. The Contractor recorded this with a video and shortly after the taxiway light fixture blew up and caused an arc flash.
 3. Situation 3; The Electrical Contractor was changing light bulbs on a live airfield lighting series circuit. The Contractor did not have the circuit shut off nor was it locked off and tagged off per OSHA requirements. The Contractor was wearing gloves to protect his hands from possible broken lamps. The Contractor had one hand on a lamp and grabbed the stem of the light fixture with his other hand and it blew off the thumb on his hand. The light fixture stem was shorted to the series circuit.
 4. Situation 4; The Electrical Contractor was changing light bulbs on a live airfield lighting series circuit. The Contractor did not have the circuit shut off nor was it locked off and tagged off per OSHA requirements. The Contractor had one hand on a lamp and grabbed the stem of the light fixture with his other hand and it blew off the index finger on his hand. The light fixture stem was shorted to the series circuit.

5. Situation 5; An Electrical Contractor was working on a base mounted airfield light fixture on a live airfield lighting series circuit. The Contractor did not have the circuit shut off nor was it locked off and tagged off per OSHA requirements. The contractor was removing the bolts for the light base cover. He had 5 of the six bolts removed. When he removed the sixth bolt the cover blew off and hit him in the face due to a ground fault condition and losing the ground path when the last bolt was removed. It is important to have light base covers connected to ground with a bonding jumper or ground strap to maintain safety of personnel. FAA AC 150/5340-30j requires the following light fixture bonding for safety of personnel: *Bond the light fixture to the light base internal ground lug via a No. 6 AWG stranded copper wire rated for 600 volts with green XHHW, THWN-2, or other suitable insulation, bare stranded conductor or a braided ground strap of equivalent current rating. The bonding conductor length must be sufficient to allow the removal of the light fixture from the light base for routine maintenance.*

6. Situation 6; During an electrical survey at an Airport, it was observed that the electric utility transformer for the Airport Electrical Vault Building had been changed from a 25 KVA unit to a 100 KVA unit to accommodate additional temporary electric services for the annual festival that took place at the Airport. The electric service to the Airport Electrical Vault is 120/240 VAC, single phase, 3 wire. The previous 25 KVA utility transformer had a maximum calculated fault current that was less than 10,000 Amps, and the service disconnect and distribution panelboard were adequately rated for fault current not exceeding 10,000 Amps at 120/240 VAC. The replacement 100 KVA transformer had an impedance of 1.73 percent and a maximum calculated fault current of 17,705 Amps. The existing Service Disconnect had 200 Amp, Bussmann NON-200 One-Time General Purpose Fuses that had 10,000 Amp Interrupting Rating which were no longer suitable for the available fault current. The Distribution panelboard had a 200 Amp, 2 pole main breaker with 22,000 AIC at 240 VAC and branch breakers that were rated 10,000 AIC at 120/240 VAC. To address the higher available fault current of 17,705 Amps the following corrective action was taken. The existing 200 Amp, Bussmann NON-200 One-Time General Purpose Fuses in the service disconnect were replaced with 200 Amp, Type RK5 fuses that had 100,000 Amp Interrupting Rating. To make the distribution panel fully rated for 22,000 AIC at 120/240 all of the branch and feeder circuit breakers were replaced with new breakers that were rated 22,000 AIC at 120/240 VAC. The point to this is that situations can change that affect existing electrical equipment ratings. When the vault service and distribution equipment was originally installed it was properly rated and suitable for the application where served by a 25 KVA transformer that had a fault current of less than 10,000 Amps. The change to the larger 100 KVA transformer was not coordinated with the vault electric service and distribution equipment. This was discovered after the transformer had been replaced with a larger unit. Upon its discovery, corrective action was taken to address this unsafe situation. Please be aware when doing work on electric service and distribution systems it is important to verify the maximum available fault current at the equipment and verify that the respective equipment is properly rated for the fault current. Sometimes changes will be necessary to ensure the equipment is properly rated to safely trip the circuit breakers or blow the fuse in the event of a fault. Where equipment is not adequately rated for the fault current it might be subject to damage and unsafe

conditions for personnel in the event of a fault. Such conditions need to be addressed and corrective action needs to be taken.

7. Situation 7; Several years ago, a client contacted us and noted they had lightning damage on their runway lighting circuit. Approximately 16 runway light fixtures and transformers were damaged and in some cases the transformers were blown out of the circuit (and disconnected). The client explained that the constant current regulator for the runway lighting system would operate providing 6.6 Amps but 0 (zero) volts output indicating a shorted output. They noted when they switched over to the backup regulator it would not run and provided an open circuit loop alarm. It was explained to the client to be very cautious about the regulator that was providing 6.6 Amps output at zero volts output. It sounded like the output lightning arrestors on the regulator had blown and shorted to ground (the frame of the regulator). This condition had the output current running through the metal frame/housing of the regulator and is a concern of electric shock or electrocution. A qualified electrician investigated and determined that both output lightning arrestors had blown and shorted to the frame of the regulator. The regulator was shut down and repairs were made. Based on the above please note the following safety concerns.
 - It is required and important that each constant current regulator always has a good and secure ground connection from its frame to a good grounding electrode system. When operating a constant current regulator confirm it has a good and secure ground connection to its frame prior to operation. This is important for the protection of personnel. In the above situation, if the regulator did not have a good ground to its frame, a condition would have existed that could have caused electric shock or electrocution.
 - It is recommended to include an output voltage meter on constant current regulators for testing, maintenance, and troubleshooting purposes. This is an optional feature, not a standard feature, and therefore needs to be included with the specification for the respective regulator. Having an output voltage meter on the regulator identified above helped us to determine the failure and unsafe condition.
 - An airport electrical vault is a restricted access electrical facility for qualified and authorized personnel only. Anytime you enter an airport electrical vault you need to be accompanied by someone that is authorized and qualified to ensure your safety. Also note that just because someone is “authorized and qualified”, does not mean that they will also take responsibility for your safety. If you are not comfortable entering an airport electrical vault, please stay out. Your safety is always important and needs to be the priority.
8. Situation 8; In July 2009 we were working at an airport and observing the installation of a new airport electrical vault building and airfield lighting equipment. An airport vault is a building that contains electrical power and airfield lighting equipment and controls. The electrical contractor staff performing the installation had left the site to go work at another location and brought in a different two-man crew (journeyman and apprentice) that was not completely

familiar with the status of the work completed to date. We had worked for several days addressing problems and were at the point of testing the new vault equipment. Tests were conducted in the morning and the airfield lighting was observed to be in working order. In the afternoon the apprentice began demolition of the old vault. The electric service had been disconnected and removed from the old vault a few days earlier. Tests were conducted again in the afternoon for demonstration to the Airport Manager and it was discovered that one of the runway circuits no longer worked. Investigation found that there was an old homerun circuit to the old vault that had not been disconnected from the airfield lighting. The apprentice had removed the old series circuit disconnecting means (cutout) and it resulted in an open circuit condition for the runway lighting series circuit, which caused the lights to no longer work. Remember this old vault had no electric service power, but it still had a live circuit running to it that originated from the new vault. This was an extremely dangerous condition. The issue was corrected, and no one was hurt. The point of this is to be aware of the possible dangers that might occur when a different crew is brought in to complete the work of others. And never assume a circuit is dead unless it has been checked and verified as disconnected at the power source AND disconnected at the respective system it is powering (disconnected at both locations). Please always take measures to ensure your safety and the safety of those you are working with.

9. Situation 9; In April 2011 we were testing a new taxiway lighting system on an old constant current regulator. The cover of the constant current regulator was off for testing and startup purposes. The Resident Technician was looking at the regulator and was told not to look at the regulator during a startup. The Resident Technician was not a qualified electrical person and left the site for safety purposes. The regulator was turned on and tested with no load. The regulator was observed to operate properly. The regulator was shut off and the taxiway lighting circuit was connected to it. The regulator was again turned on and one of the capacitors exploded and caught fire. This is an example of why you should not look at electrical equipment during start up until considered safe and you have appropriate personal protection equipment. It is also an example of the need for personnel protective equipment, clothing, face protection and other protection during start up, testing and operation of electrical equipment.
10. Situation 10; A laborer was performing an airfield lighting series circuit splice connection. He had not practiced lockout/tagout for the respective circuit. An airport maintenance person decided to check the respective airfield lighting for burnt out lamps and turned on the circuit while the laborer was performing a splice. The laborer received electric shock and had to be taken to a hospital for medical attention. The laborer was reported to have spent two days in the hospital and did recover. The point to this is that only qualified and experienced cable splicers are permitted to perform airfield lighting series circuit connections and lockout/tagout procedures must be followed for safety of personnel.
11. Situation 11; An electrical contractor crew was working on an airfield lighting system. The electrical contractor pulled the airfield lighting series circuit cutouts/disconnects in the Airport Electrical Vault. The Electrical contractor thought they had all airfield lighting series circuits disconnected but actually had one circuit that was not disconnected and was a live circuit. An apprentice

electrician went to work on the one circuit that was not disconnected and was electrocuted and died on the site. This is an example of why it is important to verify all power sources, shut off and disconnect power to each respective constant current regulator AND disconnect each respective airfield lighting series circuit/cutout and lockout/tagout the respective circuits.

12. Situation 12; An airport maintenance electrician was working on a taxi guidance sign during daylight hours. The maintenance electrician did not verify the respective series lighting circuit and did not practice lockout/tagout. The maintenance staff thought the respective circuit was off but mistakenly identified the wrong circuit. The maintenance electrician went to work on the taxi sign and received electric shock and required medical attention. The maintenance electrician did survive this incident. This is another example of why it is important to verify all power sources, shut off and disconnect power to each respective constant current regulator AND disconnect each respective airfield lighting series circuit/cutout and lockout/tagout the respective circuits. During the daylight all of the series circuits could have been shut down and not affected airfield operations. The safety of personnel is the most important issue.
13. Situation 13; An airfield maintenance staff person was troubleshooting an airfield lighting series circuit. They were in communication with the Air Traff Control Tower (ATCT) staff and having them turn the circuit off. They were not practicing lockout/tagout of the circuit and were relying on the Air Traffic Control Tower staff to tell them when the circuit was off. They requested the ATCT to turn off the circuit and the ATCT person reported back the circuit was off. The circuit had not been turned off as reported and the maintenance person died due to electrocution while working of the circuit. The point to this is, never trust someone else to shut off and lockout a circuit. You need to shut off and lockout circuits for your protection and safety.
14. Situation 14; In May 2019, it was observed during a vault survey that all of the Type SCO series circuit cutouts were wired incorrectly. This was reported to the head maintenance electrician at the Airport. The head maintenance electrician took a serious interest in this situation and requested directions for correction. The head maintenance electrician informed us that the reason he became the head maintenance electrician was because his previous supervisor had been electrocuted and died while working on an airfield lighting series circuit.
15. Situation 15; it was a very hot day in July 2011. The heat index was reported to be 122 degrees F. The actual temperature was observed on a local thermometer as 113 degrees F. An electrical contractor was working on an airfield lighting series circuit. People on site including engineering staff and contractor staff were getting overheated and it was affecting their judgement. One of the electricians received a phone call about a friend of his that was also an electrician and that was working on another nearby job site. This electrician had been electrocuted and died on the job site. The point is that weather conditions can create unsafe working conditions, and this always needs to be considered for the safety of personnel.
16. Situation 16; Please note when electrical/mechanical equipment and/or materials are energized after installation, repairs, relocation, maintenance, servicing, or

other applications there is a danger of arc flash, fire, or other unsafe conditions that might take place. When in the field observing work, stand clear of and do not look at electrical/mechanical equipment/materials when being turned on until it is confirmed to be safe and operating properly. Often during startups equipment can cause an arc flash, fire, or come apart due to defective components, incorrect wiring, failing or weakened components, incorrect application, or other factors that might affect the installation. This is a dangerous situation that can cause injury, fire, or death. Please make sure to always consider your safety and the safety of others. Many of these installations are restricted to qualified and authorized personnel only. Regardless of your qualifications you need to make sure your safety is always addressed.

17. Situation 17; When using a voltmeter to check if a circuit is live always check the meter first on a known live source to confirm the voltage meter is working properly. Many years ago, we (my supervisor at the time and myself) were working at a project site and were checking an electric service for the voltage and got no voltage reading on the voltmeter. We were pretty sure the service was active, so we checked again with a second voltmeter and got no voltage reading on the meter. We were not convinced this service was off and therefore checked it again with a third voltmeter and got no voltage reading on the meter. An electrician was on site, and we asked him about the service, and he used his voltmeter and confirmed the service was active. We had three different voltage meters that all had bad batteries and were giving false readings. Never assume an electrical system is off unless you have confirmation the system is shut off and have checked it with a known working voltage meter. Additionally, if you are not comfortable or qualified to use a voltage meter, leave that task to those that are qualified. Regardless of your qualifications you need to make sure your safety is always addressed.
18. Situation 18; During an airport electrical vault survey, we observed a Type S-1 series circuit plug cutout wired to a 120 VAC Circuit for use as a primary disconnect to a 120 VAC to 480 VAC step-up transformer. This is an unacceptable and dangerous practice. The Airport maintenance staff noted that each time they try to shut off the transformer it blows up. When the cutout plug is removed it causes a line to neutral fault (short circuit between phase conductor and neutral) and an arc flash. This puts the personnel at risk of injury, burns, and harm. The series circuit cutout in this application needs to be disconnected, removed, and replaced with a heavy duty 30 Amp, 240 VAC, 2 pole, safety switch suitable for the 120 VAC power application. Series circuit plug cutouts shall only be used on airfield lighting series circuits in accordance with the respective manufacturer's instructions.
19. Situation 19; An Airport Manager contacted us and noted the circuit breaker had tripped for their main runway lighting constant current regulator. This was during the summer on a day when the ambient temperature was 103 degrees Fahrenheit. It was suggested that they check the Airport Vault building fan to make sure it was operating properly. The Airport Manager confirmed the fan was operating. A few minutes later the Airport Manager called and noted that he discovered they had a filter on the intake air louver, and it was completely clogged with dirt. The Airport Manager noted they were not aware that this intake air louver included a filter and that it might not have been changed since

the original installation of the Airport Vault building. Note it is important that constant current regulators have adequate air flow and cooling to accommodate proper operation. Confirm ventilation and cooling systems are in proper working order.

20. Situation 20; Two electricians were troubleshooting an airfield lighting series circuit. Both were experienced electricians with more than 30 years of experience each but had little knowledge and experience with constant current regulators. They put a 600 Volt rated voltmeter across the output terminals of the constant current regulator and blew up the meter. The electricians were not aware that the maximum output voltage for the 7.5 KW constant current regulator was over 1100 Volts. Neither electrician was harmed, but the voltage meter was destroyed. It is recommended to include an output voltage meter on constant current regulators for testing, maintenance, and troubleshooting purposes. This is an optional feature, not a standard feature, and therefore needs to be included with the specification for the respective regulator. Having an output voltage meter on the regulator identified would have helped avoid the unsafe condition that occurred.

SAFETY OF PERSONNEL IS THE PRIORITY ON THE JOB. PLEASE ALWAYS PRACTICE SAFETY PROCEDURES FOR THE PROTECTION OF PERSONNEL.

END OF ITEM 125

ITEM AR125620 ABBREVIATED PAPI (L-881 SYSTEM)

DESCRIPTION

125620-1.1 This item of work shall consist of furnishing and installing Abbreviated (L-881(L) Light Emitting Diode) Precision Approach Path Indicators (PAPI's) and the associated foundations, concrete, conduits, ducts, wiring, splice cans and grounding at the locations shown on the Construction Plans. Each installation will be in accordance with the details on the Plans and these Special Provisions. This item shall include the circuit breakers, wire, labeling, legend plates, and associated electrical materials and labor in the Airport Electrical Vault, necessary to power the PAPI systems. Also included in this item will be the testing of the installation and all incidentals necessary to place each respective PAPI system into proper operation and to the satisfaction of the Engineer.

125620-1.2 REFERENCES. Note: where FAA Advisory Circulars are referenced, they shall be the current issue or issues in effect.

- A. ANSI C80.1 – Rigid Steel Conduit, Zinc Coated.
- B. ANSI C80.3 – Steel Electrical metallic Tubing (EMT).
- C. ANSI C80.4 – Fittings Rigid Metal Conduit and EMT.
- D. FAA AC No. 150/5340-30 (current issue in effect) “DESIGN AND INSTALLATION DETAILS FOR AIRPORT VISUAL AIDS.”
- E. FAA AC No. 150/5345-28 (current issue in effect) “PRECISION APPROACH PATH INDICATOR (PAPI) SYSTEMS”
- F. FAA AC 150/5345-42 (current issues in effect) “Specification for Airport Light Bases, Transformer Housings, Junction Boxes, and Accessories”
- G. FAA AC No. 150/5345-53 “AIRPORT LIGHTING EQUIPMENT CERTIFICATION PROGRAM” (current issue in effect) and AC 150/5345-53D, AIRPORT LIGHTING EQUIPMENT CERTIFICATION PROGRAM Appendix 3 Addendum (current issue in effect).
- H. FAA AC No. 150/5370-2 (current issue in effect) “OPERATIONAL SAFETY ON AIRPORTS DURING CONSTRUCTION.
- I. NEMA TC-2 – Electrical Plastic Tubing and Conduit.
- J. NEMA TC-3 – Fittings Rigid PVC Conduit and Tubing.
- K. NFPA 70 – National Electrical Code (most current issue in force).
- L. NFPA 70E – Standard for Electrical Safety in the Workplace
- M. NFPA 2638645-1 = National Fire Protection Association IDN.

- N. OSHA 29 CFR Part 1910 Occupational Safety and Health Standards for electrical safety and lockout/tagout procedures
- O. UL Standard 6 – Rigid Metal Conduit.
- P. UL Standard 467 – Grounding and Bonding Equipment.
- Q. UL Standard 486A-486B Wire Connectors.
- R. UL Standard 514B – Conduit, Tubing and Cable Fittings.
- S. UL Standard 651 – Schedule 40 and 80 Rigid PVC Conduit.

125620-1.3 SHOP DRAWINGS. The Contractor shall furnish shop drawings for approval before ordering equipment and/or materials. Shop drawings are required for PAPI units and materials to be used on the project. **Shop drawings shall be clear and legible. Copies that are illegible will be rejected.** The preferred shop drawing submittal format shall be electronic (PDF) copies. Shop drawings shall include the following information:

- A. In order to expedite the shop drawing review, inspection and/or testing of materials and equipment, the Contractor shall furnish complete statements to the Project Engineer of Record as to the origin and manufacturer of all materials and equipment to be used in the work. Such statements shall be furnished promptly after execution of the contract but, in all cases, prior to delivery of such materials and equipment.
- B. Provide certification that steel products are manufactured in the USA from domestic steel to comply with the Steel Products Procurement Act (30 ILCS 565).
- C. Provide cut sheets and specifications for the PAPI's.
- D. Concrete mix design.
- E. Provide cut sheets for L-867 light bases.
- F. Provide cut sheets with manufacturer's name, catalog number, dimensions, material and UL listing for each type and size ground rod. Include certification of 100% domestic steel for ground rods. Include cut sheets for exothermic weld connections, ground lugs, and ground wire.
- G. Provide cut sheets for all types of conduits used with the PAPI installation (for example galvanized rigid steel conduit, EMT, and liquid-tight flexible metal conduit). Include certification that steel conduits are made with 100 percent domestic steel.
- H. Provide cut sheets for reinforcing steel. Include certification that reinforcing steel is made with 100 percent domestic steel.

EQUIPMENT AND MATERIALS

125620-2.1 PAPI UNITS. The light units and power and control unit for the PAPI shall meet the requirements of FAA AC 150/5345-28 (current issue if effect) FAA approved, Type L-881(L) (System consisting of 2 light units with Light Emitting Diode type illumination), Style A (Voltage powered system suitable for operation on a nominal 240 VAC, 60 Hertz, single phase, 2-wire system), Class I (Systems that operate from -31 degrees Fahrenheit (F) (-35 degrees Celsius [C]) to 131 degrees F (55 degrees C)). Baffles will be required to set the limits of the obstacle clearance surface to 10 degrees either side of the runway centerline (20 degrees total) to restrict excess horizontal light distribution, in accordance with FAA AC 150/5340-30J, Figure A-81 PAPI Obstacle Clearance Surface.

125620-2.3 POWER AND CONTROL CABLE. Power cables from the respective power source to the respective PAPI installation shall be sized as detailed on the Plans and in conformance with Item 108. Power and control cable between the PAPI light units shall be as recommended by the respective PAPI manufacturer.

125620-2.4 CONDUIT AND DUCTS. Conduit and ducts for the PAPI systems shall conform to Item 110, per manufacturer's recommendations, as detailed on the Plans, and as specified herein.

- A. Conduit for power and control cables between the PAPI units shall be 2-inch Galvanized Rigid Steel Conduit with threaded fittings, or larger where required by NEC and/or manufacturer's recommendations for the respective cables. GRSC shall be heavy wall, hot-dipped, galvanized steel pipe bearing the UL label and conforming to UL-6 and ANSI Specification C80.1. Couplings, connectors, and fittings for rigid steel conduit shall be threaded galvanized steel or galvanized malleable iron specifically designed and manufactured for the purpose. Fittings shall conform to ANSI C80.4 and UL-514B. Galvanized rigid steel conduit shall be produced from 100 percent domestic steel. Contractor shall provide certification that the respective steel conduits used on this project are manufactured from 100 percent domestic steel.
- B. Electrical Metallic Tubing (EMT) shall be used for the PAPI mounting legs. EMT shall be galvanized steel tubing conforming to ANSI C80.3 and U.L. 797. All EMT and mounting hardware shall be constructed of corrosion resistant materials and be listed for use in wet locations. EMT fittings, couplings and connectors shall be steel compression type. Set screw fittings will not be allowed. Steel used to manufacture conduits shall be 100 percent domestic steel. Contractor shall provide certification that the respective steel conduits used on this project are manufactured from 100 percent domestic steel.
- C. Liquid-Tight Flexible Metal Conduit. Liquid-tight, flexible metal conduit shall consist of polyvinyl jacket over flexible hot dip galvanized steel tubing. The flexible conduit shall be completely sealed from liquids, dust, dirt, and fumes and be resistant to oil, gasoline, grease, and abrasion. Jacket shall also be sunlight-resistant. Liquid-tight flexible metal conduit shall be UL-listed, suitable for use as a grounding conductor, and comply with Article 350 of the NEC. Liquid-tight flexible metal conduit and associated fittings shall be UL-listed to meet the requirements of NEC 350.6. Liquid-tight flexible metal conduit shall be Anaconda Sealtite Type UA as manufactured by Anamet Electrical Inc., Liqueatite Type LA as manufactured by Electri-Flex Company, Liquid-Tuff Type LFMC as manufactured by Atkore International AFC Cable Systems, or approved equal. Do not install liquid-tight, flexible metal conduit that is not UL listed. Confirm liquid-tight, flexible

metal conduit bears the UL label prior to installation. Steel used to manufacture conduits shall be 100 percent domestic steel. Contractor shall provide certification that the respective steel conduits used on this project are manufactured from 100 percent domestic steel.

- D. Conduits for grounding electrode conductors shall be Schedule 80 (minimum) PVC, UL-listed, rated for 90°C cable-conforming to NEMA Standard TC-2 and UL 651, listed suitable for concrete encasement and direct burial in earth.

125620-2.5 SPLICE CANS. Splice cans shall conform to the requirements of FAA AC 150/5345-42 (current issues in effect) for Type L-867, Class IA, Size B (12-inch nominal diameter), 24-inch deep. Splice/transformer cans shall have 2" hubs at 0 degrees and at 180 degrees. Splice cans shall have galvanized steel or aviation yellow powder coat painted steel covers, 3/8 inch thick, or as recommended by the respective PAPI manufacturer where the splice can is installed at the PAPI installation. Coordinate selection of L-867 covers and hub/hole openings with the respective PAPI manufacturer to ensure compatibility with each respective PAPI unit. Include internal and external ground lugs on each L-867 splice can.

125620-2.6 ANTI-SEIZE COMPOUND. The Contractor shall apply an oxide-inhibiting, anti-seizing compound to all screws, nuts, breakable coupling, and all places where metal comes into contact with metal.

125620-2.7 STAINLESS STEEL BOLTS. All base plate-mounting bolts shall be stainless steel.

125620-2.8 GROUND RODS. Ground rods shall be 3/4-inch diameter by 10-feet long UL listed copper clad, with 10-mil minimum copper coating. Steel used to manufacture ground rods shall be 100 percent domestic steel.

125620-2.9 CONCRETE. Concrete associated with the each PAPI foundation piers/pad and/or splice can shall conform to Item 610 Portland Cement Concrete of the Standard Specifications for Construction of Airports and as detailed on the Plans.

125620-2.10 CIRCUIT BREAKERS. Circuit breakers, to be installed in the existing vault panelboard, shall be compatible with the existing panelboard. Circuit breakers shall be bolt-on type with an amp interrupting capacity of 10,000 Amps minimum at 120/240 VAC. Circuit breaker amperage trip settings and number of poles shall be as detailed on the Plans. Existing spare breakers in the Vault may be used where available and where they are the proper size for the application.

125620-2.11 THWN WIRE. Cable shall comply with Underwriters' Laboratories Standard UL-83 and Federal Specification A-A-59544. The conductor shall be soft-annealed, uncoated Copper and shall comply with ASTM B3 and B8. Insulation shall be rated for 600-Volt. The insulation shall be polyvinyl-chloride conforming to Underwriters' Laboratories requirements for Type THW. The outer covering shall be nylon-conforming to Underwriters' Laboratories for type THHN or THWN. Cable shall be UL-listed and marked THWN.

CONSTRUCTION METHODS

125620-3.1 INSTALLATION OF PAPI SYSTEMS. Installation of PAPI systems shall conform to FAA AC No. 150/5345-28 (current issue in effect) titled "PRECISION APPROACH PATH

INDICATOR (PAPI) SYSTEMS” and the respective manufacturer’s instructions, as detailed on the Plans, and as specified herein. The Contractor shall construct concrete bases for the PAPI system units per manufacturer’s instructions and recommendations and/or as shown on the Construction Plans. All bolt placements will be as per manufacturer’s recommendations. The structural legs shall have breakable couplings not more than 2 in. from the top of the respective base/foundation. Coordinate conduit installations into the bases as applicable for power, control, and/or grounding cable conduits. The power control unit shall be installed in the location shown on the Plans. The poles/support posts installed to support the unit will be anchored in concrete typical to the PAPI base, and each pole/support post shall have a breakable coupling not more than 2 in. from the top of the concrete base/foundation.

The PAPI units shall be installed and aimed in accordance with manufacturer’s specifications and instructions. The aiming angles shall comply with those shown on the Plans.

The Contractor will install all the required electrical equipment and materials in the electrical vault to place the proposed PAPI units into operation. The furnishing and installing of electrical equipment and materials in the vault will be incidental to the respective PAPI pay item and no additional compensation will be allowed.

125620-3.2 ELECTRICAL. The Contractor shall furnish and install all electrical materials necessary for the complete and operational installation of the PAPI systems as shown on the plans and detailed herein. The complete installation and wiring shall be done in a neat, workmanlike manner. All electrical work shall comply with the requirements of the NFPA 70 - National Electrical Code (NEC) most current issue in force. Electrical equipment and materials shall be installed in conformance with the respective manufacturer’s directions and recommendations for the respective application. Any installations which void the UL listing, Intertek Testing Services verification/ETL listing, (or other third-party listing), and/or the manufacturer’s warranty of a device will not be permitted.

- A. Keep a copy of the latest NEC in force on site at all times during construction for use as a reference. Contractor shall keep a copy of the Plans, Special Provision Specifications including any addenda, and copies of any change orders on site at all times during construction.
- B. Examine the site to determine the extent of the work. Contractor shall field verify existing site conditions and follow safety procedures for protection of personnel. All work, power outages, and/or shutdown of existing systems shall be coordinated with the Airport Manager and the Resident Engineer/Resident Technician. Any shutdown of existing systems shall be scheduled with and approved by the Airport Manager prior to shutdown. Once shut down, the circuits shall be labeled as such to prevent accidental energizing of the respective circuits. All personnel shall follow U.S. Department of Labor Occupational Safety & Health Administration (OSHA) 29 CFR Part 1910 Occupational Safety and Health Standards for electrical safety and lockout/tagout procedures including, but not limited to, 29 CFR section 1910.147 The Control of Hazardous Energy (lockout/tagout).
- C. Verify respective circuits and power sources prior to removing, disconnecting, relocating, installing, connecting, or working on the respective airfield lighting, taxi sign, NAVAID, or other device. Identify each respective circuit prior to performing work on that circuit.
- D. Install PAPI’s and other airfield lighting devices in accordance with the details shown on the Construction Plans.

- E. New cable shall be furnished from the Vault to each respective PAPI system as detailed on the Plans and Specified herein. The cable will be paid for under Item 108.
- F. Locate existing underground utilities, cables and lines. The location, size, and type of material of existing underground and/or aboveground utilities indicated on the Plans are not represented as being accurate, sufficient, or complete. Neither the Owner nor the Engineer assumes any responsibility whatsoever in respect to the accuracy, completeness, or sufficiency of the information. There is no guarantee, either expressed or implied, that the locations, size, and type of material of existing underground utilities indicated are representative of those to be encountered in the construction. It shall be the Contractor's responsibility to determine the actual location of all such facilities, including service connections to underground utilities. Prior to construction, the Contractor shall notify the utility companies of his operational plans, and shall obtain, from the respective utility companies, detailed information and assistance relative to the location of their facilities and the working schedule of the companies for removal or adjustment, where required. In the event an unexpected utility interference is encountered during construction, the Contractor shall immediately notify the utility company of jurisdiction. The Owner's Representative and/or the Resident Engineer/Technician shall also be immediately notified. Any damage to such mains and services shall be restored to service at once and paid for by the Contractor at no additional cost to the Contract. All utility cables and lines shall be located by the respective utility. Also coordinate work with all aboveground utilities.
- G. Identify, secure, and place any above ground temporary wiring in conduit to prevent electrocution and fire ignition sources in conformance with the requirements of FAA AC 150/5370-2G, Part 2.18.3 "Lighting and Visual NAVAIDs". All temporary installations shall comply with National Electrical Code Article 590 – "Temporary Installations."
- H. Grounding work and modifications shall not be performed during a thunderstorm or when a thunderstorm is predicted in the area.
- I. Homerun cables for a respective circuit that are installed in conduit or duct shall be run together in the same raceway or duct.
- J. The respective personnel performing airfield lighting work, vault work, and/or test shall be familiar with, and qualified to work on 5000 Volt airfield lighting series circuits, constant current regulators and associated airport electrical vault equipment.
- K. FAA requires that every airfield lighting cable splicer shall be qualified in making cable splices and terminations on cables rated at and/or above 5000 Volts AC and shall have a minimum of three (3) years continuous experience in terminating/splicing medium voltage cable.
- L. Obey and comply with the applicable requirements of NFPA 70E – Standard for Electrical Safety in the Workplace.
- M. Other construction projects might be in progress on the Airport at the same time as this project. The Contractor will be required to cooperate with all other contractors and the Airport Manager in the coordination of the work.

- N. The Contractor shall comply with the requirements of FAA AC No. 150/5370-2 (current issue in effect) "OPERATIONAL SAFETY ON AIRPORTS DURING CONSTRUCTION".
- O. In the event a conflict is determined with respect to manufacturer installation instructions, National Electrical Code, and/or the Contract Documents, contact the Project Engineer of Record for further directions.
- P. See Safety Plan and Notes for safety and construction coordination requirements.
- Q. Existing ducts and cables associated with PLASI removals or other removal work shall be removed where accessible and abandoned in place elsewhere unless it conflicts with the installation of the Navaid, airfield light, sign, duct, cable, handhole, manhole, site work, pavement or other work, then it shall be disconnected, removed, and disposed of off the site at no additional cost to the Contract. Contractor may remove abandoned cables at no additional cost to the Contract and shall have the salvage rights to abandoned cables.
- R. Obtaining the required borrow material from an offsite borrow, placing the borrow material, grading, seeding, and mulching the disturbed areas will be considered as an Incidental Item to the proposed work items and/or removal work and no additional compensation will be allowed.
- S. Route new cables and ducts to avoid interferences with other lines, utilities, cables, ducts, and structures.
- T. When a respective runway is closed the runway lighting and Nav aids for that runway shall be shut off. Keep respective Nav aids active during times when respective runway is open. Nav aids receiving maintenance shall be shut off until operating properly.
- U. All changes to the airfield lighting system control wiring will be documented by the Contractor and provided to the Resident Engineer/Resident Technician.

125620-3.3 CABLE INSTALLATION FOR PAPI'S. Installation of cables shall conform to Item 108, the applicable sections of FAA AC 150/5345-28 (current issue in effect), per the respective equipment manufacturer's recommendations, and as detailed on the Plans. Power and control cables from the PAPI Power and Control Unit, or PAPI Primary Unit (Light Unit with Integral Power and Control Unit), to the PAPI light units and between the PAPI light units shall be installed in 2-inch galvanized rigid steel conduit, or larger where required by NEC and/or manufacturer's recommendations for the respective cables.

125620-3.4 CONDUIT INSTALLATION FOR PAPI'S. Installation of conduit shall conform to Item 110, the respective PAPI manufacturer's installation instructions and/or recommendations, as detailed on the Plans and as specified herein. Coordinate conduit installations into the PAPI foundations and/or L-867 splice cans.

125620-3.5 GROUNDING FOR PAPI'S. Grounding for PAPI's shall conform to the respective PAPI manufacturer's installation instructions, as detailed on the Plans, and as specified herein. The power circuit to each PAPI unit shall include an equipment ground wire of the same size and type as the phase conductors. Furnish and install a 3/4-inch diameter by 10-foot long copper clad ground rod at each PAPI lighting unit. Bond each PAPI unit and the respective L-867 splice can to the respective ground rod with a #6 AWG stranded copper grounding

electrode conductor. Top of ground rods shall be buried approximately 24 inches below grade. All connections to ground rods shall be made with exothermic weld-type connectors; Cadweld by Pentair Erico Products, Thermoweld, Ultraweld by Harger, or approved equal. Connections to L-867 splice cans shall be with UL listed grounding connectors suitable for use in direct burial or concrete encasement applications. Connections to PAPI unit frame shall be as recommended by the manufacturer or with a UL listed grounding connector. All ground rods associated with the complete PAPI installation shall be bonded to together with a #6 AWG solid copper counterpoise conductor. This counterpoise conductor shall be installed in the same trench located 10 inches above the power and control conductors, between each respective PAPI unit.

125620-3.6 GROUNDING REQUIREMENTS. Grounding shall conform to the following as applicable: The Contractor shall furnish and install all grounding shown on the Plans and/or as may be necessary or required to make a complete grounding system, as required by the latest NFPA 70 – National Electrical Code in force. The reliability of the grounding system is dependent on careful, proper installation, and choice of materials. Improper preparation of surfaces to be joined to make an electrical path, loose joints, or corrosion can introduce impedance that will seriously impair the ability of the ground path to protect personnel and equipment and to absorb transients that can cause noise in communications circuits. The following functions are particularly important to ensure a reliable ground system:

- A. All products associated with the grounding system shall be UL-listed and labeled.
- B. All bolted or mechanical connections shall be coated with a corrosion-preventative compound before joining, Sanchem Inc. “NO-OX-ID “A-Special” compound, Burndy Penetrox E, or approved equal.
- C. Metallic surfaces to be joined shall be prepared by the removal of all non-conductive material, per 2020 NEC Article 250-12. All copper bus bars must be cleaned prior to making connections to remove surface oxidation.
- D. Metallic raceway fittings shall be made up tight to provide a permanent low impedance path for all circuits. Metal conduit terminations in enclosures shall be bonded to the enclosure with UL-listed fittings suitable for grounding. Provide grounding bushings with bonding jumpers for all metal conduits entering service equipment (meter base, CT cabinet, main service breaker enclosure, etc.), generator breaker enclosures, and automatic transfer switch enclosures. Provide grounding bushings with bonding jumpers for all metal conduits entering an enclosure through concentric or eccentric knockouts that are punched or otherwise formed so as to impair the electrical connection to ground. Standard locknuts or bushings shall not be the sole means for bonding where a conduit enters an enclosure through a concentric or eccentric knockout.
- E. Furnish and install ground rods at all locations where shown on the Plans or specified herein. Ground rods shall be spaced, as detailed on the Plans, and in no case spaced less than one rod length apart. All connections to ground rods and/or buried grounding electrode conductors shall be made with exothermic weld-type connectors; Cadweld by Pentair Erico Products, Thermoweld, Ultraweld by Harger, or approved equal. Exothermic-weld connections shall be installed in conformance with the respective manufacturer’s directions using molds, as required for each respective application. Bolted connections will not be permitted at ground rods or at buried grounding electrode conductors.

- F. All connections, located above grade, between the different types of grounding conductors shall be made using UL-listed, double-compression, crimp-type connectors or UL-listed, bolted ground connectors. For ground connections to enclosures, cases, and frames of electrical equipment not supplied with ground lugs, the Contractor shall drill required holes for mounting a bolted, ground connector. All bolted, ground connectors shall be Burndy, Thomas and Betts, or approved equal. Tighten connections to comply with tightening torques in UL Standard 486A to assure permanent and effective grounding.
- G. All metal equipment enclosures, conduits, cabinets, boxes, receptacles, etc. shall be bonded to the respective grounding system.
- H. Each new feeder circuit and/or branch circuit shall include an equipment ground wire. Metal raceway or conduit shall not meet this requirement. The equipment ground wire from equipment shall not be smaller than allowed by 2020 NEC Table 250-122 "Minimum Size Conductors or Grounding Raceway and Equipment." When conductors are adjusted in size to compensate for voltage drop, equipment-grounding conductors shall be adjusted proportionately according to circular mil area. All equipment ground wires shall be copper, either bare or insulated, green in color. Where the equipment grounding conductors are insulated, they shall be identified by the color green, and shall be the same insulation type as the phase conductors.
- I. Install grounding electrode conductors and/or individual ground conductors in Schedule 80 PVC conduit. Coordinate the installation of PVC conduit sleeves into the PAPI foundations to accommodate grounding electrode conductor installations from the respective PAPI unit to the respective ground rod.
- J. Grounding work affecting operations at a facility shall be coordinated with the Owner's Representative and to minimize downtime to existing systems. Contractor shall coordinate work and any power outages with the Owner's Representative. Any shutdown of existing systems shall be scheduled with and approved by the Owner's Representative prior to shut down. All power systems (AC or DC) shall have provisions to lockout and tagout any circuit to help ensure the circuit is safe to work on for protection of personnel. Once shut down, the circuits shall be labeled as such to prevent accidental energizing of the respective circuits. All personnel shall follow U.S. Department of Labor Occupational Safety & Health Administration (OSHA) 29 CFR Part 1910 Occupational Safety and Health Standards for electrical safety and lockout/tagout procedures including, but not limited to, 29 CFR section 1910.147 The Control of Hazardous Energy (lockout/tagout). Where a facility does not have lockout/tagout kits the Contractor shall provide adequate quantities of lockout/tagout kits suitable for use with the respective equipment. Where existing electrical equipment does not have features for lockout/tagout the Contractor will be responsible for providing the appropriate lockout/tagout equipment and measures to ensure the safety of personnel. All padlocks for use with lockout/tagout procedures shall have a different key. Provide lockout hasps to accommodate multiple padlocks where multiple people are working on the same system. Include lockout tags for each piece of equipment requiring servicing and shutdown. Compliance with Lockout/Tagout Procedures and all other safety procedures and requirements are the responsibility of the respective personnel working at the facility.
- K. Never remove, alter, or attempt to repair conductors or conduit systems providing grounding or electrical bonding for any electrical equipment until all power is removed from the equipment. Warn all personnel of the ungrounded condition of the equipment. Display appropriate warning signs, such as danger tags, to warn personnel of the possible hazards.

- L. Grounding work and modifications shall not be performed during a thunderstorm or when a thunderstorm is predicted in the area.
- M. Per NFPA 70E Standard for Electrical Safety in the Workplace it defines Electrically Safe Work Condition as “A state in which an electrical conductor or circuit part has been disconnected from energized parts, locked/tagged in accordance with established standards, tested to verify the absence of voltage, and, if necessary, temporarily grounded for personnel protection.” Prior to conducting tests or working on equipment, verify equipment enclosures and frames have a good and secure ground connection for the safety of personnel.
- N. Where a conflict is determined with respect to grounding requirements per manufacturer installation instructions, National Electrical Code, and/or the Contract Documents, or there are other questions or concerns about the grounding requirements contact the Project Engineer of Record: Kevin Lightfoot for further directions. Safety of personnel is the top priority.

125620-3.7 PAPI OPERATION. The PAPI units shall be on 24 hours per day, 7 days a week.

125620-3.8 RESTORATION. All turf areas disturbed by the installation of the PAPI system and associated work shall be restored, graded, and seeded to establish a stand of grass to the satisfaction of the Engineer and will be considered as incidental to the installation of the PAPI, unless detailed otherwise herein.

125620-3.9 INSTRUCTION OF AIRPORT STAFF. Contractor shall provide instruction to airport staff in regard to the operation and maintenance of the PAPI system. Contractor shall demonstrate operating procedures, and items requiring routine maintenance. Provide Operation, Installation, and Maintenance Manuals for the respective PAPI systems.

125620-3.10 GROUND CHECK. Prior to final acceptance and activation, each completed PAPI system will be ground checked by the Resident Engineer/Resident Technician and/or Illinois Division of Aeronautics, and it shall be the Contractor's responsibility to have a representative present to make any necessary adjustments and/or corrections of the respective PAPI system installation. Ground check will be scheduled after the PAPI is installed and ready for check out. The ground check often includes confirmation and measurement of aiming angle of the PAPI, testing the PAPI, measurement of input voltage, measurement of input current, testing the photocell, confirmation of proper grounding, operational tests, and other tests. The Contractor shall be responsible for providing PAPI installations that pass the ground check. A copy of the PAPI Ground Check List is included in the Appendix.

125620-3.11 FLIGHT CHECK. Prior to final acceptance and activation, each completed PAPI system will be flight checked by Federal Aviation Administration and/or Illinois Division of Aeronautics, and it shall be the Contractor's responsibility to have a representative present to make any necessary adjustments in the aiming of the PAPI units. The flight check will be scheduled after the PAPI has passed the ground check. The Contractor shall be responsible for providing a PAPI installation that passes the respective flight check by Federal Aviation Administration. **Note the FAA will pay the costs for one flight check. In the event that additional flight checks are required, the costs associated with the additional flight checks will be the responsibility of and paid for by the Contractor.**

METHOD OF MEASUREMENT

125620-4.1 The 2 Box PAPI systems to be furnished and installed shall be measured for payment as a unit price per each and shall include a Type L-881(L) system consisting of two light units, all concrete and materials as required for foundations, all cable and conduit between and/or at the PAPI lighting units, grounding, splice cans, equipment, excavating, labor, tools, aiming and calibration equipment, testing, and incidentals necessary to furnish a complete and operational PAPI system as approved by the Resident Engineer/Resident Technician. The furnishing and installing of electrical equipment and materials in the vault will be incidental to the respective PAPI pay item and no additional compensation will be allowed.

All lockout/tagout procedures to ensure and maintain safety of personnel will be considered incidental to the respective item of work for which it applies, and no additional compensation will be allowed.

All vault or other equipment labeling, legend plates, arc flash risk labels, arc-flash hazard warning labels, and other equipment identification as detailed on the Plans and as specified herein will be incidental to the respective PAPI pay item and no additional compensation will be allowed.

Ground rods, grounding electrode conductors, connections, and associated grounding work included with PAPI systems will be considered incidental to the respective item for which they are installed, and no additional compensation will be made.

Ground resistance tests for the made electrode ground system at each PAPI unit will be considered incidental to the respective PAPI and no additional compensation will be allowed.

Testing the airfield lighting systems and the associated constant current regulator tests and cable tests will be considered incidental to the Contract and no additional compensation will be allowed.

Conduits, conduit nipples, conduit couplings, and other conduit fittings included with splice cans, junction structures, Navaid installations, base mounted airfield light fixtures, and/or other airfield fixtures, will be considered incidental to the respective item for which they are installed, and no additional compensation will be made.

BASIS OF PAYMENT

125620-5.1 Payment shall be made at the contract unit price per each. This price and payment shall be full compensation for furnishing and installing the PAPI and all associated equipment and materials, for all excavating, labor, tools, equipment, and incidentals necessary to complete this item of work. The furnishing and installing of electrical equipment and materials in the vault will be incidental to the respective PAPI pay item and no additional compensation will be allowed. Cable in duct or unit duct from the respective power source to the respective PAPI installation shall be paid for under item 108.

Payment will be made under:

Item AR125620 Abbreviated PAPI (L-881 System) - per EACH

Item AS125620 Abbreviated PAPI (L-881 System) - per EACH

END OF ITEM AR125620

ITEM AT/AU125910 REMOVE PLASI

DESCRIPTION

125910-1.1. This item of work shall consist of the removal of the existing PLASI (Pulsi Light Approach Slope Indicator) units in accordance with the details in the Construction Plans and in accordance with these Special Provisions.

125910-1.2 REFERENCES. Note: where FAA Advisory Circulars are referenced, they shall be the current issue or issues in effect.

- A. FAA AC No. 150/5370-2 (current issue in effect) "OPERATIONAL SAFETY ON AIRPORTS DURING CONSTRUCTION.
- B. NFPA 70E – Standard for Electrical Safety in the Workplace
- C. OSHA 29 CFR Part 1910 Occupational Safety and Health Standards for electrical safety and lockout/tagout procedures

CONSTRUCTION

125910-2.1 REMOVAL OF PLASI.

- A. Contractor shall examine the site to determine the extent of the work. Contractor shall field verify existing site conditions. Contractor shall field verify the respective circuits and power sources prior to removing, disconnecting, relocating, working on, or connecting the respective PLASI unit, NAVAID, circuit, Vault equipment, or other device.
- B. Contractor shall coordinate work and any power outages with the Airport Manager, the respective Airport personnel, and the Resident Engineer/Resident Technician. Any shutdown of existing systems shall be scheduled with and approved by the Airport Manager prior to shutdown. Once shut down, the circuits shall be labeled as such to prevent accidental energizing of the respective circuits. All personnel shall follow U.S. Department of Labor Occupational Safety & Health Administration (OSHA) 29 CFR Part 1910 Occupational Safety and Health Standards for electrical safety and lockout/tagout procedures, including, but not limited to, 29 CFR Section 1910.147 The Control of Hazardous Energy (lockout/tagout).
- C. Contractor shall comply with the requirements of FAA AC No. 150/5370-2 (current issue in effect) "OPERATIONAL SAFETY ON AIRPORTS DURING CONSTRUCTION".
- D. Contractor shall comply with the applicable requirements of NFPA 70E – Standard for Electrical Safety in the Workplace.
- E. Removal of a PLASI unit shall include the removal of the PLASI, foundation, associated safety switch, conduits, wiring, associated step-up transformers, step-down transformers and/or boost transformers, circuit breakers, and associated equipment and materials in the Airport Electrical Vault.

- F. Power for each respective PLASI system shall be disconnected at the respective power source prior to removing the respective PLASI system. **Power for the existing PLASI systems located on Runway 9-27 are understood to be powered from the Airport Electrical Vault.** The Contractor shall field verify to confirm the respective power source for each PLASI system.
- G. The Contractor shall remove the PLASI units when the runway is closed. The Contractor shall remove the PLASI units and turn them over to the Airport. In the event that the Airport does not want the PLASI units, the Contractor shall dispose of the PLASI units off the Airport site in a legal manner. The Contractor shall coordinate with and notify the Airport Manager and the Resident Engineer/Resident Technician and provide a schedule for PLASI removals and the new PAPI installations. The Contractor shall remove the existing PLASI bases and dispose of them off the airport site in a legal manner. The existing electrical cables from the vault shall be disconnected, removed where accessible or in conflict with new work and abandoned in place elsewhere. The holes left from the removal of the concrete bases will be filled with earth material. The earth material will be compacted to prevent any future settlement. The earth material will be obtained from off the Airport site. The disturbed area will be restored, graded, and seeded to the satisfaction of the Engineer, and will be considered as an incidental item to the removal of the PLASI units.
- H. Existing airfield lighting cables associated with airfield lighting to be removed shall be removed where accessible and abandoned in place elsewhere unless it conflicts with new work and then it shall be removed at no additional cost to the Contract. If the Contractor elects to salvage the cable within the circuit to be removed, shown in the Construction Plans as cable to be abandoned, any cost associated with removal of the cable shall be considered incidental to the Contract and no additional compensation will be allowed.
- I. Remove existing ground rods associated with the PLASI systems to be removed.
- J. All turf areas disturbed by the removal of PLASI systems and associated work shall be restored, graded, and seeded to establish a stand of grass to the satisfaction of the Engineer. All areas disturbed by work shall be restored to its original condition. The hole left from the removal of each base/foundation shall be filled with earth material. The earth material shall be compacted to prevent any future settlement. The earth material shall be obtained from off the Airport site. The restoration shall include any necessary topsoiling, fertilizing, liming, seeding, or mulching, as shown on the plans. The Contractor shall be held responsible for maintaining all disturbed surfaces and replacements until final acceptance. Restoration shall be considered incidental to the pay item of which it is a component part.

BASIS OF PAYMENT

125910-3.1. This work will be paid for at the contract unit bid price per each for PLASI Removal. This price and payment shall constitute full compensation for field verification of existing site conditions and power sources, disconnecting the respective power sources, removing the existing PLASI units; removal of bases, foundations, mounting hardware, cables, ducts, conduits, transformers and associated vault equipment and materials; for all excavating and backfilling; for furnishing all earth material; for all restoration work; and for furnishing all coordination, labor, tools, equipment, and incidentals necessary to complete this item of work. Salvageable materials shall be turned over to the Airport. Any materials not salvaged by the Airport shall be legally disposed of off the Airport site by the Contractor at no additional cost to the Contract.

Payment will be made under:

Item AT125910 Remove PLASI - per EACH
Item AU125910 Remove PLASI - per EACH

END OF ITEM AR125910

END OF SPECIAL PROVISIONS

APPENDIX A

PRG-Edgar County Airport
Paris, Illinois

PRG-4981
Replace Runway 9/27
Pulse Light Approach Slope Indicators (PLASI's)
with Precision Approach Path Indicators (PAPI's)

Constant Current Regulator and
Cable Testing Forms

Engineering Firm	Hanson Professional Services Inc.
Airport Name	PRG-Edgar County Airport
Project	Replace Runway 9/27 PLASI's with PAPI's
IDA Project	PRG-4981
Hanson Project	21A0164C
Date	

TESTING FORMS

Prior to beginning airfield lighting removals, modifications, replacements, and/or cable installation all existing series circuit cables shall be Megger tested with an insulation resistance tester and recorded at the vault. All existing series circuit cable loops shall have the resistance measured with an Ohmmeter and recorded for each circuit at the vault. Each constant current regulator shall be tested with results recorded. Note: output voltage measurements are not required for constant current regulators that are not equipped with output voltage meters. Provide a True RMS Ammeter for current measurements.

Insulation resistance testing equipment for use with 5,000 Volt series circuit cables shall use an insulation resistance tester capable of testing the cables at 5,000 Volts. Older series circuit cables and/or cables in poor condition may require the test voltage to be performed at a voltage lower than 5,000 Volts (Example 1,000 Volts, 500 Volts, or less than 500 Volts). The respective test voltage shall be recorded for each cable insulation resistance test result.

Insulation resistance testing equipment for use with 600 Volt rated cables shall use a 500 Volt insulation resistance tester. The respective test voltage shall be recorded for each cable insulation resistance test result.

It is recommended to use the same insulation resistance test equipment throughout the project to ensure reliable comparative readings at the beginning of the project and at the completion of the project.

Disconnect the airfield lighting series circuit cables from the constant current regulator when performing cable insulation resistance tests (Megger Tests). Test the cables that go to the airfield for the respective airfield lighting series circuit. Connect the cable insulation resistance tester to one of the airfield lighting series circuit cables and to a good ground in the airport electrical vault such as the airport vault ground bus. Conduct the cable insulation resistance test on each respective cable for not less than 90 seconds. Record the test results at the end of the time duration for the test.

FAA Advisory Circular 150/5340-26C Maintenance of Airport Visual Aid Facilities provides guidance on Insulation Resistance Tests. Also refer to the user manual for the respective cable insulation resistance tester. Reasonably new series circuit cables and transformers with good connections should read 500 Mega-Ohms to 1,000 Mega-Ohms or higher. The readings should decrease with age. The resistance value declines over the service life of the circuit; a 10-20 percent decline per year may be considered normal. A yearly decline of 50 percent (4 percent monthly) or greater indicates the existence of a problem, such as a high resistance ground, serious deterioration of the circuit insulation, lightning damage, bad connections, bad splices, cable insulation

Engineering Firm Hanson Professional Services Inc.
Airport Name PRG-Edgar County Airport
Project Replace Runway 9/27
PLASI's with PAPI's
IDA Project PRG-4981
Hanson Project 21A0164C
Date _____

TESTING FORMS

___ Conduct cable insulation resistance test (Megger test) and record Runway 9-27 lighting series circuit cable loop at the vault. Time duration of test should not be less than 90 seconds.

Cable Under Test	Cable Insulation Resistance	Test Voltage	Time Duration
Runway 9-27 series circuit cable			

___ Runway 9-27 lighting series circuit cable loop shall have the resistance tested and recorded at the vault. Use an Ohmmeter and measure the resistance of the series circuit loop at the Vault.

Cable Under Test	Series Circuit Loop Resistance in Ohms
Runway 9-27 series circuit cable	

Engineering Firm Hanson Professional Services Inc.
Airport Name PRG-Edgar County Airport
Project Replace Runway 9/27
PLASI's with PAPI's
IDA Project PRG-4981
Hanson Project 21A0164C
Date _____

TESTING FORMS

___ Conduct cable insulation resistance test (Megger test) and record Taxiway lighting series circuit cable loop at the vault. Time duration of test should not be less than 90 seconds.

Cable Under Test	Cable Insulation Resistance	Test Voltage	Time Duration
Taxiway Lighting series circuit cable			

___ Taxiway lighting series circuit cable loop shall have the resistance tested and recorded at the vault. Use an Ohmmeter and measure the resistance of the series circuit loop at the Vault.

Cable Under Test	Series Circuit Loop Resistance in Ohms
Taxiway Lighting series circuit cable	

Engineering Firm Hanson Professional Services Inc.
Airport Name PRG-Edgar County Airport
Project Replace Runway 9/27
PLASI's with PAPI's
IDA Project PRG-4981
Hanson Project 21A0164C
Date _____

TESTING FORMS

___ Conduct cable insulation resistance test (Megger test) and record Runway 18-36 lighting series circuit cable loop at the vault. Time duration of test should not be less than 90 seconds.

Cable Under Test	Cable Insulation Resistance	Test Voltage	Time Duration
Runway 18-36 series circuit cable			

___ Runway 18-36 lighting series circuit cable loop shall have the resistance tested and recorded at the vault. Use an Ohmmeter and measure the resistance of the series circuit loop at the Vault.

Cable Under Test	Series Circuit Loop Resistance in Ohms
Runway 18-36 series circuit cable	

Engineering Firm Hanson Professional Services Inc.
Airport Name PRG-Edgar County Airport
Project Replace Runway 9/27
PLASI's with PAPI's
IDA Project PRG-4981
Hanson Project 21A0164C
Date _____

TESTING FORMS

___ Conduct cable insulation resistance test (Megger test) and record Runway 9 PLASI feeder circuit cable at the vault. Time duration of test should not be less than 90 seconds.

Cable Under Test	Cable Insulation Resistance	Test Voltage	Time Duration
Runway 9 PLASI Feeder phase conductor			

___ Conduct cable insulation resistance test (Megger test) and record Runway 27 PLASI feeder circuit cable at the vault. Time duration of test should not be less than 90 seconds.

Cable Under Test	Cable Insulation Resistance	Test Voltage	Time Duration
Runway 27 PLASI Feeder phase conductor			

Engineering Firm Hanson Professional Services Inc.
Airport Name PRG-Edgar County Airport
Project Replace Runway 9/27
PLASI's with PAPI's
IDA Project PRG-4981
Hanson Project 21A0164C
Date _____

TESTING FORMS

___ Conduct cable insulation resistance test (Megger test) and record Runway 18 PLASI feeder circuit cable at the vault. Time duration of test should not be less than 90 seconds.

Cable Under Test	Cable Insulation Resistance	Test Voltage	Time Duration
Runway 18 PLASI Feeder phase conductor			

___ Conduct cable insulation resistance test (Megger test) and record Runway 36 PLASI feeder circuit cable at the vault. Time duration of test should not be less than 90 seconds.

Cable Under Test	Cable Insulation Resistance	Test Voltage	Time Duration
Runway 36 PLASI Feeder phase conductor			

Engineering Firm Hanson Professional Services Inc.
Airport Name PRG-Edgar County Airport
Project Replace Runway 9/27
PLASI's with PAPI's
IDA Project PRG-4981
Hanson Project 21A0164C
Date _____

TESTING FORMS

Prior to beginning airfield lighting modifications and/or cable installation each constant current regulator shall be tested with results recorded. **Note: Output voltage measurements are not required for constant current regulators that are not equipped with output voltage meters.**

__ Test Runway 9-27 CCR by Manual Control and record input current, output amperage and output voltage at each step.

STEP	INPUT CURRENT	OUTPUT CURRENT	OUTPUT VOLTS
B10	Phase A:		
	Phase B:		
B30	Phase A:		
	Phase B:		
B100	Phase A:		
	Phase B:		

__ Test Runway 9-27 CCR by L-854 Radio Control (**Photocell Bypass On**) and record input current, output amperage, and output voltage at each step.

STEP	INPUT CURRENT	OUTPUT CURRENT	OUTPUT VOLTS
B10	Phase A:		
	Phase B:		
B30	Phase A:		
	Phase B:		
B100	Phase A:		
	Phase B:		

Engineering Firm Hanson Professional Services Inc.
Airport Name PRG-Edgar County Airport
Project Replace Runway 9/27
PLASI's with PAPI's
IDA Project PRG-4981
Hanson Project 21A0164C
Date _____

TESTING FORMS

__ Test Runway 9-27 CCR by Photocell and record input current, output amperage, and output voltage at respective preset step.

STEP	INPUT CURRENT	OUTPUT CURRENT	OUTPUT VOLTS
B10	Phase A:		
	Phase B:		

Engineering Firm Hanson Professional Services Inc.
Airport Name PRG-Edgar County Airport
Project Replace Runway 9/27
PLASI's with PAPI's
IDA Project PRG-4981
Hanson Project 21A0164C
Date _____

TESTING FORMS

Prior to beginning airfield lighting modifications and/or cable installation each constant current regulator shall be tested with results recorded.

__ Test Backup CCR for Runway 9-27 by Manual Control and record input current and output amperage at each step.

STEP	INPUT CURRENT	OUTPUT CURRENT
B10	Phase A:	
	Phase B:	
B30	Phase A:	
	Phase B:	
B100	Phase A:	
	Phase B:	

__ Test Backup CCR for Runway 9-27 by L-854 Radio Control (**Photocell Bypass On**) and record input current and output amperage at each step.

STEP	INPUT CURRENT	OUTPUT CURRENT
B10	Phase A:	
	Phase B:	
B30	Phase A:	
	Phase B:	
B100	Phase A:	
	Phase B:	

Engineering Firm Hanson Professional Services Inc.
Airport Name PRG-Edgar County Airport
Project Replace Runway 9/27
PLASI's with PAPI's
IDA Project PRG-4981
Hanson Project 21A0164C
Date _____

TESTING FORMS

__ Test Backup CCR for Runway 9-27 by Photocell and record input current and output amperage at respective preset step.

STEP	INPUT CURRENT	OUTPUT CURRENT
B10	Phase A:	
	Phase B:	

Engineering Firm Hanson Professional Services Inc.
Airport Name PRG-Edgar County Airport
Project Replace Runway 9/27
PLASI's with PAPI's
IDA Project PRG-4981
Hanson Project 21A0164C
Date _____

TESTING FORMS

Prior to beginning airfield lighting modifications and/or cable installation each constant current regulator shall be tested with results recorded.

__ Test Taxiway CCR by Manual Control and record input current and output amperage at each step.

STEP	INPUT CURRENT	OUTPUT CURRENT	OUTPUT VOLTS
B10	Phase A:		
	Phase B:		
B30	Phase A:		
	Phase B:		
B100	Phase A:		
	Phase B:		

__ Test Taxiway CCR by L-854 Radio Control (**Photocell Bypass On**) and record input current, output amperage, and output voltage at each step.

STEP	INPUT CURRENT	OUTPUT CURRENT	OUTPUT VOLTS
B10	Phase A:		
	Phase B:		
B30	Phase A:		
	Phase B:		
B100	Phase A:		
	Phase B:		

Engineering Firm Hanson Professional Services Inc.
Airport Name PRG-Edgar County Airport
Project Replace Runway 9/27
PLASI's with PAPI's
IDA Project PRG-4981
Hanson Project 21A0164C
Date _____

TESTING FORMS

Prior to beginning airfield lighting modifications and/or cable installation each constant current regulator shall be tested with results recorded.

__ Test Runway 18-36 CCR by Manual Control and record input current and output amperage at each step.

STEP	INPUT CURRENT	OUTPUT CURRENT	OUTPUT VOLTS
B10	Phase A:		
	Phase B:		
B30	Phase A:		
	Phase B:		
B100	Phase A:		
	Phase B:		

__ Test Runway 18-36 CCR by L-854 Radio Control (**Photocell Bypass On**) and record input current, output amperage, and output voltage at each step.

STEP	INPUT CURRENT	OUTPUT CURRENT	OUTPUT VOLTS
B10	Phase A:		
	Phase B:		
B30	Phase A:		
	Phase B:		
B100	Phase A:		
	Phase B:		

Engineering Firm Hanson Professional Services Inc.
Airport Name PRG-Edgar County Airport
Project Replace Runway 9/27
PLASI's with PAPI's
IDA Project PRG-4981
Hanson Project 21A0164C
Date _____

TESTING FORMS

___ After airfield lighting modifications, additions, and/or upgrades have been completed, Conduct cable insulation resistance test (Megger test) and record Runway 9-27 lighting series circuit cable loop at the vault. Time duration of test should not be less than 90 seconds.

Cable Under Test	Cable Insulation Resistance	Test Voltage	Time Duration
Runway 9-27 series circuit cable			

___ Runway 9-27 lighting series circuit cable loop shall have the resistance tested and recorded at the vault. Use an Ohmmeter and measure the resistance of the series circuit loop at the Vault.

Cable Under Test	Series Circuit Loop Resistance in Ohms
Runway 9-27 series circuit cable	

Engineering Firm Hanson Professional Services Inc.
Airport Name PRG-Edgar County Airport
Project Replace Runway 9/27
PLASI's with PAPI's
IDA Project PRG-4981
Hanson Project 21A0164C
Date _____

TESTING FORMS

___ After airfield lighting modifications, additions, and/or upgrades have been completed, Conduct cable insulation resistance test (Megger test) and record Taxiway lighting series circuit cable loop at the vault. Time duration of test should not be less than 90 seconds.

Cable Under Test	Cable Insulation Resistance	Test Voltage	Time Duration
Taxiway lighting series circuit cable			

___ Taxiway lighting series circuit cable loop shall have the resistance tested and recorded at the vault. Use an Ohmmeter and measure the resistance of the series circuit loop at the Vault.

Cable Under Test	Series Circuit Loop Resistance in Ohms
Taxiway lighting series circuit cable	

Engineering Firm Hanson Professional Services Inc.
Airport Name PRG-Edgar County Airport
Project Replace Runway 9/27
PLASI's with PAPI's
IDA Project PRG-4981
Hanson Project 21A0164C
Date _____

TESTING FORMS

___ After airfield lighting modifications, additions, and/or upgrades have been completed, Conduct cable insulation resistance test (Megger test) and record Runway 18-36 lighting series circuit cable loop at the vault. Time duration of test should not be less than 90 seconds.

Cable Under Test	Cable Insulation Resistance	Test Voltage	Time Duration
Runway 18-36 series circuit cable			

___ Runway 18-36 lighting series circuit cable loop shall have the resistance tested and recorded at the vault. Use an Ohmmeter and measure the resistance of the series circuit loop at the Vault.

Cable Under Test	Series Circuit Loop Resistance in Ohms
Runway 18-36 series circuit cable	

Engineering Firm Hanson Professional Services Inc.
Airport Name PRG-Edgar County Airport
Project Replace Runway 9/27
PLASI's with PAPI's
IDA Project PRG-4981
Hanson Project 21A0164C
Date _____

TESTING FORMS

___ After airfield lighting modifications, additions, and/or upgrades have been completed, conduct cable insulation resistance test (Megger test) and record Runway 9 PAPI feeder circuit cable at the vault. Time duration of test should not be less than 90 seconds.

Cable Under Test	Cable Insulation Resistance	Test Voltage	Time Duration
Runway 9 PAPI Feeder Phase A conductor			
Runway 9 PAPI Feeder Phase B conductor			

___ After airfield lighting modifications, additions, and/or upgrades have been completed, conduct cable insulation resistance test (Megger test) and record Runway 27 PAPI feeder circuit cable at the vault. Time duration of test should not be less than 90 seconds.

Cable Under Test	Cable Insulation Resistance	Test Voltage	Time Duration
Runway 27 PAPI Feeder Phase A conductor			
Runway 27 PAPI Feeder Phase B conductor			

Engineering Firm Hanson Professional Services Inc.
Airport Name PRG-Edgar County Airport
Project Replace Runway 9/27
PLASI's with PAPI's
IDA Project PRG-4981
Hanson Project 21A0164C
Date _____

TESTING FORMS

___ After airfield lighting modifications, additions, and/or upgrades have been completed, conduct cable insulation resistance test (Megger test) and record Runway 18 PLASI feeder circuit cable at the vault. Time duration of test should not be less than 90 seconds.

Cable Under Test	Cable Insulation Resistance	Test Voltage	Time Duration
Runway 18 PLASI Feeder phase conductor			

___ After airfield lighting modifications, additions, and/or upgrades have been completed, conduct cable insulation resistance test (Megger test) and record Runway 36 PLASI feeder circuit cable at the vault. Time duration of test should not be less than 90 seconds.

Cable Under Test	Cable Insulation Resistance	Test Voltage	Time Duration
Runway 36 PLASI Feeder phase conductor			

Engineering Firm	<u>Hanson Professional Services Inc.</u>
Airport Name	<u>PRG-Edgar County Airport</u>
Project	<u>Replace Runway 9/27</u> <u>PLASI's with PAPI's</u>
IDA Project	<u>PRG-4981</u>
Hanson Project	<u>21A0164C</u>
Date	<u></u>

TESTING FORMS

Tests for constant current regulators shall include the following.

1. The respective personnel performing airfield lighting work, vault work, and/or tests shall be familiar with and qualified to work on 5000 Volt airfield lighting series circuits, constant current regulators, and associated airport electrical vault equipment.
2. Prior to conducting tests confirm each constant current regulator has a good and secure frame ground connection to the vault grounding electrode system. The constant current regulator frame ground shall be a minimum #6 AWG copper conductor and UL listed grounding connectors with secure and tight connections. Correct where missing. This is required for safety of personnel.
3. The respective personnel performing tests shall be familiar with the respective test equipment and the use and operation of the test equipment. The Contractor is responsible to employ the services of personnel qualified to perform the respective tests and qualified to work on 5000 Volt airfield lighting series circuits, constant current regulators, and associated airport electrical vault equipment.
4. Test each brightness step and measure and record the input current on Phase A and Phase B for the 240 VAC branch circuit to each CCR. Note: Provide a True RMS Ammeter for current measurements.
5. Test each brightness step and record the CCR output current to the series circuit lighting circuit. Each CCR should be equipped with an output current meter. In the event the output current meter is not working properly or is out of calibration use a True RMS Ammeter for output current measurements and measure the current in the output series circuit conductor.
6. Test each brightness step and record the CCR output voltage for the series circuit lighting circuit. Each CCR should be equipped with an output voltage meter. Where the CCR does not include an output voltage meter, the output voltage measurements are not required. Do not use a 0 to 600 Volt voltmeter to measure voltage across the CCR output terminals due to safety concerns and high voltages at the CCR output.

Engineering Firm Hanson Professional Services Inc.
Airport Name PRG-Edgar County Airport
Project Replace Runway 9/27
PLASI's with PAPI's
IDA Project PRG-4981
Hanson Project 21A0164C
Date _____

TESTING FORMS

After airfield lighting modifications, additions, and/or upgrades have been completed, each constant current regulator shall be tested with results recorded. **Note: Output voltage measurements are not required for constant current regulators that are not equipped with output voltage meters.**

__ Test Runway 9-27 CCR by Manual Control and record input current, output amperage and output voltage at each step.

STEP	INPUT CURRENT	OUTPUT CURRENT	OUTPUT VOLTS
B10	Phase A:		
	Phase B:		
B30	Phase A:		
	Phase B:		
B100	Phase A:		
	Phase B:		

__ Test Runway 9-27 CCR by L-854 Radio Control (**Photocell Bypass On**) and record input current, output amperage, and output voltage at each step.

STEP	INPUT CURRENT	OUTPUT CURRENT	OUTPUT VOLTS
B10	Phase A:		
	Phase B:		
B30	Phase A:		
	Phase B:		
B100	Phase A:		
	Phase B:		

Engineering Firm Hanson Professional Services Inc.
Airport Name PRG-Edgar County Airport
Project Replace Runway 9/27
PLASI's with PAPI's
IDA Project PRG-4981
Hanson Project 21A0164C
Date _____

TESTING FORMS

__ Test Runway 9-27 CCR by Photocell and record input current, output amperage, and output voltage at respective preset step.

STEP	INPUT CURRENT	OUTPUT CURRENT	OUTPUT VOLTS
B10	Phase A:		
	Phase B:		

Engineering Firm Hanson Professional Services Inc.
Airport Name PRG-Edgar County Airport
Project Replace Runway 9/27
PLASI's with PAPI's
IDA Project PRG-4981
Hanson Project 21A0164C
Date _____

TESTING FORMS

After airfield lighting modifications, additions, and/or upgrades have been completed, each constant current regulator shall be tested with results recorded.

__ Test Backup CCR for Runway 9-27 by Manual Control and record input current and output amperage at each step.

STEP	INPUT CURRENT	OUTPUT CURRENT
B10	Phase A:	
	Phase B:	
B30	Phase A:	
	Phase B:	
B100	Phase A:	
	Phase B:	

__ Test Backup CCR for Runway 9-27 by L-854 Radio Control (**Photocell Bypass On**) and record input current and output amperage at each step.

STEP	INPUT CURRENT	OUTPUT CURRENT
B10	Phase A:	
	Phase B:	
B30	Phase A:	
	Phase B:	
B100	Phase A:	
	Phase B:	

Engineering Firm Hanson Professional Services Inc.
Airport Name PRG-Edgar County Airport
Project Replace Runway 9/27
PLASI's with PAPI's
IDA Project PRG-4981
Hanson Project 21A0164C
Date _____

TESTING FORMS

__ Test Backup CCR for Runway 9-27 by Photocell and record input current and output amperage at respective preset step.

STEP	INPUT CURRENT	OUTPUT CURRENT
B10	Phase A:	
	Phase B:	

Engineering Firm Hanson Professional Services Inc.
Airport Name PRG-Edgar County Airport
Project Replace Runway 9/27
PLASI's with PAPI's
IDA Project PRG-4981
Hanson Project 21A0164C
Date _____

TESTING FORMS

After airfield lighting modifications, additions, and/or upgrades have been completed, each constant current regulator shall be tested with results recorded.

__ Test Taxiway CCR by Manual Control and record input current and output amperage at each step.

STEP	INPUT CURRENT	OUTPUT CURRENT	OUTPUT VOLTS
B10	Phase A:		
	Phase B:		
B30	Phase A:		
	Phase B:		
B100	Phase A:		
	Phase B:		

__ Test Taxiway CCR by L-854 Radio Control (**Photocell Bypass On**) and record input current, output amperage, and output voltage at each step.

STEP	INPUT CURRENT	OUTPUT CURRENT	OUTPUT VOLTS
B10	Phase A:		
	Phase B:		
B30	Phase A:		
	Phase B:		
B100	Phase A:		
	Phase B:		

Engineering Firm Hanson Professional Services Inc.
Airport Name PRG-Edgar County Airport
Project Replace Runway 9/27
PLASI's with PAPI's
IDA Project PRG-4981
Hanson Project 21A0164C
Date _____

TESTING FORMS

After airfield lighting modifications, additions, and/or upgrades have been completed, each constant current regulator shall be tested with results recorded.

__ Test Runway 18-36 CCR by Manual Control and record input current and output amperage at each step.

STEP	INPUT CURRENT	OUTPUT CURRENT	OUTPUT VOLTS
B10	Phase A:		
	Phase B:		
B30	Phase A:		
	Phase B:		
B100	Phase A:		
	Phase B:		

__ Test Runway 18-36 CCR by L-854 Radio Control (**Photocell Bypass On**) and record input current, output amperage, and output voltage at each step.

STEP	INPUT CURRENT	OUTPUT CURRENT	OUTPUT VOLTS
B10	Phase A:		
	Phase B:		
B30	Phase A:		
	Phase B:		
B100	Phase A:		
	Phase B:		

APPENDIX B

PRG-Edgar County Airport
Paris, Illinois

PRG-4981

Replace Runway 9/27

Pulse Light Approach Slope Indicators (PLASI's)
with Precision Approach Path Indicators (PAPI's)

PAPI

GROUND CHECK LIST

Airport Identifier:	PRG
Airport Name:	Edgar County Airport
Location:	Edgar County Airport, 15551 Airport Road, Paris, Illinois 61944
FAA ACIP No.:	
IDOT/IDA No.:	PRG-4981
Hanson Project No.:	21A0164C
Date:	
Site Conditions:	

- a. Inspect PAPI to determine that it is installed correctly, at the proper height, at the correct location, level, and properly oriented.
- b. Check all fixture securing screws or bolts to ensure that they have been tightened per manufacturer recommendations. Use an anti-seize compound on bolts made of stainless steel.
- c. Check PAPI to determine that the lenses are clean and unscratched and the channels in front of the lenses are clean.
- d. Test PAPI feeder circuits for continuity and insulation resistance to ground. Observe and record megger test for PAPI feeder circuit conductors.

Cable Under Test	Cable Insulation Resistance	Test Voltage	Time Duration
Phase A Conductor			
Phase B Conductor			

- e. Check fuses and circuit breakers to determine if they are of the proper rating.

- f. Check PAPI to determine that it is properly oriented with respect to the runway longitudinal sides and the threshold. Check PAPI for proper location.

- g. Check identification number or legend plate for PAPI unit to determine that the respective identification at the installation is as assigned in the Plans.

- h. Check equipment covered by FAA specifications to determine if the manufacturers have supplied certified equipment. Also check the equipment for general conformance with requirements of the Plans, Specifications, and Special Provisions.

- i. Inspect all cables, wiring, and splices to obtain assurance that the installation is per FAA AC 150/5370-10H Standard Specifications for Construction of Airports, Item L-108, the Plans, the National Electrical Code, and local codes. Inspect and test insulation resistance of underground cables before backfilling.

- j. Check all ducts and duct markers to determine that the installation is per FAA AC 150/5370-10H Standard Specifications for Construction of Airports, Item L-110, and the Plans. Inspect underground ducts before backfill is made.

- k. Check the input voltage at the power and control circuits to determine that the voltage is within limits required for proper equipment operation. Select the proper voltage tap on equipment where taps are provided. Circuitry should also be checked per the manufacturer's requirements.

- l. Check base plates for damage during installation and refinish according to manufacturer's instructions and as acceptable to the Engineer.

- m. Check the current or voltage at the lamps to determine if the regulator current or supply voltage is within specified tolerance. If a current or voltage exceeds rated values, the lamp life will be reduced.

n. Record nameplate data for PAPI.

Manufacturer:	
FAA Type:	
Part No.:	
ID No.:	
Power Requirement:	

o. Test PAPI by respective control system and confirm proper operation.

p. Check the size and type of feeder conductor from the vault or power source to the PAPI.

q. Make sure PAPI has good ground. Test and record ground resistance of ground rod installation at each PAPI Unit.

PAPI LIGHT HOUSING UNIT	Ground Resistance Measurement in Ohms
PAPI Light Housing Unit #1 (Closest to the Runway Pavement)	
PAPI Light Housing Unit #2	

r. Check to make sure equipment ground wires were run from the PAPI Power and Control Unit to each PAPI.

- s. Observe and record the aiming angle of each PAPI Light Housing Unit.

PAPI LIGHT HOUSING UNIT	MEASURED AIMING ANGLE
PAPI Light Housing Unit #1 (Closest to the Runway Pavement)	
PAPI Light Housing Unit #2	

- t. Observe operation of the PAPI Power and Control Unit photocell and confirm proper operation of day/night brightness levels.
- u. Confirm Operation and Maintenance Manuals are provided for each PAPI unit.
- v. Record input voltage and amperage at the PAPI under operation.

DAY TIME OPERATION	
Input Voltage:	
Input Amperage:	
NIGHT TIME OPERATION	
Input Voltage:	
Input Amperage:	
RECORD VOLTAGE AT POWER SOURCE	
Voltage:	

w. Ground Check test results submitted by:

Name:	
Company:	
Date:	