



EAST SLOPEWALL PLAN



NOTES:

- Slopewall shall be reinforced with welded wire fabric, 6" x 6" W4.0 x W4.0, weighing 58 lbs. per 100 sq. ft. This fabric shall be lapped with the existing wire fabric a length of one mesh
- 2, Existing wire mesh shall be cleaned and incorporated into the new construction. Cost included with Slope Wall Removal.

BILL OF MATERIAL

Item	Unit	Quantity
Epoxy Crack Injection	Foot	74
Slope Wall Removal	Sg. Yd.	1
Slope Wall 6 Inch	Sq. Yd.	1

DESIGNED - LM REVISED -SLOPEWALL REPAIRS STATE OF ILLINOIS CHECKED ~ GG REVISED STRUCTURE NO. 045-3094 DRAWN REVISED **DEPARTMENT OF TRANSPORTATION** IMPROVING YOUR WORLD CHECKED - DSB REVISED SHEET NO. 12 OF 17 SHEETS

COUNTY TOTAL SHEET NO.

KANE 38 25

CONTRACT NO. 63661 F.A.U. RTE. 3895 SECTION 08-15104-01-BR ILLINOIS FED. AID PROJECT