


PLAN
(D' = Designated Skew Angle)



ELEVATION

DIMENSION 'E'

GRADE	'D'=0°		'D'=5°		'D'=10°	
	UPGRADE END	DOWNGRADE END	UPGRADE END	DOWNGRADE END	UPGRADE END	DOWNGRADE END
0%	2 7/8"	2 7/8"	2 7/8"	2 7/8"	2 7/8"	2 7/8"
Over 0% to 1%	2 7/8"	2 7/8"	2 7/8"	3"	2 3/4"	3"
Over 1% to 2%	2 7/8"	2 7/8"	2 7/8"	3"	2 3/8"	3 3/8"
Over 2% to 3%	2 7/8"	2 7/8"	2 7/8"	3 3/8"	2 3/8"	3 3/8"
Over 3% to 4%	2 7/8"	2 7/8"	2 3/8"	3 1/2"	1 3/4"	4"


- NOTES**
- The Backwall and the portion of the Wingwalls above the bonded construction joint shall be cast against the in-place beam.
 - Reinforcement bars shall conform to the requirements of A.A.S.H.T.O. M-31 or M-322, Grade 60.
 - Space reinforcement in cap to miss anchor bolts.

MAXIMUM PILE LOADS


SPAN	TONS
60'	35
70'	39
75'	41

DESIGN STRESSES


f'c = 3,500 psi
fy = 60,000 psi




SECTION THRU ABUTMENT
(At Right Angles)



BAR s



BAR u



BAR h1

BILL OF MATERIAL FOR ONE ABUTMENT

Bar	No.	Size	Length	Shape
h	20	#4	5'-0"	—
h1	4	#4	5'-3"	—
h2	6	#4	33'-0"	—
p	10	#7	33'-0"	—
s	31	#4	9'-5"	□
u	8	#6	11'-1"	□
v	8	#4	3'-8"	—
v1	8	#4	4'-8"	—
v2	64	#4	4'-5"	—
Concrete Structures				11.7 Cu. Yds.
Reinforcement Bars				1450 Lb.

P.P.C. DECK BEAMS	
PILE BENT ABUTMENT	
30' RDWY.	33" BMS. 'D'=0°, 5° OR 10°
STANDARD CA-3033-10	

Illinois Department of Transportation
 PASSED APRIL 4, 2005
 Theresia Demas (Signature)
 Engineer of Bridge Design
 APPROVED APRIL 4, 2005
 Ralph E. Anderson (Signature)
 Engineer of Bridges and Structures