


TRENCH DETAIL
N.T.S.


NOTES

- TRENCHES WITH MORE THAN 2 CABLES SHALL BE INCREASED 3" IN WIDTH FOR EACH ADDITIONAL CABLE. IF SPECIFIED ON PLANS, TWO PARALLEL TRENCHES MAY BE CONSTRUCTED.
- 2. DEPTH OF TRENCHES SHALL BE AS SHOWN ABOVE UNLESS OTHERWISE SPECIFIED ON THE PLANS.
- 3. SAND BACKFILL SHALL BE USED IF THE EXISTING SOIL DOES NOT MEET THE BACKFILL REQUIREMENTS.
- 4. ALL DISTURBED SURFACES SHALL BE RESTORED TO THEIR ORIGINAL CONDITION, COST IS INCIDENTAL TO ITEM 108

NOTE: AT CONTRACTOR'S OPTION, CABLE PLOWING MAY BE USED IN LIEU OF TRENCHING



CABLE JACKET REMOVED, "PENCIL" INSULATION PLASTIC BODY MOLD-HEAT SHRINKABLE TUBING WITH INTERNAL ADHESIVE, PER SPECS. POURING SPOUT FACTORY MOLDED L-823 TRANSFORMER LEADS 2" AFTER SHRINKING (TYP.) RESIN -∠RECEPTACLE END ADDITIONAL ADHESIVE COMPOUND FILLER COMPRESSION TYPE SLEEVE FIELD INSTALLED L-823 CONNECTOR, CRIMP WITH TOOL RECEPTACLE END RECOMMENDED BY MANUFACTURER SEAL ENDS OF MOLD WITH TAPE PROVIDED IN SPLICE KIT FOR IN-LINE CONNECTIONS OF EXISTING FOR SPLICES AT TAXIWAY LIGHTS AND SIGNS. CABLES CUT DURING CONSTRUCTIONS. TYPE A TYPE C



NOT TO BE USED IN THIS PROJECT UNLESS OTHERWISE DIRECTED BY ENGINEER

TYPE B

PLUG END

ADDITIONAL ADHESIVE COMPOUND FILLER
FIELD INSTALLED L-823
RECEPTACLE END

FOR SPLICES AT TAXIWAY LIGHTS AND SIGNS.

TYPE D

2" AFTER

SHRINKING (TYP.)

HEAT SHRINKABLE TUBING WITH


FACTORY MOLDED L-823 TRANSFORMER LEADS

INTERNAL ADHESIVE, PER SPECS.

CABLE SPLICES

N.T.S. NOTES

- 1. INSIDE DIAMETER OF CONNECTOR SHALL PROPERLY MATCH THE OUTSIDE DIAMETER OF CABLE.
- 2. THE COST OF FURNISHING AND INSTALLING ALL SPLICE MATERIALS SHALL BE INCIDENTAL TO THE ASSOCIATED CABLE ITEMS.
- THE CONTRACTOR SHALL HAVE A MINIMUM OF TWO (2) TYPE A SPLICE KITS ON THE JOB SITE AT ALL TIMES FOR EMERGENCY REPAIRS.



TURF CABLE / SPLICE MARKER

NOTES

- CABLE MARKERS SHALL BE INSTALLED AT ALL BENDS AND EVERY 200' ALONG THE HOMERUN.
- 2. ITEM 610 CONCRETE SHALL BE USED.
- 4. THE COST OF FURNISHING AND INSTALLING NEW MARKERS SHALL BE INCIDENTAL TO THE ASSOCIATED ITEMS.
- 5. 0.049 CU. YD. CONCRETE PER MARKER.
- A MARKER CONFORMING TO THIS DETAIL MARKED "SPLICE" SHALL BE INSTALLED AT ALL SPLICE LOCATIONS NOT IN LIGHT CANS OR MANHOLES.

