


INSTALL A NONCORROSIVE DISC OF 2" MINIMUM DIAMETER WITH THE NUMBER PERMANENTLY STAMPED, CUT OUT, OR ENGRAVED UNDER THE HEAD OF THE BASE PLATE BOLT OR ATTACHED TO LIGHT FLANGE WITH SET SCREW.

LEGENDS SHOWN ARE FOR ILLUSTRATIVE PURPOSES ONLY. CONTRACTOR TO COORDINATE LEGEND WITH AIRPORT.

THE CONTRACTOR SHALL NUMBER THE EXISTING/PROPOSED LIGHTS AND SIGNS IN EACH CIRCUIT STARTING AT THE HOMERUN CONTINUING AROUND THE ENTIRE CIRCUIT BACK TO THE HOMERUN.

AIRFIELD SIGNS SHALL BE TAGGED & NUMBERED.



LIGHT IDENTIFICATION DETAIL


MOUND SLIGHTLY, GRADE & SEED 4" MIN. GRADE BACKFILL RESTORATION PER SPEC. 108-3.5 INSULATED CABLE IN UNIT DUCT INSULATED CABLE IN UNIT DUCT INSULATED CABLE IN UNIT DUCT

NOTES

- TRENCHES WITH MORE THAN 2 CABLES SHALL BE INCREASED 3" IN WIDTH FOR EACH ADDITIONAL CABLE. IF SPECIFIED ON PLANS, TWO PARALLEL TRENCHES MAY BE CONSTRUCTED.
- DEPTH OF TRENCHES SHALL BE AS SHOWN ABOVE UNLESS OTHERWISE SPECIFIED ON THE PLANS.
- SAND BACKFILL SHALL BE USED IF THE EXISTING SOIL DOES NOT MEET THE BACKFILL REQUIREMENTS.
- 4. ALL DISTURBED SURFACES SHALL BE RESTORED TO THEIR ORIGINAL CONDITION. COST IS INCIDENTAL TO ITEM 108.

TRENCH DETAIL

N.T.S.



N.T.S.



 THE CONTRACTOR SHALL HAVE A MINIMUM OF TWO (2) TYPE A SPLICE KITS ON THE JOB SITE AT ALL TIMES FOR EMERGENCY REPAIRS.

CABLE SPLICES

N.T.S.

NOTES

1. INSIDE DIAMETER OF CONNECTOR SHALL PROPERLY MATCH THE

OUTSIDE DIAMETER OF CABLE.

RESIN -

RECOMMENDED BY MANUFACTURER
SEAL ENDS OF MOLD WITH

FOR IN-LINE CONNECTIONS OF EXISTING CABLES CUT DURING CONSTRUCTION.

TYPE A


COMPRESSION TYPE SLEEVE CONNECTOR. CRIMP WITH TOOL

TAPE PROVIDED IN SPLICE KIT

CABLE JACKET REMOVED,


"PENCIL" INSULATION
PLASTIC BODY MOLD-

POURING SPOUT



FOR SPLICES AT TAXIWAY LIGHTS AND SIGNS.

TYPE C



FOR SPLICES AT TAXIWAY LIGHTS AND SIGNS.

TYPE D

REVISIONS

NUMBER BY DATE

O 1 2

THIS BAR IS EQUAL TO 2"
AT FULL SCALE (34X22).

CAOO2 K:\SpringlieldAp\0503507\Draw\Sheets

FILE: 58_ELECDETO2.dwg
UPDATE BY: Dave Allen
PLOT DATE: 2/6/2006 4:41 PM
tbinfo

SPRINGFIELD AIRPORT AUTHORITY
ABRAHAM LINCOLN CAPITAL AIRPORT
ABRAHAM LINCOLN CAPITAL AIRPORT
SILTING ENGRESS
INC. 184-000613
WIDEN TAXIWAY A - CONSTRUCT PERIMETER
ELECTRICAL DETAILS 2

DESIGN BY: RLV
DRAWN BY: DPA
CHECKED BY: CW
APPROVED BY: CW

APPROVED BY: (UV)
DATE: 1/23/06
JOB No: 0503507

IL. PROJ. NO. SPI-3555 AIP PROJ. NO. 3-17-0096-44

SHEET 58 OF 83 SHEETS