



ME-08A CONDUIT EXPANSION / DEFLECTION COUPLING DETAIL
EXPANSION/DEFLECTION FITTING, O-Z/GEDNEY AX/DX OR APPROVED EQUAL



SPLICING ELECTRIC CABLES BASIC MATERIALS AND METHODS DETAIL NOT TO SCALE

-- PRE-FORMED STRUCTURAL JOINT, REFER TO STRUCTURAL DRAWINGS FOR EXPANSION JOINT LOCATIONS. TYPE DX FITTING-METALLIC TO NONMETALLIC CONDUIT
COUPLING (AS REQUIRED) - METALLIC TO NON-METALLIC CONDUIT COUPLING (AS REQUIRED) THE CONTRACTOR MUST PROVIDE
A DEFLECTION FITTING AT EACH
LOCATION WHERE THE CONDUIT RUN
TRAVERSES AN EXPANSION JOINT

ME-08B CONDUIT DEFLECTION FITTING DETAIL
DEFLECTION FITTING, 0-Z/GEDNEY DX OR APPROVED EQUAL
NOT TO SCALE



F.A.I. SECTION 90/94 2003-031I COUNTY TOTAL SHEE'S NO. 976 50 СООК TO STA. STA. FED. ROAD DIST. NO. 1 ILLINOIS FED. AID PROJECT

62583

NOTES:

1. SEE DRAWINGS ME-01 AND ME-02 FOR ELECTRICAL SYMBOLS AND ABBREVIATIONS.

ME-OBD BREAKOUT BOOT DETAIL NOT TO SCALE

REVISIONS NAME DATE

ILLINOIS DEPARTMENT OF TRANSPORTATION F.A.I. 90/94 (DAN RYAN EXPRESSWAY) 31st STREET TO I-57

CABLE TERMINATION AND CONDUIT EXPANSION/DEFLECTION FITTING DETAILS

SCALE: NOT TO SCALE DATE: October 29, 2004 DRAWN BY: KCM CHECKED BY: WDS

ME-08

CTE ENGINEERS CONSOER TOWNSEND ENVIRODINE ENGINEERS, INC. 303 EAST WACKER DRIVE, SUITE 600 CHICAGO ILLINOIS 60601-5212, PHONE: (312) 938-0300