

F.A.I. RTE.	SECTION		COUNTY		TOTAL	SHEET NO.
90/94	2003-03	I	C00	K	976	145
STA.	1436+00.00	TO	STA.	1446	+50.00	
FED. RO	AD DIST. NO. 1	ILLINOIS	FED.	AID	PROJECT	

## 62583

## NOTES:

- 1. SEE DRAWINGS ME-O1 AND ME-O2 FOR ELECTRICAL SYMBOLS AND ABBREVIATIONS.
- 2. COORDINATE ALL WORK WITH IDOT CONTRACT NO. 62693.
- UNLESS NOTED OTHERWISE, ALL ITEMS AND WORK SHOWN IN HEAVY LINE WEIGHT ON THIS DRAWING ARE PROPOSED ITEMS AND WORK.
- 4. SEE DRAWINGS ES-04 AND ES-05 FOR HIGH MAST LIGHT TOWER SCHEDULE.
- ALL HIGH MAST TOWER FOUNDATIONS SHOWN ON THIS DRAWING WILL BE INSTALLED BY OTHERS IN IDOT CONTRACT NO. 62693.
- ALL CONCRETE ENCASED DUCTBANKS SHOWN ON THIS DRAWING WILL BE INSTALLED BY OTHERS IN A SEPARATE CONTRACT AND WILL BE CONSIDERED AN EXISTING CONDITION FOR THIS CONTRACT.
- 7. THE CONDUIT FOR ALL RETAINING WALL MOUNTED HIGH MAST TOWERS MUST BE INSTALLED AS SHOWN ON DRAWING ME-O3.
- 8. RUN PARALLEL RACEWAYS IN COMMON TRENCH. THE FINAL INSTALLATION LOCATIONS OF THE LIGHTING RACEWAYS MUST BE COORDINATED WITH THE RACEWAYS SHOWN ON THE SURVEILLANCE PLANS.
- 9. PROVIDE A TEMPORARY POWER FEED TO THE EXISTING SIGN TRUSS STRUCTURE LIGHTING UNITS. SEE DRAWING ME-25 FOR TEMPORARY POWER FEED TO SIGN STRUCTURE DETAILS.
- 10. ALL UNIT DUCT BETWEEN STA, 1439+50 AND HIGH MAST LIGHT TOWER 7 TAB2 MUST BE INSTALLED IN FRONT OF THE RETAINING WALL FOOTING AT A DEPTH EQUAL TO THE TOP OF THE FOOTING TO AVOID CONFLICTS WITH FUTURE IDOT CONTRACT NO. 62303.
- 11. ALL UNIT DUCT BETWEEN HIGH MAST LIGHT TOWERS 7 TAB2 AND 7 TAB1 MUST BE INSTALLED AT A MINIMUM TRENCH DEPTH OF 5'-0" TO AVOID CONFLICTS WITH FUTURE IDOT CONTRACT NO. 62303.

0 50' 100 1" = 50'

RL05-30

CHECKED BY: WDS

REVISIONS	TI.	INOIS DEPARTM	NT OF TRANSPORTATION		
NAME DATE			N RYAN EXPRESSWAY)		
		31s† \$7	REET TO I-57		
		DOADWAY	LIGHTING PLANS		
			PROVEMENTS 2005		
	COME.	1// EO/	DOLUMN DV. CIL		

DATE: October 29, 2004

CONSOER TOWNSEND ENVIRONMENT ENGINEERS, INC.
303 EAST WACKER DRIVE, SUITE 600
CHICAGO LILKIOIS 6606-1522, PHONE (312) 938-0300