→②→ Z ò T ്ഗ HH3402 TYPE S1 (SPECIAL) 7 T1CD5 S. WELLS ST. 10 R-0 ++++++ UL14 NOTE 6 TCIE - R 3" RGC PUSHED LINE STA, 1494-1 SHEET RLO6-35 <u>T1-3</u> NOTE 6 AVC - MC - - M TD16 - (1) TC15 UL13 ·ν⊢ NOTE 6 1485+00 com b b com -- ⊳ 1490+00 -- ⊳ ⊳ --- CKT. C&D: 3°4, 1*6 GND, 1/4" DD IN 3" RGC IN TRENCH NGTE 5 2485+00 TF16 (R) TELS R TF15 • 0 TE16 - S.- WENTWORTH- AV.

F.A.I. RTE.	F.A.I. SECTION			COUNTY			IL TS	SHEE NO.
90/94	2003-0311		COOK		976		199	
STA. 1482+50.00 TO STA. 1494+50.00								
FED. R	DAD DIST. NO. 1	ILLIN	015	FED.	AID	PROJE	СТ	

62583

NOTES:

- 1. SEE DRAWINGS ME-01 AND ME-02 FOR ELECTRICAL SYMBOLS AND ABBREVIATIONS.
- 2. COORDINATE ALL WORK WITH IDOT CONTRACT NOS. 62300 AND 62302.
- UNLESS NOTED OTHERWISE, ALL ITEMS AND WORK SHOWN IN HEAVY LINE WEIGHT ON THIS DRAWING ARE PROPOSED ITEMS AND WORK.
- 4. SEE IDOT STANDARD DRAWINGS FOR ELECTRIC CONNECTION TO SIGN STRUCTURE DETAILS.
- 5. PROVIDE A TEMPORARY POWER FEED TO SIGN STRUCTURE T1-3 AS SHOWN. THE 3 INCH RIGID STEEL CONDUIT SLEEVE SHALL BE TRENCHED IN THE SHOULDER 30 INCHES BELOW TOP OF THE FINISHED PAVEMENT.
- 6. EXISTING TEMPORARY AERIAL CABLES TO BE REMOVED WILL BE INCLUDED FOR PAYMENT WITH THE "REMOVAL OF EXISTING LIGHTING UNIT, SALVAGE" PAY ITEM.
- 7. EXISTING TEMPORARY AERIAL CABLES TO BE REMOVED WILL BE INCLUDED FOR PAYMENT WITH THE "WOODEN POLE REMOVAL" PAY ITEM. ABANDON ANY EXISTING CONDUIT UTILIZED FOR THE TEMPORARY FEED IN PLACE.
- 8. REMOVE EXISTING SIGN LUMINAIRES, DISCONNECT THE EXISTING SIGN LIGHTING ELECTRIC SERVICE, AND REMOVE CABLES BACK TO THE NEAREST SPLICE. STRUCTURE AND FOUNDATION WILL BE REMOVED BY OTHERS.

0 50' 100

RL06-34

REVISION	IS	ILLINOIS DEPARTMENT OF TRANSPORTATION
NAME	DATE	F.A.I. 90/94 (DAN RYAN EXPRESSWAY)
		31st STREET TO I-57
		ROADWAY LIGHTING PLANS PROPOSED IMPROVEMENTS 2006

SCALE: 1"=50'
DATE: October 29, 2004

DRAWN BY: CJM.
CHECKED BY: WDS

CTE ENGINEERS

CONSOER TOWNSEND ENWRODYNE ENGINEERS, INC.
303 EAST WACKER DRIVE, SUITE 600
CHICAGO ILLINOIS 60601-522, PHONE: 1312) 938-0300