FED. ROAD DIST. NO. _ ILLINOIS FED. AID PROJECT 62583 EXISTING CABLE TRAY-EXISTING POWER PANEL-PP VIDEO-EQUIPMENT AND RACK NETWORK— EQUIPMENT AND RACK SURVEILLANCE— EQUIPMENT AND RACK SPARE EQUIPMENT— RACK HAR EQUIPMENT— AND RACK PP-04 | PP-05 INSTALL NEW CABLE TRAY (MATCH— EXISTING CABLE TRAY MANUFACTURER) (1) PP-03 FRONT FRONT FRONT INSTALL DUPLEX OUTLET ON-TOP OF EQUIPMENT RACK (TYP) EXISTING HVAC UNIT -EXISTING 2" PVC STUBOUT - EXISTING 4" PVC STUBOUTS EXISTING CABLE TRAY-EXISTING I-57 SHELTER I-57 SHELTER FLOOR PLAN NOT TO SCALE

NOTES:
1. EQUIPMENT LAYOUT BASED ON PRELIMINARY
SHELTER INSPECTION. CONTRACTOR MAY NEED TO
FIELD LOCATE EQUIPMENT RACKS AND EQUIPMENT.
COORDINATE WITH THE ENGINEER THE FINAL LOCATION
OF ALL EQUIPMENT.
2. CONTRACTOR SHALL MAINTAIN A MINIMUM OF 36" CLEARANCE
WHEN INSTALLING NEW RACKS AND EQUIPMENT.

(1) (2) *12, (1) *12 GND, 3/4" EMT CONDUIT

COMM-95

RTE.	SECTION	COUNTY	SHEETS	NO.
94/90	2003-0311	COOK	976	861
STA.	TO STA.			

REVISIONS		ILLINOIS DEPARTMENT OF TRANSPORTATION			ON
NAME	DATE	ILLINOIS DEFANTMENT OF TRANSPORTATION			UN I
		F.A.I.	. 94/90 (DAN	RYAN EXPRESS	SWAY)
		31st STREET to I-57			
		I-57 SHELTER (RO4)			
		EQUIPMENT LAYOUT			
		SCALE:	NOT TO SCALE	DRAWN BY: DH	I į
		DATE:	October 29, 2004	CHECKED BY:	JEZ

AND KEICEU

ONE NORTH FRANKLIN CHICAGO, IL 60606
FAX: G122 251-3015
FAX: G122 251-3015