
"ORLAND PARK VILLAGE CENTER" SIGN-HH *1, NOTE 3 - COMED SERVICE-3/C *2 XLP-TYPE USE SERVICE CABLES IN 2" RGS CONDUIT, NOTE 2 **US-45 (LAGRANGE ROAD)**

NOTES:

- 1. SEE DRAWING GE-1 FOR ELECTRICAL SYMBOL LIST, ABBREVIATIONS, AND GENERAL NOTES.
- 2. CONTRACTOR SHALL HAVE COMED DISCONNECT SERVICE WIRES FOR CONTROLLER *3 AT SERVICE TRANSFORMER IDENTIFIED ON DRAWING EL-2. PULL BACK COMED SERVICE WIRES TO SERVICE TRANSFORMER, CUT 2" CONDUIT, AND REMOVE TO EXISTING CONTROLLER *3 LOCATION. THE COST OF THIS WORK SHALL BE INCLUDED IN THE COST OF "RELOCATE ELECTRIC SERVICE" PAY ITEM. SEPARATE PAYMENT WILL NOT BE MADE.
- 3. CONTRACTOR SHALL REMOVE EXISTING FOUNDATION FOR LIGHTING CONTROLLER *3, UNDER THE "REMOVAL OF LIGHTING CONTROLLER FOUNDATION" PAY ITEM. TAG LOAD WIRES AND PULL LOAD WIRES BACK TO HH *1. REMOVE 2½" PVC CONDUIT BETWEEN EXISTING CONTROLLER LOCATION AND HH *1. ALL WORK SHALL BE INCLUDED IN THE "RELOCATE EXISTING LIGHTING CONTROLLER" PAY ITEM. SEPARATE PAYMENT WILL NOT BE MADE.



McDonough Assoc Engineers / Architects 130 East Randolph Street Chica

				and the same of th
E NAME =	USER NAME = Jlatour	DESIGNED -	JL W	REVISED -
60K64-SHT-EL3.dgn		DRAWN ~	CJM	REVISED -
	PLOT SCALE = 1:10	CHECKED -	КМҮ	REVISED -
	PLOT DATE = 1/27/2011	DATE -	12/17/10	REVISED -

STATE OF ILLINOIS
DEPARTMENT OF TRANSPORTATION

MULTI-USE PATH LIGHTING				F.A.P RTE.	SECTION	COUNTY	TO SHE		
1	CONTROLLER #3 ELECTRICAL DEMOLITION PLAN				330	73 R-B	соок	1.	
							EL-3	CONTRACT	NC
	SCALE: 1" = 10"	SHEET NO. 2 OF 2	SHEETS	STA.	TO STA.	ILLINOIS FED. AID PROJECT			