

VERIFIED UTILITY INFORMATION

TEST HOLE #	SIZE & TYPE	NORTHING	EASTING	STATION	OFFSET	EXISTING TOP ELEVATION	EXISTING CUT	REFERENCE ELEVATION	COMMENTS
1	3" BT	1871637.377	987526.719	111+89.96	18.00' LT	667.77'	3.13'	670.90'	UTILITY QUALITY "A"
2	8" G	1871629.113	987561.947	111+76.85	15.73' RT	666.38'	4.21'	670.59'	UTILITY QUALITY "A"
3	8" G	1870974.591	987710.256	105+02.36	16.77' RT	666.75'	3.96'	670.71'	UTILITY QUALITY "A"
4	8" G	1870788.058	987769.285	103+06.57	16.13' RT	666.67'	3.72'	670.39'	UTILITY QUALITY "A"
5	30" G	1870746.703	987798.705	102+58.21	31.54' RT	663.99'	7.29'	671.28'	UTILITY QUALITY "A"
6	SEE NOTE	1870745.822	987738.257	102+75.86	26.30' LT	660.39'	9.28'	669.67'	UTILITY QUALITY "A"
7	3" BT	1870635.946	987787.804	101+56.05	12.62' LT	667.97'	2.25'	670.22'	UTILITY QUALITY "A"
8	18" W	1870684.633	987760.683	102+10.69	23.60' LT	664.85'	4.66'	669.51'	UTILITY QUALITY "A"
9	8" G	1871248.560	987632.412	107+88.38	14.85' RT	667.17'	3.68'	670.85'	UTILITY QUALITY "A"

NOTES

TH # 6 - BRIEFY GOT A VISUAL ON THE CROWN OF PIPE BUT DUE TO EXCESSIVE GROUNDWATER AND SOIL CONTINUALLY COLLAPSING WITHIN THE EXCAVATED HOLE WE WERE NOT ABLE TO VERIFY THE SIZE OF PIPE. RECORDS SHOW A 34" CASING.

ABBREVIATIONS

BT = TELEPHONE
G = GAS
W = WATER

ALL INFORMATION SHOWN WAS OBTAINED FROM A LOCATION SURVEY.



Checked By: *[Signature]*
Date: 12/10/10

TBE Job No. IL09510426

F.A.D. RTE. 2503	SECTION TWP-1-T	COUNTY KANE	TOTAL SHEETS 43	SHEET NO. 32
Contract No. 60K07			JOB NO. :	

DESIGNED EG	REVISED
DRAWN KLC	REVISED
CHECKED KRS	REVISED
DATE 12/10/10	REVISED

STATE OF ILLINOIS DEPARTMENT OF TRANSPORTATION

IL RT. 25 at Pierce Street to Grant Street, North Aurora

SCALE: SHEET NO. STA. TO STA.

FED. ROAD DIST. NO. [ILLINOIS] JOB NO. :