

TEMPORARY WIRING NOTES:

- 1. SECURE AERIAL CABLE ATTACHMENTS TO POLE WITH POLE BANDS AT A HEIGHT THAT WILL PROVIDE THE REQUIRED 18 FOOT NATIONAL ELECTRICAL CODE CONDUCTOR CLEARANCE OVER THE ROADWAY. REFER TO DETAIL 2, SHEET LT-09.
- 2. INSERT CIRCUIT CONDUCTORS THROUGH POLE CAP. SPLICE CONDUCTORS
 TO THE LIGHTING CIRCUITS AT THE POLE BASE. REFER TO DETAIL 3,
 SHEET LT-09. REPLACE POLE CAP AFTER TEMPORARY CONDUCTORS ARE REMOVED.
- 3. CIRCUIT IDENTIFICATION IS ASSUMED AND IS PROVIDED FOR CLARIFICATION OF CIRCUIT ROUTING ONLY.

			GRAPH:	IC SCAL	.E		
			ME	TERS			
20	0	20		40	60	80	100
50	0	50	100	150	200	250	
			FEET				

LT-05

FILE			
PLOT	DATE	=	1/26/

		DESIGNED	-	I.A.B.	REVISED	-
SPAAN Te	DRAWN	_	M.K.J.	REVISED	wa .	
311 S. Wacker Drive, Suite 2400	phone: 312.277.8800 fax: 312.277.8808 web: www.SpsanTech.com	CHECKED	-	A.D.O.	REVISED	
Chicago, Illinois 60606		DATE	-	JANUARY, 2009	REVISED	-

STATE	OF	ILLINOIS	
DEPARTMENT	OF	TRANSPORTATION	

TEMPORARY LIGHTING PLAN						F.A.U. RTE.	SECTION	COUNTY	TOTAL SHEETS	SHEET NO.	
	LEMONT ROAD						2612	3104 B-1-I-2	COOK	80	29
LEINION HOAD								CONTRACT	NO. 6	OD76	
	SCALE: 1" = 50'	SHEET NO.	OF	SHEETS	STA.	TO STA.	FED. ROAD DIST. NO. 1 ILLINOIS FED. AID PROJECT				