


NOTE: TOP OF MARKER SHALL BE FLUSH WITH FINISHED PAVEMENT SURFACE. MARKER MAY BE INSTALLED IN A DRILLED HOLE AND SECURED WITH EPOXY GLUE.

**BITUMINOUS** PAVEMENT MARKER


2. BITUMINOUS PAVEMENT DUCT MARKER AND CONCRETE DUCT MARKER TO BE PROVIDED AT EACH END OF EACH DUCT AS SHOWN ON THE-LOCATION PLAN. FOR CONCRETE PAVEMENT, THE LETTER "D" SHALL BE IMPRESSED IN THE PAVEMENT INSTEAD OF THE MARKER. THE LETTER SHALL BE FORMED AS DESCRIBED IN NOTE 4.

CABLE MARKERS SHALL BE PLACED AT CHANGES OF DIRECTION AND EVERY 200' ALONG CABLE RUNS.


LETTERS 4" HIGH, 3" WIDE WITH WIDTH OF STROKE 1/2" AND 1/4" DEEP. ALL LETTERS, NUMBERS AND ARROWS TO BE IMPRESSED.



## DUCT DIRECTIONAL BORE



# CABLE IN TRENCH





### HANSON PROFESSIONAL SERVICES INC.

815 Commerce Drive Suite 200 Oak Brook, Illinois 60523 Telephone: 630.990.3800 Fax: 630.990.3801




#### CITY OF DIXON, ILLINOIS

Post Office Box 386 Dixon, Illinois 61021 Telephone: 815.288.1485

DIXON MUNICIPAL AIRPORT CHARLES R. WALGREEN FIELD OVERLAY RUNWAY 8-26, REHABILITATE HANGAR PAVEMENTS

AIP PROJECT NO. 3-17-0036-B5 IDA PROJECT NO. C73-3313



12 MARCH 2004

Sheet Title

# ELECTRICAL CABLE DETAILS

ТММ	03/29
Layout By	Cate
TMM	03/29
Designed By	Date
RMH	03/31
Reviewed By	Date

73

TURF AND PAVEMENT DUCT AND CABLE MARKERS