


HEAVY DUTY INSULATED PULLEY CLEVIS WOOD POLE MESSENGER TIED TO INSULATOR -WITH FACTORY FORMED CABLE TIE BARE COPPER GROUND WIRE EVERY THIRD POLE TO LUMINAIRE GROUND CLAMP NEUTRAL CONDUCTOR AWG BARE COPPER GROUND WIRE PHASE CONDUCTOR - WATERPROOF FUSEHOLDER & FUSE WATERPROOF INSULATION PIERCING TAP CONNECTOR - WATERPROOF FUSEHOLDER AND SOLID NEUTRAL SLUG.

TEMPORARY LIGHT POLE ATTACHMENT DETAIL

TEMPORARY LIGHT POLE DETAIL

NOTES:

1. ALL DIMENSIONS IN INCHES (MILLIMETERS)
UNLESS OTHERWISE INDICATED



AERIAL CABLE CONNECTION DETAIL N.T.S.

FILE NAME = D160E63-RDL-4.dgn PLOT DATE = 1/26/2009

DESIGNED - R.A.S. REVISED SPAAN Tech, Inc. DRAWN - R.P.J. REVISED CHECKED - I.A.B. REVISED 311 South Wacker Drive, Suite 2400 phone: 312.277.8800 fax: 312.277.8808 Chicago, II 60606 phone: 312.277.8808 web: www.SpantTech.com DATE JANUARY 26, 2009 REVISED

STATE OF ILLINOIS **DEPARTMENT OF TRANSPORTATION**

				Y LIGHT						
U.S. 30	OVER	EAST	&	WEST E	BKAN	ICH	BIG	ROCK	CREEK	
NIE.	CUCET	NO	OF.	CUEET	c c	TA		т.	O CTA	

RDI -4 OF 4 TOTAL SHEET NO. 40 17 COUNTY KANE

SECTION

117 R-2B-R CONTRACT NO. 60E63 SCALE: NONE