



T A B L E

UNIT	ANCHOR BOLT SIZE				ALUM. PED.	
	1"	1 1/4"	1 1/2"	3/4"		
	POLE GAUGES					
	7 GA.	3 GA.	7 GA.	3 GA.	7 GA.	3 GA.
A	7/16"	7/16"	1/8"	1/16"	1/8"	7/8"
B	1"	1"	1 1/4"	1 1/4"	1 1/2"	3/4"
C	1/4"	1/4"	5/16"	5/16"	3/8"	3/16"
D	5/32"	5/32"	1/4"	1/4"	1/4"	5/32"
E	1"	1"	1 1/4"	1 1/2"	1 1/2"	5/8"

CONSTRUCTION METHOD FOR "DOUBLE-NUT" INSTALLATION OF POLES AND PEDESTALS

CITY OF CHICAGO
 DEPT. OF STREETS AND SANITATION
 BUREAU OF ELECTRICITY
 DIVISION OF ELECTRICAL ENGINEERING

DESIGNED BY: EUGENE GEBULIS
 SUPERVISING ENGINEER: ELEC. DESIGN ENGR. P.E. S. S.

ENGINEER: M. S. S.

PROJECT NO. 837

DATE: 22 1 1950 SCALE: 1" = 1" DATE: 6-7-85

11-2711 ST. BORDEN/JOHN
 11-6-2009, 03:24:4
 I:\DOCUMENT\930860\CIVIL\DON\KHO087-DGN
 1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63

REVISIONS	
NAME	DATE

ILLINOIS DEPARTMENT OF TRANSPORTATION
 112TH PLACE OVER
 F.A.I ROUTE 57 (INTERSTATE 57)

ELECTRICAL STANDARD DETAILS

SCALE: NONE DRAWN BY: N/A
 DATE: 01/16/09 CHECKED BY: N/A

TENG
 TENG & ASSOCIATES, INC.
 ENGINEERS/ARCHITECTS/PLANNERS
 205 N. MICHIGAN AVE., CHICAGO, IL 60601
 TELEPHONE: 312/616-0000