

DS-12M10

7 - 1 - 10

Hutchison Engineering, Inc. Jacksonville & Shorewood, Illinois	USER NAME = tcody	DESIGNED - BAN	REVISED ~		DRAINAGE SCUPPER DS-12M10		SECTION	COUNTY TOTAL SHEET
	PLOT SCALE = NONE PLOT DATE = 8/22/2011	CHECKED - JOH	REVISED ~	STATE OF ILLINOIS	STRUCTURE NO. 055-0063	315	55-3HB	McDonough 103 50
	PLOT DATE = 8/22/2011	DRAWN - TAC CHECKED - BAN	REVISED -	DEPARTMENT OF TRANSPORTATION	SHEET NO. 19 OF 35 SHEETS			CONTRACT NO. 68A40



Notes:

All cast iron parts shall be gray iron conforming to the requirements of AASHTO M 105, Class 35B,

Bolts, anchor studs, washers and nuts shall conform to the requirements of ASTM A 307 and shall be galvanized according to AASHTO M 232.

All castings shall conform to the requirements of AASHTO M 306.

Downspouts located on the exterior side of a painted steel fascia beam shall be painted with the finish coat specified for the exterior side of the fascia beam.

As an alternate, bolts, anchor studs, washers and nuts may be stainless steel according to Article 1006.29(d) of the Standard Specifications.

Structural steel weldments of equal sections and of the same configuration may be substituted for the cast iron scupper frame. Fillet or full penetration welds shall be used for the weldments. Details shall be submitted to the Engineer for approval. Structural steel weldments shall not be substituted for the cast iron scupper grate. Structural steel frames and downspouts shall be galvanized according to AASHTO M111.

The Contractor shall take appropriate measures to assure that Protective Coat is not applied to the scupper.

Cost of the Grate, Frame, Downspout, Anchor Studs, Bolts, Washers and Nuts including complete installation of the scupper shall be paid for at the contract unit price each for Drainage Scupper, DS-12M10.

Alternate fiberglass downspout conforming to ASTM D 2996 with a short-time rupture strength hoop tensile stress of 30,000 psi min. may be used in lieu of the cast iron or steel equivalent.

	BILL	OF	MATER	RIAL	
	ITEM	UNIT	QUANT]]		
Drainage	Scupper.	DS-12	?M10	EACH	6